

A Multi-Period Optimization Model for Energy Planning with CO₂ Emission Consideration

by

Hamidreza Mirzaesmaeeli

A thesis
presented to the University of Waterloo
in fulfillment of the
thesis requirement for the degree of
Master of Applied Science
in
Chemical Engineering

Waterloo, Ontario, Canada, 2007

© Hamidreza Mirzaesmaeeli, 2007

Author's Declaration

I hereby declare that I am the sole author of this thesis. This is a true copy of the thesis, including any required final revisions, as accepted by my examiners.

I understand that my thesis may be made electronically available to the public.

Hamidreza Mirzaesmaeeli

Abstract

Planning for Ontario's future energy supply mix is a very challenging undertaking which requires consideration of various drivers and decision criteria. From the literature review conducted, no published work has been found addressing the multi-period energy planning problem with CO₂ emission constraints and the option of carbon capture and storage (CCS). The objective of this project was to develop a novel multi-period mixed-integer non-linear programming (MINLP) model that is able to realize the optimal mix of energy supply sources which will meet current and future electricity demand, CO₂ emission targets, and lower the overall cost of electricity. This model was implemented in GAMS (General Algebraic Modeling System).

The model was formulated using an objective function that minimizes the net present value of the cost of electricity (COE) over a time horizon of 14 years. The formulation incorporates several time dependent parameters such as forecasted energy demand, fuel price variability, construction lead time, conservation initiatives, and increase in fixed operational and maintenance costs over time.

The model was applied to two case studies in order to examine the economical, structural, and environmental effects that would result if Ontario's electricity sector was required to reduce its CO₂ emissions to a specific limit. The first case study examined a base case scenario in which no CO₂ limits were imposed. The second case study examined a scenario in which Ontario's electricity sector must comply with CO₂ emission limits similar to the Kyoto target of 6% below 1990 levels.

The results indicate that in order to meet the CO₂ targets of 6% below 1990 levels, Nanticoke, Atikokan, and Thunder Bay coal-fired power plants must be fuel-switched, and Lambton coal-fired power plant must be retrofitted with a CCS system. Furthermore, a total CO₂ reduction of approximately 32% was achieved when compared to the base case. The total cost associated with reducing the CO₂ emissions to 6% below 1990 levels, per ton of CO₂, was \$48.79 / ton CO₂ reduced. The total expenditure for Case Study II (CO₂ limit of 6% below 1990 levels) was approximately 10.1% higher than for the base case.

This model offers many potential benefits to Ontario's energy sector. In addition to providing an optimal solution for meeting future electricity demand, it can help Ontario meet its emissions targets while minimizing the overall cost of electricity. Furthermore, although this project was aimed at Ontario's future energy supply mix, it could also be readily applied to other regions or even countries as a whole.

Acknowledgements

I would like to gratefully acknowledge my wonderful supervisors, Dr. Ali Elkamel, Dr. Peter L. Douglas, and Dr. Eric Croiset, for their continuous support, encouragement, and invaluable guidance.

My overwhelming thanks go to my friends from the CO₂ Capture and Storage System Group. I would specially like to thank Flora Chui, Colin Alie, and Guillermo Ordorica.

Finally, I would like to acknowledge the financial support of CANMET.

Dedication

This thesis is dedicated to my wonderful parents, my two amazing brothers, and my beloved Danijela, without whom my life would be empty.

Table of Contents

Author’s Declaration	ii
Abstract	iii
Acknowledgements	iv
Dedication	v
Table of Contents	vi
List of Figures	ix
List of Tables	xi
List of Acronyms	xii

CHAPTER 1

1.1 Ontario’s Emerging Energy Challenge.....	1
1.2 Motivation for the Research	4
1.3 Research Objectives.....	5
1.4 Contribution of the Research.....	6
1.5 Methodology.....	7
1.6 Organization of Thesis.....	9

CHAPTER 2

2.1 Overview	10
2.2 Supply Technologies	10
2.2.1 Nuclear Power Stations.....	10
2.2.2 Natural Gas Power Stations	11
2.2.2.1 Simple Cycle Gas Turbine	12
2.2.2.2 Natural Gas Combined Cycle (NGCC)	12
2.2.2.3 Cogeneration.....	12
2.2.3 Coal Power Stations	12
2.2.3.1 Pulverized Coal Power Stations.....	12
2.2.3.2 Integrated Gasification Combined Cycle (IGCC).....	13
2.2.4 Hydroelectric Power Stations	14
2.2.5 Wind Power Plants.....	14
2.2.6 Ontario-Manitoba Interconnection Project	15
2.2.7 Comparison of Supply Technologies.....	15
2.3 Carbon Capture and Storage.....	16
2.3.1 Carbon Capture Technologies.....	17

2.3.2	Carbon Dioxide Sequestration in Ontario	18
2.4	Ontario’s Current Energy Mix	20
2.4.1	Nuclear	20
2.4.2	Coal	22
2.4.3	Hydroelectric.....	22
2.4.4	Natural Gas.....	22
2.5	Future Outlook.....	23
2.5.1	Electricity Demand Forecast	23
2.5.2	Fuel Price Forecast	27
2.5.2.1	Natural Gas Price Forecast	28
2.5.2.2	Coal Price Forecast	29
2.5.3	Energy Conservation Strategy.....	30
2.6	Journal Review	33
CHAPTER 3		
3.1	Model Formulation	34
3.2	Objective Function	36
3.3	Model Constraints.....	39
3.4	GAMS Model Statistics and Logic.....	45
CHAPTER 4		
4.1	Description of Case Studies.....	47
4.2	Data for Case Studies	48
4.2.1	Existing Power Plants	48
4.2.2	New Power Plants	53
4.2.3	Forecasted Data	59
4.3	Assumptions of Case Studies	60
4.4	Defining Power Allocation and Installed Capacity	61
4.5	Case Study I: Base Case	61
4.5.1	Fleet Structure: New construction, fuel-switching, and CCS retrofit.....	62
4.5.2	Power Allocation and Electricity Production	63
4.5.3	Economic Analysis.....	70
4.5.4	Carbon Dioxide Emissions	73
4.6	Case Study II: CO ₂ emissions 6% below 1990 levels	75

4.6.1	Fleet Structure: New construction, fuel-switching, and CCS retrofit.....	76
4.6.2	Power Allocation and Electricity Production	78
4.6.3	Economic Analysis.....	86
4.6.4	Carbon Dioxide Emissions	90
CHAPTER 5		
4.7	Comparison of Case Studies.....	92
5.1	Conclusions	97
5.2	Recommendations for Future Work	101
	Bibliography.....	103
	Appendix A	105
	Appendix B.....	108
	Appendix C.....	110

List of Figures

FIGURE 1 – ONTARIO’S CURRENT INSTALLED GENERATION CAPACITY IN TERMS OF PERCENTILE	1
FIGURE 2 – ONTARIO’S DEMAND GROWTH AND INSTALLED GENERATING CAPACITY PORTFOLIO OVER THE NEXT 20 YEARS	2
FIGURE 3 – HISTORICAL ENERGY PRODUCTION (TWH) AND CARBON DIOXIDE EMISSIONS FROM OPG	3
FIGURE 4- CANADA’S EMISSION TREND AND KYOTO’S EMISSION TARGET	4
FIGURE 5 - FIVE PHASE METHODOLOGY FOR THESIS COMPLETION	8
FIGURE 6 – SCHEMATIC DIAGRAM OF TYPICAL CANDU 6 NUCLEAR POWER PLANT.	11
FIGURE 7 – SCHEMATIC DIAGRAM OF A TYPICAL PULVERIZED COAL POWER STATIONS	13
FIGURE 8 – SCHEMATIC DIAGRAM OF TYPICAL INTEGRATED GASIFICATION COMBINED CYCLE POWER STATION	14
FIGURE 9 - SCHEMATIC DIAGRAM OF A HYPOTHETICAL CARBON CAPTURE AND STORAGE SYSTEM	17
FIGURE 10 – GEOGRAPHICAL LOCATION OF TWO POTENTIAL RESERVOIRS THAT MAY BE UTILIZED FOR CO ₂ STORAGE	19
FIGURE 11 – TYPICAL LOAD-DURATION CURVE	23
FIGURE 12 – LINEAR APPROXIMATION OF LOAD-DURATION CURVE	24
FIGURE 13 – ONTARIO’S FORECASTED ANNUAL ENERGY DEMAND (GWH) FOR LOW, MEDIAN AND UPPER BOUND.	26
FIGURE 14 – ONTARIO’S FORECASTED ANNUAL PEAK-LOAD DEMAND (MW) FOR LOW, MEDIAN, AND UPPER BOUND.....	26
FIGURE 15 – ONTARIO’S FORECASTED ANNUAL BASE-LOAD DEMAND (MW) FOR LOW, MEDIAN, AND UPPER BOUND.....	27
FIGURE 16 - NATURAL GAS FORECAST FROM NEB SHOWING BOTH SUPPLY-PLUS AND TECHNO-VERT SCENARIOS	29
FIGURE 17 – COAL PRICE FORECAST FROM NEB	30
FIGURE 18 - SAMPLE MATRIX USED IN THE CONSTRUCTION LEAD TIME CONSTRAINT	41
FIGURE 19 – GRAPHICAL REPRESENTATION OF SAMPLE PROBLEM.....	42
FIGURE 20 – LOGIC FOR THE OPTIMIZATION MODEL	46
FIGURE 21 - CASE SCENARIO I: TOTAL POWER ALLOCATED (MW) FROM EACH SUPPLY TECHNOLOGY	63
FIGURE 22 - CASE SCENARIO I: TOTAL POWER ALLOCATION IN TERMS OF PERCENTAGE	64
FIGURE 23 – CASE STUDY I: POWER ALLOCATED TO MEET BASE-LOAD DEMAND (MW).....	65
FIGURE 24 – CASE STUDY I: POWER ALLOCATED TO MEET PEAK-LOAD DEMAND (MW)	66
FIGURE 25 – CASE STUDY I: TOTAL ELECTRICITY PRODUCTION (TWH) FROM ALL SUPPLY SOURCES.....	67
FIGURE 26 – CASE STUDY I: THE PERCENT OF ELECTRICITY PRODUCTION FROM EACH SUPPLY SOURCE.....	68
FIGURE 27 - CASE STUDY I: ELECTRICITY PRODUCTION GENERATED TO MEET BASE-LOAD DEMAND (MW).....	69
FIGURE 28 - CASE STUDY I: ELECTRICITY PRODUCTION GENERATED TO MEET PEAK-LOAD DEMAND (MW)	69
FIGURE 29– CASE STUDY I: ANNUAL EXPENDITURE OF ENTIRE ELECTRICITY SECTOR.....	70
FIGURE 30 - CASE STUDY I: TOTAL EXPENDITURE FOR ENTIRE STUDY PERIOD (2006-2020)	72
FIGURE 31 - CASE STUDY I: ANNUAL COST OF ELECTRICITY (COE) FOR THE ENTIRE STUDY PERIOD (2006-2020)	73
FIGURE 32 - CASE STUDY I: ANNUAL CARBON DIOXIDE EMISSIONS FROM ENTIRE FLEET.....	74
FIGURE 33 - CASE STUDY II: TOTAL POWER ALLOCATED (MW) FROM EACH SUPPLY TECHNOLOGY	78

FIGURE 34 - CASE STUDY II: TOTAL POWER ALLOCATION IN TERMS OF PERCENTAGE	79
FIGURE 35 - CASE STUDY II: POWER ALLOCATED TO MEET BASE-LOAD DEMAND (MW)	81
FIGURE 36 - CASE STUDY II: POWER ALLOCATED TO MEET PEAK-LOAD DEMAND (MW)	81
FIGURE 37 - CASE STUDY II: TOTAL ELECTRICITY PRODUCTION (TWH) FROM ALL SUPPLY SOURCES	83
FIGURE 38 – CASE STUDY II: THE PERCENT OF ELECTRICITY PRODUCTION FROM EACH SUPPLY SOURCE	83
FIGURE 39 - CASE STUDY II: ELECTRICITY PRODUCTION GENERATED TO MEET BASE-LOAD DEMAND (MW).....	85
FIGURE 40 - CASE STUDY II: ELECTRICITY PRODUCTION GENERATED TO MEET PEAK-LOAD DEMAND (MW)	85
FIGURE 41 - CASE STUDY II: ANNUAL EXPENDITURE OF ENTIRE ELECTRICITY SECTOR.....	86
FIGURE 42 - CASE STUDY II: TOTAL EXPENDITURE FOR ENTIRE STUDY PERIOD (2006-2020)	88
FIGURE 43 - CASE STUDY II: ANNUAL COST OF ELECTRICITY (COE) FOR THE ENTIRE STUDY PERIOD (2006-2020)	89
FIGURE 44 - CASE STUDY II: ANNUAL CARBON DIOXIDE EMISSIONS FROM ENTIRE FLEET.....	90

List of Tables

TABLE 1 – ONTARIO’S CURRENT INSTALLED CAPACITY BASED ON SUPPLY SOURCES	20
TABLE 2 – OPERATIONAL AND OUT-OF-SERVICE NUCLEAR UNITS IN ONTARIO	21
TABLE 3 – EXISTING COAL-FIRED POWER PLANTS IN ONTARIO	22
TABLE 4 – FORECASTED PEAK DEMAND (MW) AND ENERGY DEMAND (TWH) FROM NAVIGANT CONSULTING LTD	25
TABLE 5 – ESTIMATED ENERGY EFFICIENCY PEAK-DEMAND SAVINGS (MW) BY ICF	32
TABLE 6 – ESTIMATED ENERGY EFFICIENCY SAVINGS (TWH) BY ICF	32
TABLE 7 – GAMS MODEL STATISTICS	45
TABLE 8 – ECONOMIC AND OPERATIONAL PARAMETERS OF EXISTING COAL-POWER PLANTS	48
TABLE 9 – OPERATIONAL AND ECONOMIC PARAMETERS FOR EXISTING NATURAL GAS POWER PLANTS	49
TABLE 10 – ESTIMATED REFURBISHMENT COST FOR NUCLEAR UNITS IN ONTARIO	50
TABLE 11 – CAPACITY (MW) PROFILE FOR ALL 20 NUCLEAR UNITS IN ONTARIO.....	51
TABLE 12 - OPERATIONAL AND ECONOMIC PARAMETERS FOR EXISTING NUCLEAR UNITS.....	52
TABLE 13 - OPERATIONAL AND ECONOMIC PARAMETERS FOR EXISTING HYDROELECTRIC STATIONS IN ONTARIO	52
TABLE 14 – ECONOMIC AND OPERATIONAL PARAMETERS FOR PULVERIZED COAL (PC) POWER PLANTS	55
TABLE 15 - ECONOMIC AND OPERATIONAL PARAMETERS FOR INTEGRATED GASIFICATION COMBINED CYCLE (IGCC) POWER UNITS	56
TABLE 16 - ECONOMIC AND OPERATIONAL PARAMETERS FOR NATURAL GAS COMBINED CYCLE (NGCC) POWER UNITS.....	57
TABLE 17 - ECONOMIC AND OPERATIONAL PARAMETERS FOR NUCLEAR POWER UNITS.....	58
TABLE 18 - ECONOMIC AND OPERATIONAL PARAMETERS FOR LONG TERM OUT-OF-PROVINCE HYDROELECTRIC IMPORTS	58
TABLE 19 – CASE STUDY I:CONSTRUCTION OF NEW POWER STATIONS	62
TABLE 20– CASE STUDY II:CONSTRUCTION OF NEW POWER STATIONS	76
TABLE 21 - CASE STUDY II: EXISTING COAL POWER PLANTS THAT HAVE BEEN FUEL-SWITCHED TO NATURAL GAS.....	77
TABLE 22 - CASE STUDY II: EXISTING COAL POWER PLANTS THAT HAVE BEEN RETROFITTED WITH A CCS SYSTEM.....	77
TABLE 23 - COMPARISON OF NEW POWER PLANTS BUILT FOR CASE STUDY I AND II.....	92
TABLE 24 – COMPARISON OF FUEL-SWITCHING AND CCS RETROFIT IMPLEMENTATION BETWEEN CASE STUDY I AND II.....	93
TABLE 25 – COMPARISON OF TOTAL EXPENDITURE (2006 \$CAN BILLION) BETWEEN CASE STUDY I AND II	95
TABLE 26 - ONTARIO’S FORECASTED ANNUAL ENERGY DEMAND (GWH) FOR LOW, MEDIAN AND UPPER BOUND.....	105
TABLE 27 - ONTARIO’S FORECASTED ANNUAL PEAK-LOAD DEMAND (MW) FOR LOW, MEDIAN, AND UPPER BOUND.....	106
TABLE 28 - ONTARIO’S FORECASTED ANNUAL PEAK-LOAD DEMAND (MW) FOR LOW, MEDIAN, AND UPPER BOUND.....	107
TABLE 29 – FORECASTED NG PRICES FROM NATIONAL ENERGY BOARD	108
TABLE 30 - COAL PRICE FORECAST FROM NATIONAL ENERGY BOARD	109

List of Acronyms

CANDU	CANada Deuterium Uranium
CCS	Carbon capture and storage
CDM	Conservation and Demand Management
CO ₂	Carbon dioxide
COE	Cost of electricity
EIA	Energy Information Administration
GAMS	General Algebraic Modeling System
GHG	Greenhouse gas
IECM	Integrated Environmental Control Model
IESO	Independent Electricity System Operator
IGCC	Integrated gasification combined cycle
LSFCR	Large Scale Fuel Channel Replacement
MEA	Monoethanolamine
MILP	Mixed-integer linear programming
MINLP	Mixed-integer non-linear programming
Mt	Megatonnes
MW	Megawatts
MWh	Megawatt-hour
NEB	National Energy Board
NG	Natural gas
NGCC	Natural gas combined cycle
O&M	Operating and maintenance
OMI	Ontario-Manitoba interconnection
OPA	Ontario Power Authority
OPG	Ontario Power Generation
PC	Pulverized coal combustion
SP	Supply-Push
TV	Techno-Vert
TWh	Terawatt-hour

Chapter 1

1.1 Ontario's Emerging Energy Challenge

Currently, Ontario's operable generation capacity equals approximately 30,662 MW from all sources (Ontario Power Authority, 2005). As shown in Figure 1, 37% of total capacity can be attributed to nuclear sources, 26% is renewable, 21% is coal-fired, and the remaining 16% consists of gas and oil fueled sources.




Figure 1 – Ontario's current installed generation capacity in terms of percentile (Ontario Power Authority, 2005).

Ontario's electricity sector faces one of the most challenging times in its history. While the demand for electricity has increased due to economic growth and rising population, the electricity sector's capacity has decreased over the past decade (Ontario Power Authority, 2005).

As shown in Figure 2, Ontario's supply capacity is projected to decline over the next two decades with a rapid decline in supply emerging in the next several years. Two major factors contribute to this decline in supply capacity. Firstly, it can be seen that Ontario's coal-fired capacity will be completely removed

from the electricity supply mix by 2009. This is mainly due to Ontario’s current government legislating the closure of all coal-fired plants within the next few years. Secondly, nuclear capacity declines sharply due to the retirement of many of the existing nuclear units. The combination of these two factors will decrease Ontario’s installed capacity by approximately 17,316 MW in the next twenty years.




Figure 2 -Ontario’s demand growth and installed generating capacity portfolio over the next 20 years (Ontario Power Authority, 2005).

In the meantime, Ontario’s demand increases steadily over the next two decades. If Ontario’s current consumption and demand continue, the required resources rise from 27,000 MW in 2006 to approximately 37,000 MW in 2025.

The decline of supply and increase in demand results in a potential energy gap of 24,000 MW by year 2025. A solution must be found to fill this energy gap and meet the long-term capacity needs.

To further complicate Ontario’s future supply-demand shortfall problem, greenhouse gas (GHG) emissions must be taken into consideration when evaluating potential solutions. Carbon dioxide (CO₂) is suspected to be the principal GHG responsible for global warming and climate change. With a growing concern with global warming and its effects on the environment, the industry is striving to reduce its CO₂ emissions.

Ontario Power Generation (OPG), which accounts for 70% of electricity generation in Ontario, has had wavering CO₂ emissions over the past few decades. From Figure 3, CO₂ emissions from OPG have varied from a high of 37 million tons in 2000 to a low of 15 million tons in 1994. The variability in CO₂ emissions from OPG is mainly due to changes in electricity demand and technological improvements. Since 1995, OPG has entered into a voluntary commitment to reduce their GHG emissions to levels equivalent to the 1990 baseline. Though some progress in achieving this target has been made over the past few years, OPG has often had to resort to buying CO₂ emission reduction credits to achieve their voluntary targets. As of this time, no long-term sustainable strategy has been established by OPG to address their ongoing CO₂ emission challenge.




Figure 3 – Historical energy production (TWh) and carbon dioxide emissions from OPG (Ontario Power Generation, 2007).

The ratification of the international Kyoto protocol imposes additional pressure for the Canadian government to reduce its CO₂ emissions. Under the Kyoto protocol, which was signed by the Canadian government in 1998 and ratified in 2002, the country agreed to reduce GHG emissions by 6% below 1990 levels by 2008-2010.

Although the Kyoto directive is to reduce GHG emissions, there has been an increasing trend in emissions in Canada for the past several years. In 2003, Canada contributed about 740 Megatonnes (Mt) of CO₂ equivalent of GHGs to the atmosphere, an increase of about 3% over the recorded emissions from 2002 (Figure 4). This increase in GHG emissions is significantly greater than the 1% increase which occurred between 2001 and 2002. If no mitigating measures are taken, it is estimated that Canada's GHG emissions will rise to 809 Mt by the year 2010 (Environment Canada, 2005).




Figure 4- Canada's emission trend and Kyoto's emission target (Environment Canada, 2005).

1.2 Motivation for the Research

As discussed in Section 1.1, Ontario is facing a large energy gap due to increasing demand and a decline in installed generating capacity. Furthermore, as environmental regulations become more stringent, there will be an increasing need to reduce the amount of GHGs and other pollutants emitted to the environment. Consideration must be given to meeting the rising energy demand in both an environmentally sound and cost-effective manner. In light of all the issues discussed, Ontario must find a sustainable energy mix in order to realize its future challenges.

There are various supply technologies available that could be used to help meet Ontario's energy demand. These supply options differ based on a few factors, including economical, environmental, and operational characteristics. Some technologies offer lower capital and operating cost at high emission

rates, while other supply options have higher associated costs but lower environmental impacts. Furthermore, there are several options available for pollutant mitigation, such as Carbon Capture and Storage (CCS). The underlining question then becomes what mix of supply technologies and pollutant mitigation options should be selected to meet Ontario's energy demand and environmental limits at a minimal cost. This is the question that this thesis aims to answer and its main motivation.

1.3 Research Objectives

Planning for Ontario's future energy supply mix is a very challenging undertaking which requires consideration of various drivers and decision criteria. From the literature review conducted, no prior work has been found addressing the problem of finding the optimal strategy for energy planning with CO₂ emission constraints and the option to implement CCS. The objective of this thesis is to develop a novel optimization model in order to realize the optimal mix of energy supply sources, with consideration for CO₂ emissions.

This project aims to develop a deterministic multi-period mixed-integer non-linear programming (MINLP) model that is able to realize the optimal mix of energy supply sources which will meet current and future electricity demand, CO₂ emission targets, and lower the overall cost of electricity. This model is implemented in GAMS (General Algebraic Modeling System).

The model is formulated using an objective function that minimizes the net present value of the cost of electricity (COE) over a time horizon of 14 years. The formulation incorporates several time dependent parameters such as forecasted energy demand, fuel price variability, construction lead time, conservation initiatives, and increase in fixed operational and maintenance costs over time. Although this project is aimed at Ontario's future energy supply mix, it could also be readily applied to other regions or even countries as a whole.

The specific goals and deliverables of this thesis work are as follows:

- To formulate a deterministic multi-period MINLP model that is able to realize the optimal mix of energy supply sources which will meet Ontario's current and future electricity demand, CO₂ emission targets, and lower the overall cost of electricity.
- To program and implement the model in GAMS.

- To acquire detailed data on various supply options that can be used as parameters for the model.
- To examine the cost and feasibility of using CCS in Ontario.
- To apply the model to case studies examining the impact of legislative actions that would force Ontario's electricity sector to reduce CO₂ emissions to a specific limit. The relative impact is examined based on economical, structural, and environmental affects.

1.4 Contribution of the Research

This model offers many potential benefits to Ontario's energy sector. Firstly, a novel deterministic multi-period MINLP model is developed that can be used to determine an optimal mix of energy sources needed to meet Ontario's current and future energy demand. Such a model is particularly important in light of the energy gap Ontario faces in the future. Furthermore, the research work aims to meet Ontario's CO₂ emission targets while minimizing the overall cost of electricity.

The application of the model to case studies will aid in understanding the role of different supply options in Ontario and their impact on overall cost and environment. In recent years, there has been a lot of focus on the use of CCS as a potential CO₂ mitigation option. The case studies examined in this thesis will help determine the feasibility of such CO₂ mitigation options in Ontario, and when they would be best implemented.

Though the model formulation is complex, the model is implemented in GAMS employing a user-friendly interface that makes it simple for future users to change parameters and implement different case studies. Although this project is aimed at Ontario's future energy supply mix, it could also be readily applied to other regions or even countries as a whole.

1.5 Methodology

The methodology of the project can be broken down into 5 main phases. The first phase involves defining the problem statement. The second phase focuses on conducting a thorough literature review on current and past research involving multi-period optimization planning. The third and fourth phase of the project involves gathering data and developing the mathematical model respectively. Finally, the last phase of the project consists of developing possible case studies for the model. Figure 5 outlines and briefly discusses the 5 main phases of the project.




Figure 5 - Five phase methodology for thesis completion. The five phases involve: defining the problem statement, conducting a literature review, gathering data, developing the model, and implementation of case studies.

1.6 Organization of Thesis

The remainder of this dissertation is organized into four chapters. Chapter 2 provides a detailed background on potential supply technologies and CO₂ mitigating options. Moreover, this Chapter gives an overview of Ontario's current energy mix and projected future outlooks. The last section of Chapter 2 provides a journal review on current and past research done in the field of multi-period optimization planning.

Chapter 3 of this thesis presents the mathematical formulation for the deterministic multi-period MINLP model. Furthermore, this chapter presents the GAMS model statistics and provides a discussion in regards to solving the MINLP model.

Chapter 4 details the case studies used to implement the mathematical model developed in the previous chapter. Moreover, it contains data for the different parameters needed in the model and provides a comparative analysis between the case studies.

Finally, Chapter 5 contains the concluding remarks and presents recommendations for future work.

Chapter 2

2.1 Overview

The following sections provide background information for the mathematical formulation and the case studies discussed in the upcoming chapters. The first section describes and provides the technical background for the different supply technologies discussed in this thesis. Section 2.3 describes the methodology behind current Carbon Capture and Storage (CCS) technologies and provides information on potential CO₂ sequestration sites in Ontario. The sections that follow outline background information regarding Ontario's current energy mix and projected future outlooks. The last section of this chapter provides a journal review on current and past research done in the field of multi-period optimization planning.

2.2 Supply Technologies

2.2.1 Nuclear Power Stations

Nuclear power stations produce, contain, and control the energy obtained from splitting of Uranium atoms. Nuclear reactors act like large steam engines. The energy released from electric power plants is used to heat water and produce steam, which then drives the turbine-generators to produce electricity. Just like fossil fuel plants use burning of coal, oil or gas as a heat source, nuclear power stations use heat given off from the splitting of U₂₃₅ atoms for its heat source.

The most common type of nuclear reactors are Pressurized Water Reactors, comprising 59 percent of reactor types used worldwide (Naini, Walden, Pinno, Stogran, & Mutysheva, 2005). These reactors can use either light water or heavy water to control the speed at which the atoms travel and hence increase the amount of energy released from fission of Uranium atoms. An example of a Pressurized Heavy Water Reactor (PHWR) is CANDU (CANada Deuterium Uranium) reactor technology. Figure 6 shows a typical CANDU plant.




Figure 6 – Schematic diagram of typical CANDU 6 nuclear power plant (Naini et al., 2005).

A CANDU plant uses uranium as a fuel source. Uranium atoms are split in the reactor, giving off energy in the form of heat. This heat is then used to boil water in steam generators, producing high pressure steam which is used to turn the blades of a turbine. The turbines turn the electrical generators which produce electricity that is sent to the customers.

2.2.2 Natural Gas Power Stations

Natural gas power stations use natural gas as a source of fuel. There are two types of turbines that can be used to provide power to natural gas power stations for electricity production: steam turbines or gas turbines. Steam turbine systems use high temperature and pressure steam to transfer energy to rotating turbine blades, while gas turbines use gas expansion. The turbines are then used to turn electrical generators for production of electricity.

There are three types of technologies that can be used in natural gas power stations: simple cycle gas turbine, natural gas combined cycle turbine and cogeneration turbine. Each technology is discussed in more detail in the following sections. A fourth type, fuel cells, is also available but will not be discussed here.

2.2.2.1 Simple Cycle Gas Turbine

Simple cycle gas turbines compress air in an air compressor. This compressed air is used to burn natural gas in a combustion chamber. The resulting high temperature combustion gas and air mixture expands in the turbine, driving an electrical generator to produce electricity.

2.2.2.2 Natural Gas Combined Cycle (NGCC)

Natural gas combined cycle (NGCC) power plants produce electricity from a combination of a gas cycle and a steam cycle. The gas cycle is identical to the one described in the simple cycle gas turbine section (refer to Section 2.2.2.1). In addition to the gas cycle, the waste heat of the exhaust gases leaving the gas turbine is used for steam generation in a heat exchanger. The steam generated from the heat exchanger is used to drive a steam generator and produce additional electricity.

2.2.2.3 Cogeneration

Cogeneration is similar to NGCC, and uses exhaust gases leaving the gas cycle as feed to a heat exchanger. However, whereas NGCC uses steam produced from the heat exchanger to drive a steam generator and produce additional electricity, cogeneration uses the thermal energy of the steam directly for purposes such as industrial processes or water heating. Hence, in cogeneration, the steam is not used to produce electricity.

2.2.3 Coal Power Stations

Coal power plants use coal as a fuel source for power generation. Technologies used in coal power plants are categorized into two groups: combustion and gasification. Pulverized coal power stations use combustion technologies and are discussed in the following section. An example of gasification technology is an Integrated Gasification Combined Cycle, described in Section 2.2.3.2 below.

2.2.3.1 Pulverized Coal Power Stations

Pulverized coal power stations use coal combustion technologies. Pulverized coal is fed to a steam boiler and steam turbine. A simple schematic of pulverized coal combustion is presented in Figure 7. Coal is first ground to a very fine powder for combustion. The pulverized coal is then combusted in a series of burners, generating hot gases that are used to produce steam in a boiler. The steam is used to turn a turbine which drives a generator and produces electricity. During the process of coal burning, ash is formed in the combustion chamber. The bottom ash consisting of large particles can be collected and

removed. The rest of the coal ash remains in the combustion chamber and is known as fly ash. Some fly ash can be captured using various air pollution control technologies.




Figure 7 – Schematic diagram of a typical pulverized coal power stations (Naini et al., 2005).

2.2.3.2 Integrated Gasification Combined Cycle (IGCC)

Integrated Gasification Combined Cycle (IGCC) uses coal gasification technologies. In coal gasification, coal is gasified by partial combustion to produce synthetic gas. This process uses a gasification agent consisting of air, oxygen and steam.

IGCC combines gas and steam turbines for electricity production. A schematic of an IGCC power plant is presented in Figure 8. Coal slurry is reacted with oxygen (or air) and steam, and syngas is produced, consisting mainly of CO and hydrogen. The raw syngas is cooled and cleaned to remove particulates and sulphur impurities. The clean syngas is burned in a combustion turbine which drives a generator to produce electricity. The hot exhaust gases are recovered and used to produce steam. The resulting steam is used to drive a steam turbine, which turns a generator and produces additional electricity.




Figure 8 – Schematic diagram of typical Integrated Gasification Combined Cycle power station (Naini et al., 2005).

2.2.4 Hydroelectric Power Stations

Hydroelectric power stations generate electricity using the force of water that falls into turbines and rotates the shaft of the turbines. By rotating the shaft of turbines, the potential energy of the water is converted into kinetic energy. The shaft from the turbine is connected to a generator. The kinetic energy from the shaft turns the electrical generator and produces electricity.

Water for use in hydroelectric power stations can be obtained by building a dam on a large river. Water is stored behind the dam in large reservoirs and can be released onto turbine propellers through a dam water intake. After passing through the turbine, the water is released back into the river.

2.2.5 Wind Power Plants

Wind power plants generate electricity by using wind to turn wind turbines. In principle, wind's potential energy is converted to kinetic energy that rotates the blades of turbines, which in turn transfer this energy to an electrical generator. The electrical generators produce electricity.

2.2.6 Ontario-Manitoba Interconnection Project

The Ontario-Manitoba Interconnection (OMI) project aims to provide a long-term hydroelectric supply of electricity to Ontario via a cross-province transmission infrastructure. The total capacity of the OMI project is estimated to be from 1,500 MW to 3,000 MW (Ontario Power Authority, 2005). The electricity supply would come from a new hydroelectric power plant constructed at the Conawapa site on the Nelson River in Manitoba. If approved, the supply of electricity may be available to Ontario as early as 2012.

2.2.7 Comparison of Supply Technologies

In this section, the various supply technologies are compared in terms of operating characteristics, cost, and environmental impacts.

Nuclear power plants do not emit any GHGs or ozone precursors during normal operation. However, there are radioactive emissions from nuclear power plant's operation. These emissions have been found to be less than the radioactive emissions from coal-fired power plants (Naini et al., 2005). Capital costs and construction periods of nuclear power plants are generally higher than for coal or gas power stations. However, the fuel costs are considerably lower (Ontario Power Authority, 2005).

Natural gas power stations costs depend on the size of the power plant and the selected turbine technology. Simple cycle gas turbines have lower capital costs than combined cycle and cogenerators, but generally have lower efficiency. One advantage of simple cycle gas turbines is that they have fast start-up times and can hence provide electricity for peak-load demand. However, since they do not have long operating times, simple cycle gas turbines are not efficient for base-load service. NGCC's have higher capital costs than simple cycle gas turbines, but lower operating costs. Also, NGCC is generally more efficient than simple cycle gas turbines. NGCC's can be used for base-load or peak-load. Cogeneration has higher capital costs than NGCC's and simple cycle gas turbines, but higher efficiency (Ontario Power Authority, 2005).

Coal power stations generally have lower fuel costs than other fossil fuels. IGCC power plants generally have higher capital costs than other competing technologies. Also, IGCC power plants have higher operating costs than pulverized coal power stations. Coal power plants emit pollutants, such as CO₂, NO_x, SO₂ and particulates. In addition, combustion of coal results in the release of mercury, benzene

and formaldehydes. Radioactive elements such as radon and uranium are also released from coal power stations. Whereas pulverized coal power stations produce fly ash, none is generated by IGCC plants.

Use of hydroelectric power stations for electricity production is usually cheaper than use of other technologies because there are no fuel costs associated with hydroelectric plants. Also, the efficiency rate of electricity produced from hydro sources is about double compared to fossil fuel plants (Naini et al., 2005). However, hydroelectric plants depend on water availability which makes electricity production vulnerable to seasonal droughts and changes in weather.

Hydroelectric power stations do not generate any GHGs or other atmospheric emissions. However, there are some negative environmental implications associated with hydroelectricity production. Notably, hydroelectricity generation has adverse impacts on agriculture and river ecological system since dams can lower water tables, alter water temperatures and damage water wildlife.

Similarly to hydroelectric power stations, wind power plants have no fuel costs associated with their operation since they use wind energy to produce electricity. However, wind power plants heavily depend on wind conditions. Moreover, wind is intermittent by nature and the electricity generated by wind turbines will vary depending on wind strength (Ontario Power Authority, 2005).

2.3 Carbon Capture and Storage

Carbon capture and storage (CCS) has received widespread interest as a potential method for controlling and reducing CO₂ emissions from fossil fuel power plants (Roa & Rubin, 2002). The basic design of a CCS system includes four fundamental processes. The first process involves the separation and concentration of the CO₂ present in the gas stream of fossil fuel power plants. Once the CO₂ is separated and concentrated to a nearly pure form, it is compressed beyond its critical value in order to convert the concentrated CO₂ gas into a liquid phase and allow for liquid phase transportation. The third stage of the process involves the transport of the concentrated liquid CO₂ stream via a network of pipelines to a storage location. Finally, the last stage of the process is the sequestration of the CO₂ into a medium such as a deep saline aquifer or a depleted oil and gas reservoir for long term storage (Benson & Surles, 2006). A schematic of a hypothetical CCS system is illustrated in Figure 9.




Figure 9 - Schematic diagram of a hypothetical carbon capture and storage system that uses a deep saline aquifer for long term storage of carbon dioxide.

A CCS system can be implemented on any new or existing power plant in order to reduce and control CO₂ emissions. The cost associated with retrofitting an existing power plant with a CCS system generally tends to be higher than of a new power plant with a CCS system already in place. This cost difference is largely due to the higher energy penalty that is incurred by less efficient heat integration as well as potential site specific difficulties that are inherent in most retrofit projects (Rao & Rubin, 2002). Although the cost of retrofitting an existing power plant with a CCS system may be higher, this may potentially be outweighed by the benefit of maintaining the operation of the power plant, while meeting CO₂ emission targets, without having to build a new plant.

2.3.1 Carbon Capture Technologies

There exist a wide range of technologies that are currently available in order to separate and capture CO₂ present in a gas streams. The carbon capture technologies available can be grouped in three general categories: post-combustion capture, pre-combustion capture and oxy-fuel combustion.

A post-combustion carbon capture process involves the removal of CO₂ from the flue gas of power plants. The most common method for post-combustion carbon capture is a chemical absorption process

that uses monoethanolamine (MEA) as a solvent. The process consists of running the flue gases through a low pressure gas/liquid absorber where the CO₂ is removed from the flue gas by partitioning with the amine solvent. The amine is then heated to a specific temperature in order to release the pure CO₂ and regenerate the solvent.

Pre-combustion capture processes involve the removal of most of the carbon content in a fossil fuel before it is combusted. The process involves the pre-combustion reaction of the fossil fuel with steam and air, producing a syngas that is comprised of primarily CO and H₂. The CO is then reacted with water to produce a mixture of CO₂ and additional H₂, which can then be separated and utilized for energy production and the CO₂ stored respectively (Benson & Surles, 2006).

2.3.2 Carbon Dioxide Sequestration in Ontario

Carbon dioxide sequestration refers to long term and safe storage of carbon dioxide in a medium such as a deep saline aquifer or a depleted oil and gas reservoir. The process of carbon dioxide sequestration is normally performed after the carbon dioxide has been separated and captured from the gas stream of a power plant by a suitable process.

In Ontario, two large reservoirs for CO₂ sequestration have been identified, one located in the southern part of Lake Huron and the other located within Lake Erie. The approximate storage capacity for these two reservoirs has been estimated to be 289 and 442 million tonnes of CO₂, respectively (Shafeen, Croiset, Douglas, & Chatzis, 2004a). In order to achieve the estimated storage capacity of the reservoir, the injected CO₂ must maintain a temperature and pressure condition beyond its critical value. This supercritical state of CO₂ increases the density of the CO₂ and allows large quantities of CO₂ to be stored in a relatively small volume. The supercritical state of CO₂ can only be maintained if it is stored at a minimum reservoir depth of 800 m (Shafeen, Croiset, Douglas, & Chatzis, 2004b). Figure 10 illustrates the geographical location of the two potential reservoirs for CO₂ sequestration in Ontario.



Figure 10 – Geographical location of two potential reservoirs that may be utilized for CO₂ storage. The two reservoirs identified are Lake Huron and Lake Erie.

2.4 Ontario's Current Energy Mix

Ontario's current energy mix is composed of a variety of supply sources. The main technologies supplying electricity to Ontario are nuclear, hydroelectric, coal, natural gas and oil. The current installed capacity from all the supply sources totals approximately 30,662 MW (Ontario Power Authority, 2005). Table 1 presents the installed capacity of each supply technology in Ontario's energy mix.

Table 1 – Ontario's current installed capacity based on supply sources (Ontario Power Authority, 2005).

Technology	Existing Capacity (MW)
Nuclear	11,397
Hydroelectric	7,756
Coal	6,434
Gas/Oil	4,976
Other	99
Total	30,622

2.4.1 Nuclear

Nuclear power plays a very important role in Ontario's energy supply mix. Currently, nuclear power accounts for approximately 37% of Ontario's installed capacity and provides over 50% of Ontario's electrical energy needs.

There are currently three CANDU nuclear power plants in Ontario: Pickering generating station, Darlington generating station and Bruce Power. Table 2 outlines the nuclear units available in Ontario and the expected operational lifespan of each unit. The end-of-service dates presented in Table 2 are uncertain estimates which may change based upon various factors such as refurbishment strategies and maintenance practices over the next few years.

Table 2 – Operational and out-of-service nuclear units in Ontario. The data presented in this table includes the gross capacity, first commercial operation and the estimated end-of-service date for each nuclear unit in Ontario.

	Unit	Status	Gross Capacity (MW)	First Commercial Operation	End of Service Dates
Pickering Nuclear Plant					
Pickering A	Unit 1	Operational – was returned to service in 2005	515	07/1971	n/a
	Unit 2	Out of Service	515	12/1971	n/a
	Unit 3	Out of Service	515	06/1972	n/a
	Unit 4	Operational – was returned to service in 2003	515	06/1973	2016
Pickering B	Unit 5	Operational	516	05/1983	2008
	Unit 6	Operational	516	02/1984	2009
	Unit 7	Operational	516	01/1985	2010
	Unit 8	Operational	516	01/1986	2011
Bruce Nuclear Plant					
Bruce A	Unit 1	Refurbished: Expected start date 2009	750	09/1977	n/a
	Unit 2	Refurbished: Expected start date 2010	750	01/1977	n/a
	Unit 3	Operational	750	01/1978	2012
	Unit 4	Operational	750	01/1979	2016
Bruce B	Unit 5	Operational	785	03/1985	2010
	Unit 6	Operational	820	09/1984	2009
	Unit 7	Operational	785	04/1986	2011
	Unit 8	Operational	785	05/1987	2012
Darlington Nuclear Plant					
Darlington	Unit 1	Operational	881	11/1992	2017
	Unit 2	Operational	881	10/1990	2015
	Unit 3	Operational	881	02/1993	2018
	Unit 4	Operational	881	02/1993	2018

As shown in Table 2, most of the nuclear units were built in the 1970s and 80s and are reaching the end of their expected service life. Consequently most nuclear units will need to be retired or refurbished before 2018 (Winfield, Horne, McClenaghan, & Peters, 2004).

Refurbishment of the existing nuclear units in Ontario would involve a wide range of work and require a great deal of economic investment. The most significant part of the refurbishment process, and incidentally the most expensive, is the replacement of the fuel channels of the reactors, a process referred to as Large Scale Fuel Channel Replacement (LSFCR). The LSFCR refurbishment process involves the restoration of the nuclear reactor core and requires the shut-down of the nuclear unit for a period of at least two years (Winfield et al., 2004).

2.4.2 Coal

Ontario's coal-fired power plants are a significant part of the current supply mix. Coal power plants account for approximately 21% of Ontario's installed capacity and provide for 19% of Ontario's electricity generation requirements.

Ontario currently operates four coal-fired power plants and one dual fuelled oil and natural gas power plant. The coal power plants are Lambton, Nanticoke, Atitokan, and Thunder Bay. The oil and natural gas power plant is the Lennox generating station. Table 3 presents the existing coal-fired power plants in Ontario.

Table 3 – Existing coal-fired power plants in Ontario.

	Fuel	No. of Units	Capacity (MW)	% of fossil fuel capacity	Dates in service
Nanticoke	Coal	8	3938	46	1973/1978
Lambton	Coal	4	1975	23	1969/1970
Thunder Bay	Coal	2	310	4	1981/1982
Atitokan	Coal	1	215	3	1985
Lennox	Oil/Gas	4	2140	25	1976/1977

2.4.3 Hydroelectric

In Ontario, hydroelectric power accounts for approximately 26% of the installed capacity available to the province, and provides for 23% of the electricity generation. There are currently 108 hydroelectric stations within Ontario, but only 58 stations are directly connected to the electricity grid (Ontario Ministry of Energy, 2005). The largest hydroelectric stations in Ontario are the Niagara Plant Group which operate on the Niagara River and at DeCew Falls in St.Catharines. These stations have a combined capacity of 2,278 MW (Ontario Power Generation, 2006).

2.4.4 Natural Gas

Currently, Natural Gas accounts for approximately 7% of the supply mix in Ontario. There are presently 60 Natural Gas power plants of various capacities in Ontario, but only 19 of these stations are connected to Ontario's electricity grid. The total installed capacity of all the natural gas-fired generating stations is approximately 2,100 MW (Ontario Ministry of Energy, 2007).

2.5 Future Outlook

2.5.1 Electricity Demand Forecast

A load duration curve is often used to help plan for electrical utilities. A typical curve is presented in Figure 11 (Murphy, Sen, & Soyster, 1982).




Figure 11 – Typical load-duration curve.

From Figure 11, h is the number of hours in a year during which the demand is greater than or equal to a given load L (MW). The area under the curve represents the amount of energy, given in megawatt-hours, for a given period of time.

For large-scale applications, such as large nuclear units and gas turbines, the load duration curve can be simplified using linear approximation. A typical two-step linear approximation is given in Figure 12.




Figure 12 – Linear approximation of load-duration curve.

From Figure 12, a specific generating unit is assumed to operate in base-mode and/or peak-mode. This two-step linear approximation is used in this dissertation in order to simplify the problem.

Various electricity demand forecasts for Ontario have been published. In 2005, Independent Electricity System Operator (IESO) forecasted the energy and peak-load demand for Ontario for the ten-year period from 2006-2015. The results show that the energy demand is predicted to grow by 0.9% annually over the forecast period. Total energy demand is expected to increase from 157 TWh to 170 TWh by 2015. IESO predicts an increase in the normal weather peak from 24,200 MW in 2006 to 25,700 MW in 2015, while the normal weather summer peak is expected to increase from 24,000 MW to 26,900 MW over the same time period. Furthermore, the forecast shows an average annual increase of 0.7% for the winter peak and an average annual growth rate of 1.3% for the summer peak (IESO, 2006).

Navigant Consulting Ltd. used IESO 2005 forecast to extrapolate electricity demand to 2025. In this forecast, annual hourly data was extracted from IESO’s forecast for the period of 2006-2015. For the remaining analysis period of 2016-2025, the 2015 typical week profile was extrapolated and fit to the annual energy and peak demand forecast (Navigant Consulting, 2005). The Ontario peak demand and energy consumption forecasts from Navigant Consulting Ltd. are shown in Table 4 below.

Table 4 – Forecasted peak demand (MW) and energy demand (TWh) from Navigant Consulting Ltd.

	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015
Annual Energy (TWh)	156.8	158.3	160.3	161.2	162.6	164.2	166.0	167.0	168.4	169.7
Peak Demand (MW)	24,205	24,374	24,627	25,045	25,228	25,534	25,840	26,461	26,461	26,874

	2016	2017	2018	2019	2020	2021	2022	2023	2024	2025
Annual Energy (TWh)	171.2	172.7	174.3	175.8	177.4	178.9	180.5	182.1	183.7	185.3
Peak Demand (MW)	27,211	27,552	27,898	28,248	28,602	28,961	29,692	29,692	30,064	30,441

Chui, Elkamel, Croiset, and Douglas (2006) used a stochastic model to forecast Ontario’s electricity demand from 2006 to 2020. In this model, employment forecasts from the Ontario Ministry of Finance and various weather scenarios were used to predict electricity demand. This forecast contains a lower, median, and upper bound. The lower bound uses a low employment growth rate and mild weather conditions, while the median bound uses median employment growth rate and median weather scenarios. Finally, the upper bound uses high employment growth rate and extreme weather scenarios. The forecasted annual energy demand, annual peak-load demand, and annual base-load demand from Chui et al. (2006) are shown in Figure 13, 14, and 15 respectively.




Figure 13 – Ontario’s forecasted Annual Energy demand (GWh) for low, median and upper bound (Chui et al.,2006).




Figure 14 – Ontario’s forecasted annual peak-load demand (MW) for low, median, and upper bound (Chui et al.,2006).




Figure 15 – Ontario’s forecasted annual base-load demand (MW) for low, median, and upper bound (Chui et al.,2006).

As can be seen from Figure 13, Ontario’s annual energy demand grows by a range of 0.7% to 0.97% from year 2006 to 2020. Figure 14 shows an annual increase in peak-load demand in the range of 1.21% to 1.82% for the same time period. Finally, from Figure 15 it can be seen that the annual base-load demand grows in the range of 0.71% to 0.99%.

This thesis paper uses the electricity forecast estimated by Chui et al. (2006) for the case studies discussed in Chapter 4. The data for annual energy demand, annual peak-load demand, and annual base-load demand used in the model is presented in Appendix A.

2.5.2 Fuel Price Forecast

Future fuel prices in North America will be affected by numerous factors, such as demand growth, productive capacity, and the type of supply sources. For instance, the prices may vary depending on the availability of conventional and non-conventional supply sources and the industry’s cost and ability to bring them to market.

2.5.2.1 Natural Gas Price Forecast

There are numerous natural gas price forecasts reported in literature. Sproule forecasted natural gas prices based on Henry Hub daily closing prices. Based on this forecast, an upward trend was observed from 1997 to 2007, and prices were expected to fall in 2008 as the new set of Liquefied Natural Gas (LNG) terminals come on-line (Naini et al., 2005). The Energy Information Administration's (EIA) Annual Energy Outlook (AEO) was released in 2005 and forecasts for the Lower 48 US Supplier's average wellhead price. Unlike the Sproule forecast, the EIA's AEO2005 forecast does not include the transportation costs of delivering natural gas to costumers and is hence based on lower prices than Henry Hub. The AEO2005 forecasts natural gas prices rising until 2008, and falling after the new LNG terminals come on-stream (Naini et al., 2005).

This paper uses the National Energy Board's (NEB) natural gas price forecasts. The NEB forecasts natural gas prices delivered to industrial consumers in Ontario. It is based on two scenarios: a Supply-Push (SP) case and a Techno-Vert (TV) case. The SP scenario is based on an assumption that technology advances gradually and that there is limited action on the environment in Canada. One of the major premises of the SP case is the security and development of conventional North American gas sources using proven technologies.

The TV scenario is based on the assumption that technology advances occur more rapidly and that Canadians take broad action on the environment. The heightened concern for the environment is assumed to result in an increasing demand for cleaner fuels and advances in technology. The outcome is rapid technological advances resulting in development of non-conventional gas sources (Naini et al., 2005).

The NEB's forecast is presented in Figure 16. Numerical data for the annual NG forecast is presented in Table 29 of Appendix B.




Figure 16 - Natural gas forecast from NEB showing both Supply-Plus and Techno-Vert scenarios. Numerical data for the annual natural gas forecast is presented in Table 29 of Appendix B. Costs are expressed in terms of 1986 Canadian dollars.

From Figure 16, the natural gas prices are forecasted to decrease after 2010 for both SP and TV scenarios. The TV scenario predicts a slight increase in prices between 2006 and 2010. Similarly to Sproule and AEO’s outlooks, the gas price decrease may be a result of the assumption that LNG terminals come-on stream after 2010.

2.5.2.2 Coal Price Forecast

Sproule and EIA’s AEO2005 forecasts predict coal prices, measured in terms of US export price of coal, to decline from 2007 to 2025. AEO2005 forecast indicates coal prices will not drop below 2003US\$ 35/short ton for the next two decades (Naini et al., 2005).

This paper uses coal price forecasts from the NEB. The NEB coal price forecast is shown in Figure 17. Numerical data for the annual NG forecast is presented in Table 30 of Appendix B.




Figure 17 – Coal price forecast from NEB. Numerical data for the annual coal forecast is presented in Table 30 of Appendix B. Costs are expressed in terms of 1986 Canadian dollars.

From Figure 17, NEB’s coal prices are measured as delivered prices to industrial consumers in 1986 Canadian dollars per GJ coal. NEB projects coal prices to decline by one percent until year 2015, after which time the coal prices are expected to remain constant. It is assumed that there are no significant resource constraints on coal production. Also, continuing efficiency improvements such as mergers in the transportation industry are assumed.

2.5.3 Energy Conservation Strategy

Historically, conservation has occurred naturally with advances in technology. For instance, home appliances have been replaced by more efficient ones and building materials have become more energy-conserving with technological advances. Such energy efficiency improvements are known as “technology improvements” and are typically reflected in demand forecasts.

Conservation and Demand Management (CDM) is the use of a wide range of activities in an effort to reduce consumer demand and use of electricity. CDM usually results in higher levels of conservation than technology improvements due to more direct intervention in the market through incentives, standards or other mechanisms. The activities undertaken to reduce the use of electricity can be classified into three distinct categories: conservation efforts that result in less than normal use of electricity; energy efficiency activities that result in less electricity utilized for the same level of service; and load management activities to reduce demand during peak times.

Though technology improvements are typically included in demand forecasts, it is often difficult to determine the extent of technology improvement present in such forecasts. For example, the IESO's 10-year Outlook is heavily influenced by past trends and behaviours, and it is thus difficult to quantify the contribution by technology improvements. Furthermore, energy savings due to CDM activities can be substantial but are even more difficult to quantify without detailed information on the programs, tools and standards.

In order to assess electricity conservation potential in Ontario, ICF Consulting has developed a methodology based on a combination of two approaches. The first approach is known as "experience-based", and is based on a review of the effects of energy-conservation programs in various U.S. jurisdictions as well as other efficiency potential analysis. The second approach, known as "accounting approach", is based on an assessment of potential efficiency improvement contributions by various sectors, sub-sectors and end users (Ontario Power Authority, 2005). ICF used a combination of these two complementary approaches to help utilize the strengths of each. Though each approach has its advantages, they also have some inherent weaknesses. For instance, the experience-based approach uses U.S. data that may not be applicable to Ontario.

Using the two approaches described above, ICF considered four scenarios reflecting increasing levels of aggressiveness in energy conservation efforts. Energy Efficiency (EE) 25 refers to information-based programs with financial incentives of 25% of incremental cost of new equipment installation. EE50 are common programs in which financial incentives equal 50% of incremental cost of new equipment installation. EE100 are programs that involve intensive technical assistance and have financial incentives of 100% of incremental cost. Finally, EE100 Plus Standards programs take into account a broad range of aggressive generic standards and also involve financial incentives of 100% of incremental cost (ICF Consulting, 2005). Efficiency improvements estimated by ICF are given in Table 5 and Table 6 below.

Both sets of data assume a hot summer day since efficiency improvement during such weather provide additional energy savings.

Table 5 – Estimated energy efficiency peak-demand savings (MW) by ICF. The estimates are divided into four scenarios which reflect the increasing levels of aggressiveness in energy conservation efforts (ICF Consulting, 2005).

Scenario	2010		2015		2020		2025	
	Est.1 (MW)	Est.2 (MW)	Est.1 (MW)	Est.2 (MW)	Est.1 (MW)	Est.2 (MW)	Est.1 (MW)	Est.2 (MW)
EE 25	440	200	600	950	780	1840	980	2280
EE50	1110	850	1530	3050	1680	4040	1490	4330
EE100	1790	1770	2040	4290	1820	4800	1570	4520
EE100 Plus	2440	4620	2360	5380	1960	5050	1710	4730

Table 6 - Estimated energy efficiency savings (TWh) by ICF. The estimates are divided into four scenarios which reflect the increasing levels of aggressiveness in energy conservation efforts (ICF Consulting, 2005).

Scenario	2010		2015		2020		2025	
	Est.1 (TWh)	Est.2 (TWh)	Est.1 (TWh)	Est.2 (TWh)	Est.1 (TWh)	Est.2 (TWh)	Est.1 (TWh)	Est.2 (TWh)
EE 25	3.2	1.1	4.5	5.7	5.3	12.7	5.3	17.2
EE50	8.2	5	10	20.4	8.9	27.2	6.9	27.7
EE100	12.2	10.9	11.9	28.3	9.3	30.4	7.1	28.2
EE100 Plus	15.1	27.2	12.5	32.1	9.6	30.8	7.3	28.5

2.6 Journal Review

From our literature review to date, we have found several authors that have used multi-period optimization methods for planning purposes. Iyer, Grossmann, Vasantharajan and Cullick (1998) have developed a multi-period mix-integer linear programming (MILP) model for the planning and scheduling of offshore oil field facilities. This mathematical model employs a general objective function that optimizes a selected economic indicator. Maravelias and Grossmann (2001) proposed a complex multi-period optimization model to address the challenge of planning for the production of a new product in highly regulated industries, such as pharmaceuticals and agrochemicals. The model uses a multi-period MILP model that maximizes the expected net present value of a multi-period project. The model, although comprehensive, does not account for the lead time required for construction of new plants. Mo, Hegge and Wangensteen (1991) developed a stochastic dynamic model for handling the uncertainties in generation expansion problems. The model makes it possible to identify the connection between investment decisions, time, construction periods, and uncertainty.

Hashim, Douglas, Elkamel and Croiset (2005) developed a single-period deterministic MINLP optimization model aimed to predict a fleet-wide system configuration which simultaneously satisfies electricity demand and CO₂ emission constraints at minimum cost. The mathematical model developed was linearized using exact linearization techniques in order to overcome the inherited problems with solving non-linear models. Although the model developed by Hashim et al. (2005) is very comprehensive and complex, its single period mathematical structure does not allow the incorporation of multi-period factors such as construction lead time and fuel price fluctuations over time. In order to improve the optimization model and make it more realistic, the model developed by Hashim et al. (2005) must be extended to a multi-period domain.

From the journal review conducted, no publication was found addressing the problem of finding the optimal strategy for energy planning with CO₂ emission constraints and the option to implement carbon capture and storage. This thesis involves the development of a novel deterministic multi-period MINLP optimization model in order to realize the optimal mix of energy supply sources, while meeting CO₂ emissions targets.

Chapter 3

3.1 Model Formulation

The formulation developed is a multi-period Mixed Integer Linear Programming (MILP) model that is able to realize the optimal mix of energy supply sources which will meet current and future electricity demand, CO₂ emission targets, and minimize the overall cost of electricity. The model presented is initially a Mixed Integer Non-Linear Programming (MINLP) model that is then linearized using exact linearization methods. The linearization of the non-linear model is done with the aim of avoiding inherited computational difficulties encountered with large convex non-linear models. This linearization is able to lower the computation expense while retaining the consistency of the solution.

The developed model was programmed and implemented in the GAMS (General Algebraic Modeling System) optimization package and solved using the CPLEX 10 solver. The GAMS code is included in Appendix C.

The indices, sets, variables, and parameters used in the planning model are the following:

Indices		T	Time horizon (years)
t	Time period (years)	$(CO_2)_{ij}$	CO ₂ emission from boiler i using fuel j (tonne of CO ₂ /MWh)
i	Boiler	E_k^{max}	Maximum supplemental energy required for k th capture technology
j	Fuel type (coal or natural gas)	ε_{ikt}	Percent of CO ₂ captured from boiler i using carbon capture technology k during period t (%)
l	Load block (peak or base-load)	β_i	Construction lead time for power station i (years)
k	Carbon capture technology	Q_i	Cost of carbon capture and storage for boiler i (\$/tonne of CO ₂)
Sets		D_{tl}	Electricity demand during period t for load l (MWh)
F	Fossil fueled power plants	B_{tl}	Conservation and demand management during period t and load block l (MWh)
NF	Non-fossil fueled	ρ	Factor for transmission and distribution losses
new	New power plants	$CLimit_t$	Specified CO ₂ limit during period t
$new - cap$	New power plants with carbon capture		
Parameters		Binary variables	
F_{ijt}	Fixed operating cost of boiler i using fuel j during period t (\$/MW)	n_{it}	=1 if power plant i is built during period t = 0 otherwise
V_{ijt}	Variable operating cost of boiler i using fuel j during period t (\$/MWh)	y_{it}	=1 if power plant i is operational during period t = 0 otherwise
C_{ij}	Capacity of boiler i using fuel j (MW)	x_{ijt}	=1 if coal-fired boiler i is operational while using fuel j during period t =0 otherwise
P_{lt}	Duration of load block l during period t (hrs)	z_{ijkt}	=1 if the carbon capture technology k is used on boiler i, which uses fuel j, during period t.
U_{jt}	Fuel cost for fuel j during period t (\$/GJ)	h_{it}	=1 if coal-fired boiler i undergoes fuel-switching during period t =0 otherwise
G_{ij}	Heat rate of boiler i using fuel j (GJ/MWh)	Continuous variables	
R_{it}	Cost associated with fuel-switching coal-fired boiler i during period t	E_{ijlt}	Power allocation from boiler i using fuel j for load block l during period t (MW)
S_{it}	Capital cost of power plant i during period t	$(Cre)_t$	Carbon credits purchased during period t (tonne of CO ₂)
$(CCost)_t$	Cost of carbon credits during period t (\$/tonne of CO ₂)		

3.2 Objective Function

The objective function of the planning model is to minimize the total discounted present value of the costs associated with meeting electricity demand while satisfying a CO₂ reduction target over a specified planning horizon. The components associated with the objective function include: fixed and variable operating and maintenance cost, fuel cost, retrofit cost, capital cost for new power plants, carbon capture and storage cost, and cost of purchasing carbon credits.

The objective function for the deterministic multi-period MINLP model is as follows:

$$\begin{aligned}
 \min f(i, j, k, l, t) = & \underbrace{\sum_{i \in F} \sum_j \sum_t F_{ijt}^F C_{ij}^F x_{ijt}}_{\text{Fixed O\&M cost of existing powerplants}} + \underbrace{\sum_{i \in NF} \sum_t F_{it}^{NF} C_i^{NF} y_{it}^{NF}}_{\text{Variable O\&M cost of existing powerplants}} + \underbrace{\sum_{i \in F} \sum_j \sum_l \sum_t V_{ijt}^F E_{ijlt}^F P_{lt}}_{\text{Variable O\&M cost of existing powerplants}} + \underbrace{\sum_{i \in NF} \sum_l \sum_t V_{it}^{NF} E_{ilt}^{NF} P_{lt}}_{\text{Variable O\&M cost of existing powerplants}} + \\
 & \underbrace{\sum_{i \in F} \sum_j \sum_l \sum_t U_{jt} G_{ij}^F E_{ijlt}^F P_{lt}}_{\text{Fuel cost for fossil fuel plants}} + \underbrace{\sum_{i \in F} \sum_t R_{it} h_{it}}_{\text{retrofit cost for fuel switching}} + \underbrace{\sum_{i \in P^{new}} \sum_t S_{it}^{new} C_i^{new} n_{it}}_{\text{capital cost for new powerplant}} + \underbrace{\sum_{i \in P^{new}} \sum_t F_{it}^{new} C_i^{new} y_{it}^{new}}_{\text{Fixed O\&M cost of new powerplant}} + \\
 & \underbrace{\sum_{i \in P^{new}} \sum_l \sum_t V_{it}^{new} E_{ilt}^{new} P_{lt}}_{\text{Variable O\&M cost of new powerplant}} + \underbrace{\sum_{i \in P^{new}} \sum_l \sum_t U_{it} G_i^{new} E_{ilt}^{new} P_{lt}}_{\text{Fuel cost for new powerplant}} + \underbrace{\sum_t (Cre)_t (CCost)_t}_{\text{Cost of purchasing CO2 emission credits}} + \\
 & \underbrace{\sum_{i \in F} \sum_j \sum_k \sum_l \sum_t Q_i(CO2)_{ij} \varepsilon_{ikt} E_{ijt}^F z_{ijkt} P_{lt}}_{\text{Carbon capture and storage cost for existing powerplants}} + \underbrace{\sum_{i \in P^{new-cap}} \sum_l \sum_t Q_i(CO2)_i \varepsilon_{ikt} E_{ilt}^{new} P_{lt}}_{\text{Carbon capture and storage cost for new powerplants}}
 \end{aligned}$$

The construction of new power plants involves the use of postulated power plants that have a pre-assigned capacity and operational parameter. Energy production from these new hypothetical power plants can only occur if the optimizer has previously decided to build the new power plant. Several constraints, which are discussed in the next section, have been formulated in order to prevent the generation of electricity from new power plants that have not been constructed.

It is important to note that no binary variable is associated with the cost of CCS for new power plants. For new power stations, the option to have a carbon capture system in place is dependent on which power station is chosen. For every hypothetical new power station there is an equivalent power station, with a similar capacity and operational parameters, that has an integrated CCS system. The optimizer considers the two corresponding power plants and will decide whether to build the power plant with a CCS or the one without CCS.

The non-linear term in the objective function comes from the equation that considers the CCS for existing power plants. This non-linearity is due to the cross-product of the binary variable z_{ijkt} (decision whether to put the k^{th} carbon capture technology on the i^{th} boiler using the j^{th} fuel during time period t) and the continuous variable E_{ijtl}^F (power allocation from i^{th} fossil fuel boiler using the j^{th} fuel type during period t and l^{th} demand). Linearization of this term can be achieved by an exact linearization method.

In order to achieve linearity, the following equation must be reformulated.

$$\sum_{i \in F} \sum_j \sum_k \sum_l \sum_t Q_i(CO2)_{ij} \varepsilon_{ikt} E_{ijtl}^F z_{ijkt} P_{lt} \quad (1)$$

The reformulation of this equation involves the introduction of a new continuous variable and several auxiliary constraints. The newly defined continuous variable α_{ijtl} is introduced into the equation and will replace the nonlinear expression.

$$\alpha_{ijktl} = E_{ijtl}^F z_{ijkt} \quad \forall i, \forall j, \forall t, \forall k, \forall l \quad (2)$$

By substituting equation 2 into equation 1 the following equation is achieved,

$$\sum_{i \in F} \sum_j \sum_k \sum_l \sum_t Q_i(CO2)_{ij} \varepsilon_{ikt} \alpha_{ijktl} P_{lt} \quad (3)$$

In order to insure that this reformulation will yield the same results as its non-linear counterpart, additional constraints must be defined. The constraints proposed are as follows:

$$0 \leq \alpha_{ijtl} \leq C_{ij}^{Fmax} \quad \forall i, \forall j, \forall t, \forall l \quad (4)$$

$$E_{ijtl}^F - C_{ij}^{Fmax} (1 - z_{ijkt}) \leq \alpha_{ijtl} \leq C_{ij}^{Fmax} z_{ijkt} \quad \forall i, \forall j, \forall t, \forall k, \forall l \quad (5)$$

By introducing the new formulation for CCS cost presented in equation 3 into the objective function the MINLP is reduced to a MILP. The linearized objective function is given as:

$$\begin{aligned}
\min f(i, j, k, l, t) = & \underbrace{\sum_{i \in F} \sum_j \sum_t F_{ijt}^F C_{ij}^F x_{ijt}}_{\text{Fixed O\&M cost of existing powerplants}} + \underbrace{\sum_{i \in NF} \sum_t F_{it}^{NF} C_i^{NF} y_{it}^{NF}}_{\text{Variable O\&M cost of existing powerplants}} + \underbrace{\sum_{i \in F} \sum_j \sum_l \sum_t V_{ijt}^F E_{ijlt}^F P_{lt}}_{\text{Variable O\&M cost of existing powerplants}} + \underbrace{\sum_{i \in NF} \sum_l \sum_t V_{it}^{NF} E_{ilt}^{NF} P_{lt}}_{\text{Variable O\&M cost of existing powerplants}} + \\
& \underbrace{\sum_{i \in F} \sum_j \sum_l \sum_t U_{jt} G_{ij}^F E_{ijlt}^F P_{lt}}_{\text{Fuel cost for fossil fuel plants}} + \underbrace{\sum_{i \in F} \sum_t R_{it} h_{it}}_{\text{retrofit cost for fuel switching}} + \underbrace{\sum_{i \in P^{new}} \sum_t S_{it}^{new} C_i^{new} n_{it}}_{\text{capital cost for new powerplant}} + \underbrace{\sum_{i \in P^{new}} \sum_t F_{it}^{new} C_i^{new} y_{it}^{new}}_{\text{Fixed O\&M cost of new powerplant}} + \\
& \underbrace{\sum_{i \in P^{new}} \sum_l \sum_t V_{it}^{new} E_{ilt}^{new} P_{lt}}_{\text{Variable O\&M cost of new powerplant}} + \underbrace{\sum_{i \in P^{new}} \sum_l \sum_t U_{it} G_i^{new} E_{ilt}^{new} P_{lt}}_{\text{Fuel cost for new powerplant}} + \underbrace{\sum_t (Cre)_t (CCost)_t}_{\text{Cost of purchasing CO2 emission credits}} + \\
& \underbrace{\sum_{i \in F} \sum_j \sum_k \sum_l \sum_t Q_i(CO2)_{ij} \varepsilon_{ikt} \alpha_{ijkl} P_{lt}}_{\text{Carbon capture and storage cost for existing powerplants}} + \underbrace{\sum_{i \in P^{new-cap}} \sum_l \sum_t Q_i(CO2)_i \varepsilon_{ikt} E_{ilt}^{new} P_{lt}}_{\text{Carbon capture and storage cost for new powerplants}}
\end{aligned}$$

3.3 Model Constraints

The objection function that is discussed in Section 3.2 is subject to the following constraints.

Annual electricity demand

The annual electricity generated from the entire fleet minus the supplemental energy required for potential carbon capture processes (E_{ikt}) must be greater or equal to the annual electricity demand.

$$\sum_{i \in F} \sum_j E_{ijtl}^F P_{lt} + \sum_{i \in NF} E_{itl}^{NF} P_{lt} + \sum_{i \in P^{new}} E_{itl}^{new} P_{lt} - \sum_{i \in F^c} \sum_k E_{ikt} \geq D_{tl} \quad \forall t, \forall l \quad (6)$$

Taking into account potential energy savings due to conservation and demand management (CDM) strategies, equation 6 becomes;

$$\sum_{i \in F} \sum_j E_{ijtl}^F P_{lt} + \sum_{i \in NF} E_{itl}^{NF} P_{lt} + \sum_{i \in P^{new}} E_{itl}^{new} P_{lt} - \sum_{i \in F^c} \sum_k E_{ikt} \geq D_{tl} - B_{tl} \quad \forall t, \forall l \quad (7)$$

where, B_{tl} is the forecasted annual energy savings (MWh) due to CDM strategies.

The energy constraint in equation 7 is enhanced further by considering the potential electricity losses incurred during the stages of transmission and distribution. Although the electricity losses in the transmission and distribution system are nonlinear with transmitted power (Scherer, 1978), an approximation could be achieved by factorizing the power received with the dispatched power. Taking into account transmission losses, equation 7 becomes;

$$(1 - \rho) \left(\sum_{i \in F} \sum_j E_{ijtl}^F P_{lt} + \sum_{i \in NF} E_{itl}^{NF} P_{lt} + \sum_{i \in P^{new}} E_{itl}^{new} P_{lt} - \sum_{i \in F^c} \sum_k E_{ikt} \right) \geq D_{tl} - B_{tl} \quad \forall t, \forall l \quad (8)$$

where ρ represents a factor for transmission and distribution losses.

Capacity constraint for existing power stations

In terms of the capacity allocation, the net power capacity (MW) of any power station cannot be exceeded. The maximum capacity constraints for existing fossil fuel and non-fossil fuel power plants are expressed in equations 9 and 10 respectively.

$$\sum_l E_{ijlt}^F \leq C_{ij}^{Fmax} x_{ijt} \quad \forall i \in F, \forall t, \forall j \quad (9)$$

$$\sum_l E_{ilt}^{NF} \leq C_i^{NFmax} y_{it}^{NF} \quad \forall i \in NF, \forall t \quad (10)$$

Construction lead time and capacity constraint for new power stations

The multi-period nature of the planning model requires the consideration of construction lead time for new power stations, which differs depending on the type of generating technology considered. For new power stations, no power can be supplied to the grid unless the construction of the new power plant has been completed. To achieve this, equation 11 has been formulated to insure that during the construction phase of a new power plant, no electricity generating capacity is available. Furthermore, the constraint in equation 11 also functions as a capacity constraint in which the net power capacity limit of a new power plant cannot be exceeded.

$$E_{it'}^{new} \leq C_i^{max} (1 - n_{it}) \quad \forall i \in P^{new}, \forall t, \forall t' = 1, \dots, [t + (\beta_i - 1)] \quad (11)$$

The binary variable n_{it} determines whether power plant i should start construction during year t . Since the start of a construction project occurs only once for a given power plant i , the value of n_{it} must be less or equal 1 for the sum of all time period t (equation 12). The parameter β_i represents the construction lead time for power station i .

$$\sum_t n_{it} \leq 1 \quad \forall i \in P^{new} \quad (12)$$

A relationship between the binary variables n_{it} and y_{it}^{new} can be attained by formulating equation 13. This equation ensures that if construction of a new power plant i occurs during year t , the plant is operational for all time periods $t + \beta_i$.

$$(T - t) - \sum_{t=(t+\beta_i)}^T y_{it}^{new} + n_{it} \leq \beta_i \quad \forall i \in P^{new}, \quad \forall t = 1, \dots, (T - \beta_i) \quad (13)$$

An alternative method for the formulation of construction lead time and capacity constraint of new power stations: The Matrix Method

An alternative approach that can be utilized in order to incorporate construction lead time into the model involves the use of a three indices matrix which restricts the maximum power output of a given power station. Each row in the matrix corresponds to a specific year of construction and each column refers to a “regular” year. The non-zero values in the matrix specify the maximum capacity of the power station. A sample matrix for a hypothetical power plant P_1 is illustrated in Figure 18.

$$\begin{array}{c} P_1 \ t_1 \\ P_1 \ t_2 \\ P_1 \ t_3 \\ P_1 \ t_4 \\ P_1 \ t_5 \end{array} \begin{bmatrix} t_1 & t_2 & t_3 & t_4 & t_5 \\ 0 & 0 & 20 & 20 & 20 \\ 0 & 0 & 0 & 20 & 20 \\ 0 & 0 & 0 & 0 & 20 \\ 0 & 0 & 0 & 0 & 0 \\ 0 & 0 & 0 & 0 & 0 \end{bmatrix}$$

Figure 18 - Sample matrix used in the construction lead time constraint. Each row in the matrix corresponds to a year during which construction would have commenced. The non-zero values in the matrix specify the maximum capacity of power plant P_1 .

The above matrix can be used in conjunction with the binary variable y_{it_c} , which specifies the year in which construction should commence, in order to constrain the model from generating power from a power plant that has not yet been constructed. Equations 14 and 15 may be used as alternative to the mathematical constraints formulated in equation 11 and 12.

$$E_{it}^{new} \leq \sum_{t_c} y_{it_c} K_{it_c t} \quad \forall i \in P^{new}, \forall t \quad (14)$$

where $K_{it_c t}$ represents a three indices matrix.

$$\sum_{t_c} y_{it_c} \leq 1 \quad \forall i \in P^{new} \quad (15)$$

In order to illustrate the concept that is presented in equation 14 and 15, consider the following example;

A time horizon of 5 time periods is considered in which the construction of a new coal power plant, P_1 , should commence during time period 2. Furthermore, the time required to finish the construction of the new power plant is specified to be 2 time periods. Since the construction of P_1 starts in period 2 and it takes two periods to finish construction, power plant P_1 should not be able to supply power to the grid until time period 4. The sample problem is illustrated in Figure 19.




Figure 19 – Graphical representation of sample problem. Power plant P_1 starts construction during period 2 and construction is not completed until period 3.

Given that the construction of the new power plant has been determined to start during period 2, the value for binary variable y_{it_c} for power station $i=1$ during $t_c = 2$, is 1 (i.e. $y_{1,2} = 1$) and zero for all other time periods.

Based on equation 14 and the matrix in Figure 18, the energy capacity for power plant P_1 during time periods 1 through 5 will be;

$$E_{11}^{new} \leq 0$$

$$E_{12}^{new} \leq 0$$

$$E_{13}^{new} \leq 0$$

$$E_{14}^{new} \leq 20$$

$$E_{15}^{new} \leq 20$$

There are several advantages in using equation 14 and 15, rather than the equations presented in 11 and 12. The first advantage stems from the fact that fewer binary variables need to be defined and calculated in the method presented by 14 and 15. Secondly, the formulation in 11 and 12 generate a large number of equations which significantly impacts the computational time. Lastly, the methodology presented in equation 14 and 15 is easier to program into the GAMS optimization package.

Capacity constraint on capture process

The operation of any capture process requires the use of energy, either from the plant itself or from the grid. Equation 16 is formulated in order to ensure that the energy required for the k^{th} carbon capture process is zero when no capture process is assigned to the i^{th} coal-fired boiler. The parameter E_k^{max} represents the maximum supplementary energy required for the k^{th} carbon capture process.

$$E_{ikt} \leq z_{ikt} E_k^{\text{max}} \quad \forall i \in F^c, \forall k, \forall t \quad (16)$$

Fuel-selection and power plant shutdown

Given that the model considers the option of fuel-switching existing coal-fired boilers with a less carbon intensive fuel, such as natural gas, a constraint must be formulated in order to restrict the use of two different fuel types on the same boiler. To achieve this goal, equation 17 has been formulated. The binary variable x_{ijt} represents the fuel section (coal or natural gas) for the i^{th} fossil fuel boiler during time period t and could have a value of zero if the i^{th} boiler is shut-down.

$$\sum_j x_{ijt} \leq 1 \quad \forall i \in F, \forall t \quad (17)$$

The binary variables x_{ijt} and h_{it} (decision whether to fuel-switch coal power plant i during time t) can be related by formulating the mathematical relation presented in equation 18.

$$(T - t + 1) - \sum_{t=t}^T x_{ijt} + h_{it} \geq 1 \quad \forall t, \forall i \in F, \forall j \in \text{eng} \quad (18)$$

Since fuel-switching of a coal power boiler i can occur only once during the time horizon T , the constraint in equation 19 must be included.

$$\sum_t h_{it} \leq 1 \quad \forall i \in F \quad (19)$$

Selection of CO₂ capture process

In terms of CO₂ capture process selection for a given boiler, a capture process can only be retrofitted if the boiler is operational. Equation 20 insures that if an existing coal-fired boiler is shutdown, no CO₂ capture process can be put online.

$$\sum_k z_{ikt} \leq \sum_j x_{ijt} \quad \forall i \in F^c, \forall t \quad (20)$$

Furthermore, only one type carbon capture technology can be used for a given boiler *i* during a time period *t*. The constraint formulated in equation 21 can be used to prevent the use of two carbon capture technologies on the same boiler.

$$\sum_k z_{ikt} \leq 1 \quad \forall i \in F^c, \forall t \quad (21)$$

Carbon dioxide emission constraint

The annual CO₂ emissions produced as a result of electricity generation are limited by the constraint formulated in equation 22. This constraint specifies that the annual CO₂ emissions emitted by all existing and newly constructed boilers must be less than or equal to the specified annual CO₂ target. It is assumed that the only power plants that generate CO₂ emissions are those which use fossil fuel. Power stations that utilize non-fossil fuel, such as nuclear power plants, are assumed to have no CO₂ emissions and therefore are not included in equation 22.

The CO₂ constraint presented in equation 22 also considers the potential of CO₂ reduction by means of carbon credits. The CO₂ emitted by the entire fleet for a particular year may be reduced by the purchase of CO₂ credits for that year.

$$\sum_{i \in F^c} \sum_l \left[\left(\sum_j CO2_{ij}^F E_{ijt}^F P_{lt} \right) \left(1 - \sum_k \varepsilon_{ikt} z_{ikt} \right) \right] + \sum_{i \in P^{new}} \sum_l CO2_i^{new} E_{itl}^{new} P_{lt} - Cre_t \leq CLimit_t \quad \forall t \quad (22)$$

Although the constraint discussed above only pertains to CO₂ emissions, similar constraints can be formulated for other emissions, such as SO₂ and NO_x, by substituting the corresponding emission coefficients and specified annual limits. Incorporating these constraints would allow the model to consider multiple pollutants and allow the emissions of these pollutants to be controlled. The drawback of including additional emission constraints within the model is that it increases the size of the model significantly and from a computational point of view would make the model difficult to solve. Therefore, the model presented in this thesis will only constrain the annual CO₂ emissions and will not limit the emissions of any other pollutants.

3.4 GAMS Model Statistics and Logic

The model described in Sections 3.1-3.3 was programmed and implemented in the GAMS optimization package. The model was solved using the ILOG CPLEX 10.1 solver, which uses a branch and cut algorithm in order to solve complex problems. The CPLEX solver was chosen based on its advance optimization algorithm structure which allows it to solve large and complex MILP problems, such as the one presented in this thesis, with relatively high performance.

The programmed GAMS model was executed on an AMD Athlon 2.59 GHz, 2 GB RAM computer. Once executed, GAMS was able to find an optimal solution after a runtime of approximately 9 hours. The GAMS model statistics is presented in Table 7.

Table 7 – GAMS model statistics outlining block of equations, blocks of variables, non-zero elements, number of single equations, number of single variables and discrete variables.

BLOCKS OF EQUATIONS	63	SINGLE EQUATIONS	14,903
BLOCKS OF VARIABLES	37	SINGLE VARIABLES	11,476
NON ZERO ELEMENTS	82,119	DISCRETE VARIABLES	2,595

The only GAMS/CPLEX option used to solve the problem was the “Probe = Full” function available in CPLEX 10.1. This function allows an initial deep probe of the problem before any iteration is performed in order to determine the best strategy to solve the problem. Although this function may initially be very time consuming, it can sometimes significantly reduce the overall computational time of the problem.

Several other GAMS/CPLEX options were initially considered, but no significant performance or computational time improvements were noticed. The most effective strategy found to improve the overall performance and reduce the computational time of the problem was to reformulate the problem. Two formulations of the same model were found to yield dramatically different results in terms of performance and solving time.

In order to successfully run the model, several parameters, such as energy demand and power plant specifications, must be specified by the user. The parameters required by the model are retrieved via a GAMS add-on tool called xls2gams. This software tool enables GAMS to retrieve data from a specified Excel file and use the data as input parameters to the model. A detailed discussion of all the parameters needed to run the model is presented in Section 4.2.

Once all the parameters are retrieved by the xls2gams add-on tool, the model will attempt to solve the problem using the CPLEX 10.1 solver. The output of the model is exported to a Microsoft Excel file where it is automatically formatted into tables and figures. In addition to the Excel Output file, GAMS also generates an output file which contains raw data results and specific model statistics.

The logic for the model is shown in Figure 20.




Figure 20 – Logic for the optimization model.

Chapter 4

4.1 Description of Case Studies

The sections that follow outline two case studies that were implemented using the model developed in Chapter 3. The two case studies presented were selected in order to examine the economical and structural impact on Ontario's electricity sector when forced to comply with a given CO₂ emission limit. The emission limit specified is based on the Kyoto target of 6% below 1990 levels. Each case study is based on a 14 year time horizon, starting in 2006 and ending in 2020.

The two case studies examined are:

- **Case Study 1:** Presents a base case scenario in which no CO₂ emission limits are imposed on Ontario's electricity sector.
- **Case Study 2:** Presents a future scenario in which CO₂ emissions from the entire fleet must be 6% below 1990 levels after the year 2011. To achieve this, annual CO₂ emissions from the entire fleet must be less than 20 Mt per year after the year 2011.

In order to address future electricity demand several supply sources are considered in the case studies. The technologies that are considered include nuclear, natural gas, coal, hydroelectric, pulverized coal combustion (PC), integrated gasification combined cycle (IGCC), and natural gas combined cycle (NGCC) power plants. Although additional power plant technologies exist, the scope of the case studies discussed in this thesis only considers the above mentioned technologies as possible supply candidates.

As discussed in Chapter 3, the optimization model takes into account several distinctive characteristics of each supply technology, such as economic, environmental, and operational specifications, and determines the optimal mix of supply sources needed to satisfy each case study. The economic, environmental, and operational parameters for each supply technology are presented in Section 4.2.

The results of the case studies are presented in Sections 4.5 and 4.6. A comparative analysis of the two case studies is presented in Section 4.7.

4.2 Data for Case Studies

This section provides several of the required input data parameters necessary to implement the model developed in Chapter 3.

4.2.1 Existing Power Plants

Fossil-Fueled Power Plants

Ontario currently operates four coal-fired power plants with a combined capacity of approximately 6,285 MW. The four coal power plants currently in operation are Lambton, Nanticoke, Atitokan, and Thunder Bay. In addition to the four coal-fired power plants, there is a dual fueled oil and natural gas power plant referred to as the Lennox generating station.

The economic and operational parameters for existing coal and NG and oil power plants in Ontario are presented in Table 8. This table also presents the cost associated with fuel-switching an existing coal-power plant to natural gas. The variable and fixed operating and maintenance (O&M) cost for the coal power plants were obtained from Ontario Ministry of Energy (2005). All other parameters were attained from Hashim (2006).

Table 8 – Economic and operational parameters of existing coal-power plants and cost associated with fuel-switching to natural gas. All costs are expressed in terms of 2005 Canadian dollars.

Power Plant	Gross Capacity (MW)	Non-Fuel Variable O&M Cost (\$/MWh)		Fixed O&M Cost (\$/MW)		Capacity Factor (%)	Retrofit Cost (\$/MW)	Heat Rate (GJ/MWh)		CO2 Emissions (tCO2 / MWh)		Cost of CCS (\$/t CO2)	Elec. req. for CCS (MWh/t CO2)	
		coal	ng	coal	ng			coal	ng	coal	ng		coal	ng
Lambton	1948	2.45	0	36804	15970	0.75	23676.79	9.84	6.77	0.9278	0.5631	55.83579	0.317	0.356
Nanticoke	3820	2.25	0	32715	15970	0.75	23676.79	9.88	6.77	0.93	0.558	55.38001	0.317	0.356
Atitokan	211	5.11	0	74631	20994	0.75	23676.79	9.82	6.77	1.023	0.6138	212.7123	0.317	0.356
Lennox	2100	0	0	n/a	15970	0.75	n/a	7.82	6.77	0.651	0.651	n/a	0.356	0.356
Thunder Bay	306	5.11	0	74631	20994	0.75	23676.79	11.7	6.77	1.023	0.6138	216.2164	0.317	0.356

Natural Gas Power Plants

In Ontario, there are 60 natural gas power plants in operation, but only 20 of these power plants are connected to Ontario's electricity grid. The case studies discussed in this thesis will only take into account the natural gas power stations which are connected to the grid. The operational and economic parameters for the existing natural gas power plants are presented in Table 9. The data outlined in Table 9 was obtained from Ontario Power Authority (2005).

Table 9 – Operational and economic parameters for existing natural gas power plants. All costs are expressed in terms of 2005 Canadian dollars (Ontario Power Authority, 2005).

Technology	Non-Fuel Variable O&M Cost (\$/MWh)	Fixed O&M Cost (\$/MW)	Capacity Factor (%)	CO2 Emissions (tonne CO2 / MWh)
Single Cycle	3.42	5310	0.85	0.408
Combined Cycle	2.64	16020	0.85	0.290
Cogeneration	2.74	29880	0.85	0.290

Nuclear Power Plants

As mentioned in Section 2.4.1, most of the existing nuclear units in Ontario will reach the end of their service life by 2018. Consequently, Ontario's nuclear units will need to be decommissioned, refurbished, or replaced within the time horizon of the case studies presented in this thesis. The end-of-service dates for all 20 nuclear units in Ontario are presented in Table 2.

The refurbishment of a nuclear unit involves a significant amount of capital investment. The estimated refurbishment costs for Ontario's nuclear power units are presented in Table 10. The case studies discussed in this thesis will use the midpoint estimate when considering refurbishment cost of nuclear units (e.g., \$3.5 billion for Pickering B). Furthermore, it is assumed that the lead-time for the refurbishment of a single nuclear unit will be approximately two years. During the refurbishment process, the unit being refurbished will be shutdown and consequently no electricity can be produced from that unit. The estimates for refurbishment costs were attained from Winfield et al. (2004).

Table 10 – Estimated refurbishment cost for nuclear units in Ontario. All costs are expressed in terms of 2005 Canadian dollars (Winfield et al., 2004).

Station	Cost Range
Bruce 3 & 4	\$720 million
Bruce 1 & 2	\$1.5 to \$2.5 million
Bruce B (5-8)	\$3 to \$4 billion
Pickering A (1-4)	\$3 to \$4 billion
Pickering B (5-8)	\$3 to \$4 billion
Darlington (1-4)	\$3 to \$4 billion
Total	\$14.2 to \$19.2 billion

The decommissioning of nuclear units is a very complex and cost intensive process. The work involved in a nuclear decommissioning project include the dismantling of the plant structure, decontamination of equipment, site remediation, and long term storage of nuclear waste. The estimated cost of decommissioning all 20 nuclear units in Ontario is 7.4 billion (Winfield et al., 2004).

The case studies presented in this thesis assume that all the nuclear power units in Ontario will be refurbished before the end-of-service year outlined in Table 2. The capacity profile for all nuclear units is shown in Table 11.

Table 11 – Capacity (MW) profile for all 20 nuclear units in Ontario from 2006-2020. The shaded area in the table represent the periods in which the unit was shut-down in order to undergo refurbishment.

	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
Pickering 1	515	515	515	515	515	515	515	515	515	515	515	515	515	515	515
Pickering 2	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Pickering 3	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
Pickering 4	515	515	515	515	515	515	515	515	515	515	515	0	0	515	515
PICKERING A	1030	1030	1030	1030	1030	1030	1030	1030	1030	1030	1030	515	515	1030	1030
Pickering 5	516	516	516	0	0	516	516	516	516	516	516	516	516	516	516
Pickering 6	516	516	516	516	0	0	516	516	516	516	516	516	516	516	516
Pickering 7	516	516	516	516	516	0	0	516	516	516	516	516	516	516	516
Pickering 8	516	516	516	516	516	516	0	0	516	516	516	516	516	516	516
PICKERING B	2064	2064	2064	1548	1032	1032	1032	1548	2064	2064	2064	2064	2064	2064	2064
Bruce 1	0	0	0	750	750	750	750	750	750	750	750	750	750	750	750
Bruce 2	0	0	0	0	750	750	750	750	750	750	750	750	750	750	750
Bruce 3	750	750	750	750	750	750	750	0	0	750	750	750	750	750	750
Bruce 4	750	750	750	750	750	750	750	750	750	750	750	0	0	750	750
BRUCE A	1500	1500	1500	2250	3000	3000	3000	2250	2250	3000	3000	2250	2250	3000	3000
Bruce 5	785	785	785	785	785	0	0	0	785	785	785	785	785	785	785
Bruce 6	820	820	820	820	0	0	820	820	820	820	820	820	820	820	820
Bruce 8	785	785	785	785	785	785	0	0	785	785	785	785	785	785	785
Bruce 7	785	785	785	785	785	785	785	0	0	785	785	785	785	785	785
BRUCE B	3175	3175	3175	3175	2355	1570	1605	820	2390	3175	3175	3175	3175	3175	3175
Darlington 1	881	881	881	881	881	881	881	881	881	881	881	881	0	0	881
Darlington 2	881	881	881	881	881	881	881	881	881	881	0	0	881	881	881
Darlington 3	881	881	881	881	881	881	881	881	881	881	881	881	881	0	0
Darlington 4	881	881	881	881	881	881	881	881	881	881	881	881	881	0	0
DARLINGTON	3524	3524	3524	3524	3524	3524	3524	3524	3524	3524	2643	2643	2643	881	1762

The operational and economic parameters for Ontario’s existing nuclear units are presented in Table 12. The data outlined in Table 12 was obtained from Ontario Power Authority (2005).

Table 12 - Operational and economic parameters for existing nuclear units. All costs are expressed in terms of 2005 Canadian dollars (Ontario Power Authority, 2005).

Station	Variable O&M Cost (\$/MWh)	Fixed O&M Cost (\$/MW)	Capacity Factor
Bruce A	1.42	105720	0.9
Bruce B	1.42	105720	0.9
Darlington	1.42	105720	0.9
Pickering A	1.42	105720	0.9
Pickering B	1.42	105720	0.9

Hydroelectric

Hydroelectric power plays a very important role in Ontario’s current energy mix. Approximately 26% of Ontario’s installed capacity is composed of hydroelectric power. There are currently 108 hydroelectric stations within Ontario, but only 58 stations are directly connected to the electricity grid (Ontario Ministry of Energy, 2007).

Ontario’s existing hydroelectric stations provide electricity for both base-load and peak-load demand. The total hydroelectric capacity available to serve base-load demand in Ontario is approximately 3,424 MW. The hydroelectric capacity to meet intermediate and peak-load demand is approximately 3,299 MW (Atomic Energy of Canada Limited, 2005). The hydroelectric stations that are designated for base-load electricity production are the Beck and Decew hydro stations in Niagara, and the R.H. Saunders hydro station near Cornwall (Ontario Ministry of Environment, 2006).

The operational and economic parameters for the existing hydroelectric stations are presented in Table 13. The data outlined in Table 13 was obtained from Ontario Power Authority (2005).

Table 13 - Operational and economic parameters for existing hydroelectric stations in Ontario. All costs are expressed in terms of 2005 Canadian dollars (Ontario Power Authority, 2005).

	Variable O&M Cost (\$/MWh)	Fixed O&M Cost (\$/MW)	CO ₂ Emissions (tonne CO ₂ /MWh)
Hydroelectric	0	40830	0

4.2.2 New Power Plants

In order to meet future electricity demand, new power plants will need to be built. The case studies discussed in this thesis will examine the use of the following supply sources to meet future demand:

- Nuclear
- Pulverized coal combustion (PC)
- Integrated Gasification Combined Cycle (IGCC)
- Natural Gas Combined Cycle (NGCC)
- Long Term Out-Of-Province Hydroelectric Imports

Although additional supply sources exist, the scope of the studies presented in this thesis only considers the above mentioned technologies as possible candidates.

The outlined supply sources all have distinctive characteristics and may differ greatly based on environmental, economical and operational parameters. Some technologies offer lower capital and operating cost at high emission rates, while other supply options have higher associated costs but lower environmental impacts. In terms of capital cost, there are economies of scales that favor construction of large power stations over smaller ones. The capital and operational cost for building one large unit is often lower than if two smaller units, with the same total capacity, were built.

The economical and operational parameters for the PC, IGCC, and NGCC power units used in the case studies are presented in Table 14, Table 15, and Table 16, respectively. The data outlined in Table 14 – Table 16 were obtained from the Integrated Environmental Control Model (IECM) developed by Carnegie Mellon University and the Department of Engineering and Public Policy. The IECM is a computer modeling tool that performs a complete performance, emissions, and cost assessment of various fossil-fueled power plants of different capacity and operational specifications. The estimates for project cash-flow during construction were obtained from Ayres, MacRae, and Stogran (2004). The costs of CCS presented in Table 14 -Table 16 were obtained from Hashim (2006). For the power stations that have an integrated CCS system, the cost associated with CCS is incorporated in the cost and operational parameters presented in Table 14 -Table 16.

The economic and operational parameters for nuclear power plants used in the case studies are presented in Table 17. The data in Table 17 were obtained from Ayres et al. (2004). The case studies presented examine two types of nuclear technologies. The first nuclear unit is a twin ACR-700 nuclear

reactor with a net capacity of 1,406 MW. The second reactor is a twin CANDU 6 nuclear unit with a net capacity of 1,346 MW. The cost and operational parameters of these two nuclear units are significantly different. The capital and fixed operating costs of the twin CANDU 6 units are generally higher than that of the ACR-700 reactors. A slight advantage that CANDU 6 reactors possess is the fact that they have a significantly lower variable operating cost than its predecessor, the ACR-700.

In addition to the power plant technologies discussed above, the case studies presented in this thesis will examine the potential long-term electricity supply from out-of-province hydroelectric imports. More specifically, the case studies consider the potential use of the Ontario-Manitoba Interconnection (OMI) project as a long term electricity supply source. A description of the OMI project is presented in Section 2.2.6. The economic cost for the OMI project is outlined in Table 18. The data from Table 18 was obtained from Ontario Power Authority (2005).

Table 14 – Economic and operational parameters for pulverized coal (PC) power plants. This table presents data for single PC units and PC units that have been retrofitted with a MEA Carbon Capture and Storage (CCS) system. All costs are expressed in terms of 2005 Canadian dollars.

	PC	PC	PC with CCS	PC with CCS	PC with CCS
Gross Capacity (MW)	457.7	526.5	337.4	459.2	491.7
Non-Fuel Variable O&M Cost (\$/MWh)	2.866172247	2.855230313	20.28099538	19.62101636	19.46717892
Fixed O&M Cost (\$/MW)	57290.89899	52839.93878	96454.497	83296.71947	80439.44886
Capital Cost (\$/MW)	1,776,943	1,724,854	3,074,431	2,900,407	2,850,685
Capacity Factor (%)	0.75	0.75	0.75	0.75	0.75
Heat Rate (BTU/MWh)	9.59801646	9.59485123	13.0196244	13.0090736	13.0090736
CO ₂ Emissions (tonne CO ₂ /MWh)	0.875075515	0.874791439	0.118789039	0.118692638	0.11867017
NO ₂ Emissions (tonne NO ₂ /MWh)	3.100E-05	3.0946E-05	3.1485E-05	3.1471E-05	3.1457E-05
NO Emissions (tonne NO/MWh)	0.0004	0.000383	0.000520273	0.000519972	0.000519735
SO ₂ Emissions (tonne SO ₂ /MWh)	0.001085	0.001084	4.27E-07	4.27E-07	4.27E-07
Cost of CCS (\$/tonne CO ₂)	N/A	N/A	74.28	69.27	62.88
Construction lead time (years)	5	5	5	5	5
Project Cash Flow	Year 0: 3.1% (down payment) Year 1: 16.1% Year 2: 30.8% Year 3: 34.1% Year 4: 15.9%				

Table 15 - Economic and operational parameters for Integrated Gasification Combined Cycle (IGCC) power units. This table presents data for single IGCC units and IGCC units that have been retrofitted with a MEA Carbon Capture and Storage (CCS) system. All costs are expressed in terms of 2005 Canadian dollars.

	IGCC	IGCC	IGCC	IGCC with CCS	IGCC with CCS	IGCC with CCS
Gross Capacity (MW)	274.8	552.4	830.3	231.4	465.8	700.5
Non-Fuel Variable O&M Cost (\$/MWh)	1.24	1.23713470	1.24402075	12.9655949	11.1619224	10.4532119
Fixed O&M Cost (\$/MW)	97748.609	72521.9550	63476.4947	145,191.72	112,030.15	74,494.85
Capital Cost (\$/MW)	2,377,150	2,217,331	2,140,382	3,562,173	3,327,773	3,327,773
Capacity Factor (%)	0.85	0.85	0.85	0.85	0.85	0.85
Heat Rate (BTU/MWh)	11.173243	11.1099388	11.0888373	13.3572484	13.2728424	13.2306394
CO ₂ Emissions (tonne CO ₂ /MWh)	0.9860847	0.98092224	0.97896847	0.08997359	0.08939411	0.08915146
NO ₂ Emissions (tonne NO ₂ /MWh)	4.3048E-06	4.2814E-06	4.2732E-06	5.2259E-06	5.1942E-06	5.1802E-06
NO Emissions (tonne NO/MWh)	5.33E-05	5.31E-05	5.29E-05	6.47653E-05	6.43677E-05	6.41958E-05
SO ₂ Emissions (tonne SO ₂ /MWh)	8.92E-05	8.88E-05	8.86E-05	0.000107	0.0001	0.000106
Cost of CCS (\$/tonne CO ₂)	N/A	N/A	N/A	19.79	15.41	15.41
Construction lead time (years)	5	5	5	5	5	5
Project Cash Flow	Year 0: 3.1% (down payment) Year 1: 16.1% Year 2: 30.8% Year 3: 34.1% Year 4: 15.9%					

Table 16 - Economic and operational parameters for Natural Gas Combined Cycle (NGCC) power units. This table presents data for single NGCC units and NGCC units that have been retrofitted with a MEA Carbon Capture and Storage (CCS) system. All costs are expressed in terms of 2005 Canadian dollars.

	NGCC	NGCC	NGCC	NGCC with CCS	NGCC with CCS	NGCC with CCS
Gross Capacity (MW)	253.3	506.5	759.8	216.1	432.3	648.4
Non-Fuel Variable O&M Cost (\$/MWh)	0	0	0	8.57967927	6.68023991	5.93628639
Fixed O&M Cost (\$/MW)	20994.10	15970.730	14284.6016	39322.5348	29082.5243	27003.3712
Capital Cost (\$/MW)	752,685	748,542	746,411	1,319,981	1,220,539	1,240,664
Capacity Factor (%)	0.85	0.85	0.85	0.85	0.85	0.85
Heat Rate (BTU/MWh)	7.177674	7.1776746	7.17767461	8.41105719	8.41105719	8.41105719
CO ₂ Emissions (tonne CO ₂ /MWh)	0.367458	0.3673516	0.36738713	0.04307133	0.04304038	0.04305070
NO ₂ Emissions (tonne NO ₂ /MWh)	4.6237E-06	4.6264E-06	4.6255E-06	4.0662E-06	4.0648E-06	4.0658E-06
NO Emissions (tonne NO/MWh)	5.73E-05	5.73E-05	5.73229E-05	6.71678E-05	6.71732E-05	6.71714E-05
SO ₂ Emissions (tonne SO ₂ /MWh)	0	0	0	0	0	0
Cost of CCS (\$/tonne CO ₂)	N/A	N/A	N/A	71.53	46.98	46.98
Construction lead time (years)	3	3	3	3	3	3
Project Cash Flow	Year 0: 0% (down payment) Year 1: 50% Year 2: 50%					

Table 17 - Economic and operational parameters for nuclear power units. All costs are expressed in terms of 2005 Canadian dollars.

	Twin ACR-700	Twin CANDU 6
Gross Capacity (MW)	1506	1456
Net Capacity (MW)	1406	1346
Variable O&M Cost including Fuel (\$/MWh)	4	2.3
Fixed O&M Cost (\$/MW)	11,160.00	13,270.00
Capital Cost (\$/MW)	2,414,170	3,057,050
Capacity Factor (%)	0.9	0.9
CO ₂ Emissions (tonne CO ₂ /MWh)	0	0
NO ₂ Emissions (tonne NO ₂ /MWh)	0	0
NO Emissions (tonne NO/MWh)	0	0
SO ₂ Emissions (tonne SO ₂ /MWh)	0	0
Construction lead time (years)	8	8
Project Cash Flow	Year 0: 3.1% (down payment) Year 1: 8.0% Year 2: 21.0% Year 3: 27.1% Year 4: 19.6% Year 5: 12.0% Year 6: 7.2 % Year 7: 5.1%	

Table 18 - Economic and operational parameters for long term out-of-province hydroelectric imports. All costs are expressed in terms of 2005 Canadian dollars (Ontario Power Authority, 2005).

	Gross Capacity (MW)	Variable O&M Cost (\$/MWh)	Fixed O&M Cost (\$/MW)	Capital Cost (\$/MW)	CO ₂ Emissions (tonne CO ₂ /MWh)
Long Term Out-of-Province Purchase	1250	0	42350	4,550,000	0

4.2.3 Forecasted Data

Forecasted energy demand was obtained from the analysis generated by Chui et al. (2006). For all case studies, a conservative median energy, base-load, peak-load forecast was assumed. This forecast was discussed in Section 2.5.1 of this thesis.

The NEB fuel forecasts discussed in Sections 2.5.2.1 and 2.5.2.2 were used for the case studies presented. The assumption was made that technology advances gradually and that there is limited action on the environment in Canada (Supply Push scenario).

In terms of Conservation and Demand Management, the case studies presented in this thesis assume a conservation forecast based on programs in which financial incentives equal 50% of incremental cost of new equipment installation (EE50). Data and discussion regarding conservation initiatives are presented in Section 2.5.3.

4.3 Assumptions of Case Studies

The model and case studies presented in this thesis assume the following:

- The electricity generated from nuclear power units is only used for base-load demand. Nuclear units cannot be utilized for peak-demand generation due to design and safety related limitations. For this reason, it is assumed that all power generated from nuclear units will only be used to satisfy base-load demand.
- All existing nuclear units in Ontario will be refurbished before their end-of-service dates. The refurbishment cost associated with each unit is a mid-point estimate of the data presented in Table 10. The time required to refurbish a single unit is assumed to be two years (Winfield et al., 2004). During the refurbishment process, the unit being refurbished will be shutdown and consequently no electricity can be produced from that unit.
- The total hydroelectric capacity available to serve base-load demand in Ontario is approximately 3,424 MW. The hydroelectric capacity to meet intermediate and peak-load demand is approximately 3,299 MW (Atomic Energy of Canada Limited, 2005).
- No new renewable supply sources are realized within the time horizon of the case studies presented in this thesis.
- Fixed and Variable O&M costs for all power stations are assumed to remain constant over time. Although the O&M costs of power stations often increase over time, due to aging of the unit, no reliable data were found to address the increase in O&M costs over time.
- It is assumed that the technology for CCS is available and CO₂ sequestration within the two reservoirs in Ontario, Lake Huron and Lake Erie, can be realized.

4.4 Defining Power Allocation and Installed Capacity

There are two terms that are frequently used when describing electricity production and structure. The first term is “power allocation” and the second is “installed capacity”. Although these two terms are related, they have very different meanings. This section attempts to clarify the meaning of these two terms.

Power allocation is defined as the amount of power (MW) that a given power plant allocates *in order to satisfy demand*. The power allocated from a power plant is further divided into base-load allocation and peak-load allocation. Similar to its root meaning, base-load allocation is the amount of power that a power plant allocates to meet base-load demand, and peak-load demand is the amount of power that a power plant allocates in order to meet peak-load demand.

Alternatively, installed capacity is defined as a power plant’s electric generating capacity *when operating at full production*. It is measured in MW units. The installed capacity of a power plant does not give any indication of how much power has been assigned to meet demand.

The case studies presented in the following sections will describe the fleet-structure in terms of power allocation.

4.5 Case Study I: Base Case

The base case represents a scenario in which no CO₂ emission limits are imposed on the electricity sector. Moreover, this case study assumes that a carbon credit system or market is established in which individual power stations may purchase carbon credits at a cost. It is assumed that the technology for CCS in Ontario is available and can be implemented if needed.

This case study also assumes that the phasing-out of coal power plants is not enforced by the policy makers. The existing nuclear power units will be refurbished based upon their estimated end-of-service dates. Furthermore, the assumption is made that all new or existing nuclear power plants are only used to meet base-load demand and are not used to satisfy peak-demand. Conversely, wind power will be used for the purpose of meeting peak demand and not base load demand.

Results for Case Study I are presented in the following sub-sections.

4.5.1 Fleet Structure: New construction, fuel-switching, and CCS retrofit

Table 19 illustrates the construction of new power stations for the base case. It includes the year in which the construction of new power plants started (represented by an “X”), as well as the years during which the unit is under construction (represented by the shaded area).

Table 19 – Case Scenario I: Construction of new power stations. The “X” represents the year in which construction of the new generating unit started and the shaded are represents the years during which the unit is under construction. The years after the shaded areas assume the unit to be fully operational.

Net Capacity (MW)	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
New Power Plant Without CCS															
PC-31	526.5	X													
NGCC-22	1013	X													
NGCC-31	759.8			X											
NGCC-32	1519.6				X										
NGCC-23	1519.5								X						
NGCC-21	506.5										X				

From Table 19, it can be seen that for the base case, one new PC and five new NGCC power stations need to be built between 2006 and 2020. The total net capacity of all new NGCC and PC units is 5,318 MW and 526.5 MW respectively.

For this case study, the model selected to keep all existing coal, natural gas, wind, and hydroelectric power stations operational throughout the study period (2006-2020).

No fuel-switching was implemented on existing coal power plants by the model. The decision not to fuel-switch any of the existing coal power plants to natural gas is due to the fact that there are no CO₂ limits in the base case. Since no CO₂ limits are imposed, and operating a unit using coal as a fuel source is cheaper than using natural gas, the model selected to continue using coal as its fuel source rather than fuel-switch to natural gas. Additionally, there is a capital cost associated with fuel-switching a coal powered station to natural gas which would not be justified in this scenario. The decision to not fuel-switch existing coal power plants will inevitably lead to higher CO₂ emissions if no CCS is implemented.

Even though PC power plants have lower fuel cost than NGCC's, the model chose to build five new NGCC power stations and only one new PC. This may be due to the lower capital cost of building a new NGCC unit outweighing the fuel costs associated with use of natural gas.

Since there are no CO₂ emission constraints in place, the model did not retrofit any of the existing coal power plants with CCS. Putting a CCS system in place requires significant capital investment which would increase the total cost without justification in this case.

4.5.2 Power Allocation and Electricity Production

Total power (MW) allocated from each supply technology for the base case is presented in Figure 21. Total percent of power allocated to each generating technology for years 2006, 2010, 2015 and 2020 is given in Figure 22.




Figure 21 - Case Scenario I: Total power allocated (MW) from each supply technology.




Figure 22 - Case Scenario I: Total power allocation in terms of percentage for the years 2006, 2010, 2015 and 2020.

From Figure 21, it can be seen that the power allocated from renewable sources stays constant at 7,902 MW. The power allocated from renewable sources does not increase since no new renewable supply sources are considered in any of the case studies, as discussed in Section 4.3. Existing NG and oil allocation reaches a maximum of 4,814 MW in 2010. From this year on, the NG and oil allocation stays constant. In order for existing NG and oil power to exceed its maximum capacity, at least one of the coal power units would have to fuel-switch to natural gas. As discussed in the previous section, there is no fuel-switching in the base case.

As shown in Figure 21, power allocated from coal plants remains constant at a maximum of 6,285 MW. All coal power units are operating at maximum capacity during 2006-2020 in order to meet both peak-load and base-load demand. No long term hydroelectric imports are realized. From Figure 21, power allocated from nuclear plants ranges from 7,364 MW in year 2013 to 10,057 MW in 2015. As discussed in Section 4.2.1, during the time period studied some nuclear power plants will undergo refurbishment at certain years (for instance, Pickering 4 undergoes refurbishment during the 2017-2018 period). During this time, the units that are being refurbished cannot generate any electricity and cannot contribute to the total power allocated from nuclear plants.

No NGCC+CCS, IGCC+CCS, PC+CCS, and IGCC were constructed during the time horizon considered, and hence no power was allocated from these supply sources. From Figure 21, power allocated from NGCC ranges from 101 MW in 2009 to 5,312 MW in 2019. PC operates at a maximum capacity of 526.5 MW from the first year of operation, 2011.

From Figure 22, it can be seen that in the year 2006 13% of power is allocated from existing NG and oil, 24% from coal, 30% from renewable sources and 33% from nuclear plants in order to meet demand. By year 2010, NGCC becomes part of the total energy mix. By the year 2015, PC also contributes to the total power.

As energy demand rises over the years, the percent of power allocated from nuclear sources comprises less of the total supply mix. By 2020, percent of power allocated from nuclear sources amounts to 26% of the total mix.

Figure 23 and Figure 24 show the power (MW) allocated from each supply source to meet base-load and peak-load demands, respectively.




Figure 23 – Case Study I: Power allocated to meet base-load demand (MW).




Figure 24 – Case Study I: Power allocated to meet peak-load demand (MW).

As shown in Figure 23, base-load demand is mostly satisfied by the utilization of renewable, coal, and nuclear power. In 2013, in addition to renewable, coal, and nuclear, 115 MW of power is allocated from the new PC generating unit. The model did not allocate any power from NGCC or existing NG and oil sources to meet base-load demand. This may be because in order to meet base-load demand the unit would have to be operated continuously, and as natural gas is an expensive fuel source it most likely was not cost-effective to use NGCC for base-load.

During the time period between 2006 and 2020, the forecasted base-load demand varies and power allocation is adjusted to meet demand accordingly.

As illustrated in Figure 24, peak-load demand is satisfied by various supply sources, including NGCC, renewable, coal, PC, and existing NG and oil. In this case, NGCC and existing NG and oil are utilized since they are operated only during periods of peak demand and are hence cost-effective. The model did not allocate any power from nuclear sources due to the assumption that nuclear units can only be used to meet base-load demand (see Section 4.3).

During the time period between 2006 and 2020, the forecasted peak-load demand increases steadily and new power plants must be brought online in order to satisfy this demand.

The total electricity production (TWh) from each supply technology for the base case is presented in Figure 25. The percent of electricity production from each supply source for years 2006, 2010, 2015 and 2020 is given in Figure 26.




Figure 25 – Case Study I: Total electricity production (TWh) from all supply sources.




Figure 26 – Case Study I: The percent of electricity production from each supply source for years 2006, 2010, 2015 and 2020.

As shown in Figure 25 and Figure 26, a significant amount of electricity production is generated from nuclear power. The electricity produced from nuclear power plants ranges from 65 TWh in 2013 to 88 TWh in 2015. By the year 2015, nuclear power produces about 51% of the electricity needed to meet Ontario’s demand.

Electricity production from NGCC becomes part of the energy mix in 2009, once the first NGCC power plant has been constructed. The electricity production from NGCC ranges from 0.34 TWh in 2010 to 15 TWh in the year 2019. Electricity generation from new PC power plants remains constant from 2011 through 2020. Electricity production from existing NG and oil, coal, and renewable sources generally decreases over time, as new, more efficient supply sources are introduced to the energy mix.

Figure 27 and Figure 28 illustrate the electricity production generated to meet base-load and peak-load, respectively.




Figure 27 - Case Study I: Electricity production generated to meet base-load demand (TWh).




Figure 28 - Case Study I: Electricity production generated to meet peak-load demand (TWh).

Electricity generated to meet base-load demand comes predominantly from nuclear power plants. As shown in Figure 27, the electricity generated from nuclear plants accounts for more than half of Ontario’s base-load electricity demand. The remaining electricity demand is satisfied by renewable, existing coal, and PC energy. The production of electricity from the PC power plant is introduced only in the year 2013, at which time it produces 1 TWh to help meet base-load demand.

Energy production required to meet peak-load electricity demand is generated from various supply sources. Renewable, existing NG and oil, and coal generate most of the electricity to meet peak-load demand from 2006 through 2020. By year 2018-2019, NGCC sources become a large contributor of electricity.

4.5.3 Economic Analysis

The annual expenditure, presented in 2006 Canadian dollars, of the entire electricity sector is shown in Figure 29. The annual expenses consist of: variable O&M for new and existing power station, fixed O&M for new and existing power station, capital cost associated with fuel-switching, cost refurbishment of existing nuclear units, cost of CO₂ credits, fuel costs, and capital cost for construction of new power stations.




Figure 29 – Case Study I: Annual expenditure of entire electricity sector. All costs are expressed in terms of 2006 Canadian dollars.

As shown in Figure 29, the major factors which contribute to the cost of generating electricity are fuel cost, refurbishment cost for existing nuclear units, and fixed O&M cost for existing power stations.

The cost of fuel is the largest contributor to the total annual cost of generating electricity. Fuel cost for the entire fleet rises steadily from 2006 to 2011. The observed increase in fuel prices is mainly due to a rise in electricity demand, variability in natural gas prices and utilization of new power stations. The cost of fuel drops during 2014-2015, but steadily continues to rise after 2015 and reaches a maximum of \$2.2 billion in year 2019.

The cost of nuclear refurbishment is particularly large from 2010 to 2014. During this time period, 9 nuclear units are scheduled to be refurbished. The maximum refurbishment cost of existing nuclear units occurs during the years 2011-2013.

The fixed O&M cost for existing power stations remains relatively steady during the entire time horizon studied. The maximum expenditure for fixed O&M costs is incurred during year 2015, at a cost of \$1.68 billion.

The lowest contributor to the annual expenditure is the variable O&M costs for new power plants. The variable O&M costs associated with new power stations is not considered until the year 2009, since no new power plants have been built until this time. After 2009, a new NGCC-22 power station is brought online and the fixed O&M cost associated with operating this power plant is accounted for. The variable O&M cost for new power stations increases after 2009 as new power stations are built, and reaches a maximum of \$100.9 million in year 2020.

The costs associated with fuel switching, CCS, and carbon credit purchases are zero since these options were not realized in this case study.

The breakdown of the total expenditure by sector for the entire study period (2006-2020) is presented in Figure 30.




Figure 30 - Case Study I: Total expenditure for entire study period (2006-2020). All costs are expressed in terms of 2006 Canadian dollars (\$billion).

As shown in Figure 30, the highest contributors to the total expenditure are cost of fuel, fixed O&M costs for existing generating stations, and nuclear refurbishment cost, with a total cost of \$25.22, \$22.43 and \$11.97 billion, respectively. This is in-line with the year-to-year results shown in Figure 29. Variable cost associated with new power plants accounts for the lowest part of the total expenditure, with a total cost of \$50 million. The total expenditure for the entire study period is \$70.10 billion.

The cost of electricity (COE) during the period under study is presented in Figure 31. The COE values were obtained by dividing total annual expenditure with the annual electricity production. The average COE for the study period is 2.804 cents/kWh.




Figure 31 - Case Study I: Annual cost of electricity (COE) for the entire study period (2006-2020). All costs are expressed in terms of 2006 Canadian dollars.

As shown in Figure 31, the COE varies significantly throughout the span of the study period. The COE ranges from a minimum of 2.09 cents/kWh in 2006, to a maximum of 3.38 cents/kWh in 2012. The variability associated with the COE in any particular year is dependent on all the factors that are considered in the total expenditure for that year. For instance, the high COE observed in year 2012 is due to a large amount of capital spent on fuel, construction of new power plants, and refurbishment of nuclear units, relative to how much electricity is generated. Similarly, the low COE experienced in 2006 is due to the low capital expenditure spent relative to the electricity generated.

4.5.4 Carbon Dioxide Emissions

Annual CO₂ emissions from the entire fleet are presented in Figure 32. The total CO₂ emission over the study period amount to 525 Mt. Note that no CO₂ emissions limits are imposed on the base case, and hence it is expected that the base case will have the highest CO₂ emissions from the two case studies examined in this thesis.




Figure 32 - Case Study I: Annual carbon dioxide emissions (Mt CO₂) from entire fleet.

As can be seen in Figure 32, the annual CO₂ emissions from the entire fleet vary significantly from year-to-year.

The CO₂ emissions increase steadily from year 2006 through 2013, reaching a maximum peak of 44.052 Mt. After the year 2013, CO₂ emissions briefly decrease but go back up and continue rising after 2015. The maximum CO₂ generated occurs in 2019, with a total of 44.058 Mt of CO₂ released to the atmosphere.

As shown in Figure 32, the Nanticoke coal-fired generating station is the single largest source of CO₂ emissions. In 2013, Nanticoke alone was responsible for 52.98% of the CO₂ emissions generated from the entire fleet.

Since CO₂ emissions from other locations remain relatively constant throughout the study period, it seems that Nanticoke is mainly responsible for the observed variability in CO₂ emissions over the time period studied.

4.6 Case Study II: CO₂ emissions 6% below 1990 levels

Case Study II presents a scenario in which Ontario's electricity sector must comply with annual CO₂ emissions 6% below 1990 levels. This regulation comes into effect after year 2011. There are no CO₂ emission limits enforced between 2006 and 2011. After the year 2011, Ontario's fleet must comply with an annual CO₂ emission limit of 20 Mt (6% below 1990 level). Moreover, this case study assumes that a carbon credit system or market is established in which individual power stations may purchase carbon credits at a cost. It is assumed that the technology for CCS in Ontario is available and can be implemented if needed.

This case study also assumes that the phase-out of the coal power plants is not enforced by the policy makers. The existing nuclear power units will be refurbished based upon their estimated end-of-service dates. Furthermore, the assumption is made that all new or existing nuclear power plants are only used to meet base-load demand and are not utilized to satisfy peak-demand. Wind power will be used for the purpose of meeting peak demand and not base load demand.

Results for Case Study II are presented in the following sub-sections.

4.6.1 Fleet Structure: New construction, fuel-switching, and CCS retrofit

Table 20 illustrates the construction of new power stations for Case Study II. It includes the year in which the construction of new power plants started (represented by an “X”), as well as the years during which the unit is under construction (represented by the shaded area).

Table 20– Case Study II: Construction of new power stations. The “X” represents the year in which construction of the new generating unit started and the shaded are represents the years during which the unit is under construction. The years after the shaded areas assume the unit to be fully operational.

	Net Capacity (MW)	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
New Power Plant Without CCS																
NGCC21	506.5	X														
NGCC32	1519.6		X													
NGCC33	2279.4				X											
New Power Plant With CCS																
NGCC21	432.3				X											
NGCC31	648.4				X											
Nuclear Power Plants																
ACR-700	1406	X														

From Figure 26, it can be seen that for Case Study II, three new NGCC power plants without CCS and two NGCC power plants with CCS system need to be built between 2006 and 2020. The net capacity of all new NGCC units without CCS and NGCC with CCS totals 4,305.5 MW and 1,080.7 MW respectively.

In addition to the three new NGCC power plants, one ACR-700 nuclear power plant is built in 2006. The net capacity of this nuclear power plant is 1,406 MW. The ACR-700 power plant will be under construction for 7 years and will be available for service after 2012.

For this case study, the model selected to keep all existing coal, natural gas, wind, and hydroelectric power stations operational throughout the study period (2006-2020).

Fuel-switching was implemented at Nanticoke, Atikokan, and Thunder Bay during the years 2012, 2017, and 2017 respectively. Table 21, illustrates the coal power plants that have been fuel-switched to NG. The “X” in Table 21 represents the year in which fuel-switching should be implemented and the shaded area represents the years in which that particular power plant is operated using NG as its fuel.

Table 21 - Case Study II: Existing coal power plants that have been fuel-switched to natural gas. The “X” represents the year in which fuel-switching was implemented and the shaded area represents the years in which that specific coal power plant is using natural gas as its fuel source.

	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
Lambton															
Nanticoke							X								
Atikokan												X			
Lennox															
Thunder Bay												X			

As shown in Table 22, a CCS system is to be retrofitted onto Lambton coal power plant in 2018. The “X” in Table 22 represents the year in which CCS retrofit should be implemented and the shaded area represents the years in which that particular power plant is operating with CCS system in place.

Table 22 - Case Study II: Existing coal power plants that have been retrofitted with a CCS system. The “X” represents the year in which the coal power plant was retrofitted with a CCS system and the shaded area represents the years in which the plant is operating with a CCS system in place.

	2006	2007	2008	2009	2010	2011	2012	2013	2014	2015	2016	2017	2018	2019	2020
Lambton													X		
Nanticoke															
Atikokan															
Lennox															
Thunder Bay															

4.6.2 Power Allocation and Electricity Production

Total power (MW) allocated from each supply technology for the base case is presented in Figure 33. The percent of power allocation based on generating technology for years 2006, 2010, 2015 and 2020 is given in Figure 34.




Figure 33 - Case Study II: Total power allocated (MW) from each supply technology.




Figure 34 - Case Study II: Total power allocation in terms of percentage for the years 2006, 2010, 2015 and 2020.

From Figure 33, it can be seen that the power allocated from renewable sources stays constant at a maximum level of 7,902 MW. As discussed in Section 4.3, the maximum capacity is reached because no new renewable supply sources are considered in the two case studies.

Existing NG and oil allocation reaches a maximum of 9,151 MW in 2018. The increase in the maximum capacity of existing NG and oil plants is due to the fact that Nanticoke, Atikokan, and Thunder Bay coal power stations undergo fuel-switching during years 2012, 2017, and 2017 respectively.

Power allocated from coal power plants ranges from 0 MW to 6,269 MW, as shown in Figure 33. Coal power is highly utilized throughout the time frame in which no CO₂ limits are imposed on Ontario’s electricity sector (2006-2011).

In years 2012, 2013, and 2017 there is no power production from any of the Coal power plants. During these years other electricity-generating technologies must be utilized in order to fill the energy gap created. Electricity-generating technologies used during these years include NGCC+CCS and existing NG and oil.

As shown in Figure 33, no long term hydroelectric imports are realized. Furthermore, power allocated from nuclear plants ranges from 8,820 MW in year 2010 to 10,172 MW in 2016. The construction of the new ACR-700 nuclear power plant is completed at the end of 2012. After 2012, the newly constructed nuclear units are available for power supply to the grid.

No IGCC+CCS, PC+CCS, IGCC, and PC were constructed during the time horizon considered, and hence no power was allocated from these supply sources. From Figure 33, power allocated from NGCC ranges from 51 MW in 2014 to 4,306 MW in 2012. The power allocated by NGCC+CCS ranges from a minimum of 236 MW to maximum of 1,081 MW.

From Figure 34, it can be seen that in year 2006, 13% of power is allocated from existing NG and oil, 24% from coal, 30% from renewable sources and 33% from nuclear plants.

As energy demand rises over the years, the percent of power allocated from nuclear sources remains relatively constant. This constant percentage from the total supply mix is maintained due to the construction of the new ACR-700 nuclear power plant which is scheduled to start producing electricity by 2013.

While the percent power allocation from nuclear power plants remains constant, the percent power allocated by coal power plants decreases over time. In 2006, the percent of power allocation from coal power plants is 24%. By 2020, the percent of power allocated from coal power plants amounts to only 3% of the total mix.

Figure 35 and Figure 36 show the power (MW) allocated from each supply source to meet base-load and peak-load demands respectively.




Figure 35 - Case Study II: Power allocated to meet base-load demand (MW).




Figure 36 - Case Study II: Power allocated to meet peak-load demand (MW).

As shown in Figure 35, base-load demand is predominantly satisfied with use of renewable and nuclear power. The reason these two technologies are primarily used to meet base-load demand is because they are cheap and clean technologies that may be used to generate electricity on a continuous basis.

Coal power plants are utilized in order to help meet base-load demand during the time period in which no CO₂ emission constraints are imposed on the electricity sector (2006-2011). After 2011, the year after which CO₂ emissions are imposed, the use of coal technology is no longer utilized to meet base-load demand. The use of coal technology to meet base-load demand is no longer chosen after year 2011 because of the high CO₂ emissions that coal power plants generate.

NGCC, NGCC+CCS, and existing NG and oil power plants are used to meet base-load demand after the year 2011. The utilization of these generating technologies in order to meet base-load demand is minimal due to the high fuel-cost associated with the continuous operation of these plants.

As illustrated in Figure 36, peak-load demand is satisfied by various supply sources, including NGCC, NGCC+CCS, renewable, coal, and existing NG and oil. Conversely to base-load demand, NGCC is highly utilized since it is operated only during periods of peak demand and is hence cost-effective. The model did not allocate any power from nuclear sources due to the assumption that nuclear units can only be used to meet base-load demand (see Section 4.3).

The utilization of coal power in order to meet peak-load demand decreases significantly after the year 2011. The decrease in power allocation from coal power plants is due to the CO₂ emission restrictions imposed on the electricity sector after this year. In order to reduce CO₂ emissions to target levels, the model chose to reduce the use of coal power plants, and instead utilize less carbon-intensive fueled plants such as NGCC.

During the time period between 2006 and 2020, the forecasted peak-load demand increases steadily and new power plants must be brought online in order to satisfy this demand.

The total electricity production (TWh) from each supply technology for Case Study II is presented in Figure 37. The percent of electricity production from each supply source for years 2006, 2010, 2015 and 2020 is given in Figure 38.




Figure 37 - Case Study II: Total electricity production (TWh) from all supply sources.




Figure 38 – Case Study II: The percent of electricity production from each supply source for years 2006, 2010, 2015 and 2020.

As shown in Figure 37 and Figure 38, a significant amount of electricity production is generated from nuclear power. The electricity produced from nuclear power plants ranges from 72 TWh to 89 TWh. By year 2015, nuclear power produces about 51% of the electricity needed to meet Ontario's demand.

Electricity production from NGCC commences in 2009, after the first NGCC power plant has been constructed. The electricity production from NGCC ranges from 0.2 TWh in 2009 to 13 TWh in the year 2014. Electricity produced from the two NGCC+CSS is connected to the grid in 2012 and ranges from 1 TWh to 8 TWh.

The electricity production from coal power plants decreases significantly after the year 2011. This decrease in electricity production from coal power plants is compensated by increasing the electricity production output of other supply technologies. The underlying reason why the model decided to decrease electricity production from coal power plants is due to the CO₂ emission targets set after the year 2011.

Electricity production from existing NG and oil, nuclear, NGCC, and NGCC+CSS generally increase over time. The increase in electricity production from these supply technologies is due to a decline in electricity generation from coal power plants and an increase in electricity demand.

Figure 39 and Figure 40 illustrate the electricity production generated to meet base-load and peak-load respectively.




Figure 39 - Case Study II: Electricity production generated to meet base-load demand (TWh).




Figure 40 - Case Study II: Electricity production generated to meet peak-load demand (TWh).

Electricity generated to meet base-load demand is predominantly produced from nuclear power plants. As shown in Figure 39, the electricity generated from nuclear plants accounts for more than half of Ontario’s base-load electricity demand. The remaining electricity demand is satisfied by renewable, coal, NGCC, NGCC+CCS, and existing NG and oil supply technologies. After 2011, coal power plants are no longer used in order to meet Ontario’s base-load electricity production demand.

Energy production for peak-load electricity demand is generated from various supply sources. Renewable, existing NG and oil, and coal generate most of the electricity to meet peak-load demand from 2006 through 2011. After 2011, coal power plants play a less significant role in energy production for peak-load demand and other supply technologies, such as NGCC, become large contributors to electricity generation.

4.6.3 Economic Analysis

The annual expenditure, presented in 2006 Canadian dollars, of the entire electricity sector is shown in Figure 41. The annual expenses consist of: variable O&M for new and existing power station, fixed O&M for new and existing power station, capital cost associated with fuel-switching, cost refurbishment of existing nuclear units, cost of CO₂ credits, fuel costs, and capital cost for construction of new power stations.




Figure 41 - Case Study II: Annual expenditure of entire electricity sector. All costs are expressed in terms of 2006 Canadian dollars.

As shown in Figure 41, the major factors that contribute to the cost of generating electricity are fuel costs, refurbishment costs for existing nuclear units, and fixed O&M costs for existing power stations.

Similar to Case Study I, the cost of fuel is the biggest contributor to the total annual cost of generating electricity. Fuel cost for the entire fleet rises steadily from 2006 to 2012. The increase in fuel prices is mainly due to a rise in electricity demand, variability in natural gas prices, and the utilization of new supply technologies which use natural gas as fuel. The cost of fuel drops during years 2013-2015, but continues to rise steadily after 2015. The highest expenditure occurs in 2012, when \$2.8 billion dollars are spent on fuel costs.

The cost of nuclear refurbishment is particularly high from 2010 to 2014. During this time period, 9 nuclear units are scheduled to be refurbished. The maximum expenditure for refurbishment of existing nuclear units occurs during the years 2011-2013.

The fixed O&M cost for existing power stations remains relatively steady during the entire time horizon studied. The maximum expenditure for fixed O&M costs occurs during year 2015, at a cost of \$1.59 billion.

The capital expenditure for building new power plants is significantly high from year 2006 through 2012. The high capital expenditure experienced during this time period is due to the construction of 6 new power plants (3 NGCC, 2 NGCC+CCS, and 1 nuclear). The construction of these new units requires a considerable amount of cash-flow during 2006-2012.

The lowest contributor to the annual expenditure is the variable O&M cost for new power plants and the cost associated with CCS. The variable O&M cost associated with new power stations is not considered until the year 2009, since no new power plants have been built until this time. After 2009, a new NGCC-21 power station is brought online and the fixed O&M cost associated with operating this power plant is accounted for. The variable O&M cost for new power stations increases after 2009 as new power station are built, and reaches a maximum of \$108.1 million in year 2020.

The cost associated with CCS is considered in the year 2012, when the two new NGCC+CCS power plants are scheduled to start operation. The expenditure for CCS is not significantly high during 2011 through 2017, due to the low amount of CO₂ captured and sequestered from the new NGCC power plants. The

cost of CCS increases considerably in 2018, when the Lambton coal power plant is retrofitted with a CCS system. The CCS annual expenditure reaches a maximum of 161.7 million in the year 2020.

The cost associated with carbon credits is zero since no carbon credits were purchased in any year.

The breakdown of the total expenditure by sector for the entire study period (2006-2020) is presented in Figure 42.




Figure 42 - Case Study II: Total expenditure for entire study period (2006-2020). All costs are expressed in terms of 2006 Canadian dollars (\$billion).

As shown in Figure 42, the highest contributors to total expenditure are cost of fuel, fixed O&M costs for existing generating stations, and nuclear refurbishment costs with a total price of \$30.34, \$21.33 and \$11.97 billion respectively. This is in-line with the year-to-year results shown in Figure 41. The costs associated with fuel-switching, capital and O&M costs of CCS retrofit, and variable cost associated with new power plants accounts for the lowest parts of the total expenditure, with a total cost of \$10, \$54 and \$54 million respectively. The total expenditure for the entire study period is \$79.10 billion.

Figure 43 illustrates the annual COE for Case Study II. The COE values were obtained by dividing total annual expenditure with the annual electricity production. The average COE for the study period is 3.129 cents/kWh.




Figure 43 - Case Study II: Annual cost of electricity (COE) for the entire study period (2006-2020). All costs are expressed in terms of 2006 Canadian dollars.

As shown in Figure 43, the COE varies significantly throughout the span of the study period. The COE ranges from a minimum of 2.252 cents/kWh in 2006, to a maximum of 4.12 cents/kWh in 2012. The variability associated with the COE in any particular year is dependent on all the factors that are considered in the total expenditure for that year. For instance, the high COE observed in year 2012 is due to a large amount of money being spent on fuel, construction of new power plants, and refurbishing nuclear units, relative to how much electricity is generated. Similarly, the low COE experienced in 2006 is due to the low capital expenditure spent relative to the electricity generated.

4.6.4 Carbon Dioxide Emissions

Annual CO₂ emissions from the entire fleet are presented in Figure 44. The total CO₂ emissions over the study period amount to 359 Mt. Note that an annual CO₂ emissions limit of 20 Mt after the year 2011 was imposed in this case study, and hence it is expected that this case study will have lower CO₂ emissions compared to the base case.




Figure 44 - Case Study II: Annual carbon dioxide emissions from entire fleet.

As can be seen in Figure 44, the annual CO₂ emissions from the entire fleet are relatively high during the years in which no CO₂ emission limits are imposed (2006 through 2011), and constant at 20 Mt after year 2011 when an annual CO₂ limit is imposed on the entire fleet.

The CO₂ emissions from the fleet increase from 2006 through 2011, reaching a peak of 36 Mt in 2011. As shown in Figure 44, the Nanticoke coal-fired generating station is the single largest source of CO₂

emissions during the years in which no emissions limits are imposed. In 2011, Nanticoke alone is responsible for 50.09 % of the CO₂ emissions generated from the entire fleet.

After the year 2011, the annual CO₂ emissions from the entire fleet remains constant at 20 Mt due to the annual CO₂ emissions imposed on the fleet.

4.7 Comparison of Case Studies

The following section presents a comparative analysis of the two case studies outlined in Sections 4.5 and 4.6. The comparative analysis is done based on differences in fleet structural, power production, economical expenditure, and environmental impacts.

The fleet structure for Case Study I and II differs notably. As can be seen in Table 23, in the base case (Case Study I), one PC power plant and five new NGCC power plants were built, whereas for the case study with CO₂ emission limits (Case Study II), three NGCC, two NGCC+CCS, and one nuclear power plant were built. There were no new coal-fueled supply technologies built in Case Study II.

Table 23 - Comparison of new power plants built for Case Study I and II. The table presents the type of technology, net capacity, and the year in which construction should commence.

	Technology	Net Capacity (MW)	Start of construction	Total capacity (MW)
Case Study I	PC-31	526.5	2006	5318.5
	NGCC-22	1013	2006	
	NGCC-31	759.8	2008	
	NGCC-32	1519.6	2010	
	NGCC-23	1519.5	2014	
	NGCC-21	506.5	2016	
Case Study II	NGCC21	506.5	2006	4305.5
	NGCC32	1519.6	2007	
	NGCC33	2279.4	2009	
	NGCC21+CCS	2279.4	2009	2711.7
	NGCC31+CCS	432.3	2009	
	ACR-700 Nuclear Unit	1406	2006	1406

In Case Study I, decision criteria were based on several parameters such as the construction capital costs, operation parameters, and fuel price forecasts. The optimal solution was found based on the imposed parameters and with no consideration for CO₂ emissions. It was not economically justified to implement any CCS systems for this case since there were no requirements to reduce CO₂ emissions.

For Case Study II, CO₂ emission constraints are imposed and the optimal solution involves considering the power plant technologies that meet CO₂ emission requirements. The optimizer has to be mindful of CO₂ emissions when choosing to build a new power plant. Unlike the base case, two NGCC plants were built with an integrated CCS system in Case Study II. Furthermore, no PC plants were built.

In regards to the existing coal power plants, there are several notable differences between the base case and Case Study II. These include the implementation of fuel-switching, retrofitting with CCS, and the power allocated from each power plant in order to meet demand.

Table 24 shows whether fuel-switching and CCS retrofitting was implemented for each existing coal power plant in the two cases studied.

Table 24 – Comparison of fuel-switching and CCS retrofit implementation between Case Study I and II.

Power Plant	Fuel-Switching		CCS Retrofit	
	Case Study 1	Case Study 2	Case Study 1	Case Study 2
Lambton	No	No	No	Yes
Nanticoke	No	Yes	No	No
Atikokan	No	Yes	No	No
Lennox	No	No	No	No
Thunder Bay	No	Yes	No	No

As shown in Table 24, Nanticoke, Atikokan, and Thunder Bay power plants were fuel-switched for Case Study II, while none of the coal power plants were fuel-switched in the base case. This is because the capital costs and the fuel costs associated with switching an existing coal power plant to NG are considerable. The driving force behind fuel-switching is to lower CO₂ emissions and since there are no CO₂ emission constraints, no incentives exist to choose this option in the base case.

For the same reasons listed above, Lambton was retrofitted with a CCS system in 2018 for Case Study II but no CCS was implemented in Case Study I (Table 24). Once again, retrofitting a power plant with a CCS system is only justified when CO₂ emissions need to be reduced.

As shown in Figure 21 of Section 4.5.2, in the base case the power allocation from coal power plants is maximized in each year of the period studied. This implies that all coal power units are operational at maximum capacity in order to meet peak-load or base-load demand. The power allocation from coal power plants for Case Study II is shown in Figure 33 of Section 4.6.2. As can be seen from this figure, not all coal units are running at full capacity in Case Study II. While coal power plants were utilized to the maximum to meet demand in Case Study I, maximum coal power plant utilization was only employed from 2006-2011 for Case Study II. During these years, no annual CO₂ limits were imposed. After this

time, annual CO₂ emissions are constrained for Case Study II, and coal power plants are utilized minimally. This is due to the high CO₂ emissions associated with using coal power plants that have no CO₂ mitigating technologies.

In Case Study II, maximum coal power plant utilization was employed from 2006-2011 to meet base-load and peak-load demand. From 2011-2020, coal power plants were utilized minimally to meet peak-load demand, and were not used at all to meet base-load demand. This is because in order to meet base-load demand, the coal plants would need to be run continuously which would generate high CO₂ emissions. For peak-load demand, however, the coal plants do not need to be used continuously but only need to be turned on during peak periods and CO₂ emissions associated with such operation are much lower. In order to compensate for the gap in power production created by not using coal power plants, other supply technologies were used in Case Study II to meet demand, such as NGCC+CCS, NGCC, and new nuclear.

In both the base case and Case Study II, the optimizer decided to maximize renewable energy production (maximum of 7,902 MW). This is because renewable energy is a clean and inexpensive supply source. For the base case the fact that renewable energy is a clean energy source is not the determining factor in choosing it, since there are no CO₂ emission limits, but it is rather its low-cost that is the motivation behind renewable energy utilization.

The long-term hydro imports discussed in Section 2.2.6 were not utilized in either of the case studies examined. This is because the optimizer determined that it would be more economically feasible to build other supply technologies rather than use long term hydroelectric imports from Ontario-Manitoba Interconnection project.

Table 25 presents a comparison of the total expenditure for Case Study I and Case Study II for the entire study period of 2006-2020.

Table 25 – Comparison of total expenditure (2006 \$CAN billion) between Case Study I and II.

Expenditure	Total expenditure (2006 \$CAN billion)		
	Case Study 1 : Base Case	Case Study II : 6% below 1990 levels	Difference (Case II – Case I)
Nuclear refurbishment	11.97	11.97	0
Capital for new power	4.88	8.17	3.29
Capital for fuel-switching	0	0.1	0.1
Fixed O&M of existing	22.43	21.33	-1.1
Fixed O&M of new	0.87	1.03	0.16
Fuel	25.22	30.34	5.12
Variable O&M of existing	5.58	5.07	-0.51
Variable O&M of new	0.05	0.54	0.49
Capital and O&M of CCS	0	0.54	0.54
Total	70.99829	79.09674	8.09846

The cost of capital for new power plants is higher for Case Study II than the base case by \$3.29 billion. This is because of the higher cost of building low-CO₂ emission facilities, such as NGCC+CCS. In particular, the cost of building a new nuclear plant is a major factor in the higher capital costs seen in Case Study II.

From Table 25, the cost of fuel is higher for Case Study II since more power plants using natural gas are employed in this case. Since the cost of natural gas is higher compared to the other fuel sources, the overall cost is higher for Case Study II.

Fixed and variable O&M costs of existing plants were lower for Case Study II compared to the base case. This is mainly due to the fact that the coal power plants in Case Study II are operated less frequently than in the base case. However, fixed and variable O&M costs for new plants were higher for Case Study II since operating costs of new plants, such as NGCC+CCS, are higher than for NGCCs with no CCS systems. Furthermore, the new power plants are utilized more in order to meet demand, and hence the associated O&M costs are higher.

From Sections 4.5.4 and 4.6.4, the total CO₂ produced for Case Study I and Case Study II is 525 Mt and 359 Mt respectively. Thus, there is a total of 166 Mt less CO₂ produced in Case Study II. This is a CO₂ reduction of approximately 32% for Case Study II when compared to the base case. From Table 25, the total expenditure for Case I is \$70.99 billion and for Case II it is \$79.09 billion, a difference of \$8.1 billion. This amounts to an increase of 10.1% in cost. This amount represents the total additional investment

required to meet a CO₂ target of 6% below 1990 levels after 2011 for Case Study II. Hence, the total cost associated with CO₂ reduction, per ton of CO₂, is \$48.79 / ton CO₂ reduced.

The average cost of electricity for Case Study II is higher than for Case Study I. From Section 4.5.3 and 4.6.3, the cost of electricity for Case Study I is 2.804 cents/kWh and for Case Study II it is 3.129 cents/kWh. The higher COE is due to the increased cost associated with meeting the CO₂ limit for Case Study II.

Overall, mitigating CO₂ emissions is a cost intensive endeavour that results in increased overall costs, which have a direct effect on increasing the total COE costs. The higher costs of meeting CO₂ targets in Case Study II are based on various factors. Namely, costs increase due to: selection and construction of cleaner, less carbon-intensive supply technologies; cost of CCS; cost of fuel switching; and operation of more expensive supply technologies.

Chapter 5

5.1 Conclusions

This project achieved the objective of developing a deterministic multi-period mixed-integer non-linear programming (MINLP) model that is able to realize the optimal mix of energy supply sources that meet current and future electricity demand, CO₂ emission targets, and lower the overall cost of electricity. This model was implemented in GAMS (General Algebraic Modeling System) using the ILOG CPLEX 10.1 solver.

The specific goals and deliverables that were accomplished as part of this thesis work are:

- A deterministic MINLP model was developed and implemented in GAMS.
- Detailed data was acquired on various supply options that were used as parameters for the model.
- The cost and feasibility of using carbon capture and storage in Ontario were examined.
- The model was applied to two case studies: a base case, and a case scenario in which Ontario's electricity sector must comply with annual CO₂ emissions of 20 Mt (6% below 1990 level) after year 2011. The relative impacts studied were based on economical, structural and environmental affects.

It should be noted that although this project was aimed at Ontario's future energy supply mix, it has been formulated in a way that allows its application to other regions or countries.

MODEL FORMULATION

Several conclusions and findings can be made in regards to the MINLP model formulation:

- The formulated MINLP mathematical model was linearized using exact linearization methods in order to avoid inherited computational difficulties of large convex non-linear models. This linearization was able to lower the computation expense while retaining the consistency of the solution.

- The objective function of the model was formulated with the aim of minimizing the net present value of the cost of electricity (COE) over a time horizon of 14 years. The formulation incorporated several time dependent parameters such as forecasted energy demand, fuel price variability, construction lead time, conservation initiatives, and increase in fixed operational and maintenance costs over time.
- The programmed GAMS model was executed and solved on an AMD Athlon 2.59 GHz, 2 GB RAM computer. Once executed, GAMS was able to find an optimal solution after a runtime of approximately 9 hours.
- Several GAMS/CPLEX solving options were considered in order to improve performance and reduce overall computational time. However, none of the options considered achieved this objective. The most effective strategy found to improve the overall performance and reduce the computation time was to reformulate the problem.

CASE STUDIES

The main conclusions of the two case studies examined in this project are as follows:

Case Study I – Base Case

- One PC power plant and five new NGCC power plants were built between 2006 and 2020. The total net capacity of all new NGCC and PC units was 5,318 MW and 526.5 MW respectively.
- No NGCC+CCS, IGCC+CCS, PC+CCS and IGCC were constructed during the time horizon considered.
- It was found that no economic justification existed to implement any CCS systems or fuel switching since there were no requirements to reduce CO₂ emissions.
- The majority of base-load demand was met through utilization of renewable, coal, and nuclear power. Peak-load demand was satisfied by various supply sources, including NGCC, renewable, coal, PC and existing NG and oil.

- Coal power plant usage was maximized in order to help meet the base-load and peak-load demand.
- Renewable energy production was utilized to its maximum of 7,902 MW during the entire time period studied.
- The total CO₂ emission over the study period amount to 525 Mt.
- The total expenditure for the entire study period was \$79.10 billion. Moreover, the average COE for the base case was 2.804 cents/kWh.

Case Study II – CO₂ Emissions 6% below 1990 levels by 2011

- Three NGCC, two NGCC+CCS, and one nuclear power plant were built between 2006 and 2020. The total net capacity of new NGCC, NGCC+CCS, and nuclear power plants was 4,305.5 MW, 2,711.7 MW, and 1,406 MW respectively. There were no new coal-fueled supply technologies built in Case Study II.
- We are able to meet an annual CO₂ target of 20 Mt (6% below 1990 levels) after 2011. This target can be achieved by implementing a combination of fuel-switching, CCS retrofit, power balancing, and construction of low emitting supply technologies.
- Nanticoke, Atikokan, and Thunder Bay power plants were fuel-switched in years 2012, 2017, and 2017, respectively. The fuel-switching of these coal power plants was implemented in order to reduce the CO₂ emitted from these power plants. The optimizer determined that it was more economically feasible to fuel-switch the above mentioned coal power plants than to shut them down. The capital cost of fuel-switching these power stations is \$10 million.
- It was determined that the option of retrofitting an existing coal power plant with a CCS system is a sound and economically feasible endeavour. In Case Study II, a CCS system was retrofitted in Lambton coal power plant in year 2018. The overall cost of implementing and operating this CCS system amount to \$54 million.
- Maximum coal power plant utilization was employed from years 2006-2011 in order to meet base-load and peak-load demand. After year 2011, coal power plants were minimally operated

to meet peak-load demand and were not used at all to meet base-load demand. Coal power plants were not utilized for base-load demand after year 2011 due to the high CO₂ emission. In order to compensate for the gap in power production created by not using coal power plants, other supply technologies were used in Case Study II to meet demand, such as NGCC+CCS, NGCC and new nuclear.

- The total CO₂ emission over the study period amounted to 359 Mt. This is a CO₂ reduction of approximately 32% when compared to the base case. The annual CO₂ emissions from the entire fleet remained constant at 20 Mt after the year 2011.
- The total expenditure for the entire study period was \$79.10 billion. The total expenditure for Case Study II was approximately 10.1% higher than for the base case. The higher cost observed in Case Study II is due to the additional expenditure required to mitigate and meet the specified CO₂ limit. Fuel cost and capital expenditure for new power stations are the main two factors that drive the total cost of Case Study II up. The increased fuel cost is due to the operation of more expensive fuel sources such as natural gas. The increase in capital expenditure is due to the construction of more expensive, but low carbon-intensive, power plants such as NGCC+CCS and nuclear units.
- The total cost associated with reducing the CO₂ emissions to 6% below 1990 levels, per ton of CO₂, was \$48.79 / ton CO₂ reduced.
- The average cost of electricity for Case Study II was higher than Case Study I. The COE for Case Study II was 3.129 cents/kWh, which is an increase of about 10.04% when compared to the base case. The higher COE was due to an increased cost associated with meeting the CO₂ limit for Case Study II.

5.2 Recommendations for Future Work

The multi-period optimization model developed in this thesis can be improved by pursuing the following recommendations:

1. The model can be reformulated from a deterministic model into a stochastic model. Reformulating the model into a stochastic multi-period framework would allow handling of probabilistic parameters. In reality, parameters such as electricity demand and fuel price fluctuations are random in nature and do not follow a deterministic path. However, the reformulation of the model into a stochastic framework may significantly increase the complexity of the model and inheritably complicate the computational time of the solution.
2. The developed model currently does not take into account the geological location of the new power plants being built. In future work, the model can be modified in order to incorporate the geographical location of the new power plants. The location of the new stations may directly affect both transmission losses and local distribution strategies.
3. The model could be improved by formulating an additional mathematical function that would allow the optimizer to design and map a complete pipe-line network for the CCS system. In order to achieve this, the geological map of a region can be divided into a zoning matrix. The path of the pipe-line network would be determined by several factors such as the cost of building a pipeline through that zone and the particular characteristics of the area.
4. Currently the formulated model is designed as a single objective function model which attempts to minimize the cost of electricity while meeting electricity demand and a specified annual CO₂ limit. The model can be reformulated into a multi-objective function that minimizes the total cost of electricity and CO₂ emission of the entire fleet simultaneously.
5. The fixed and variable O&M costs of the power stations considered in this thesis were assumed to remain constant over time. In reality, the O&M costs of power stations increase over time due to aging of the unit. In order to improve the results of the model, it is recommended that reliable time dependent O&M costs be found and used.

6. The model can be expanded by considering several additional pollutants such as NO_x, SO₂, and Particulate Matter (PM). Specifying emission limits of additional pollutants may increase the size of the model significantly, and hence, increase the overall computational time.
7. The model may be expanded to include the option of importing and exporting electricity from neighbouring regions.

Bibliography

Atomic Energy of Canada Limited. (2005). *Maintaining Flexibility: Ontario's Electricity Supply Gap and Implications for the Supply Mix*. Toronto: Atomic Energy of Canada Limited.

Ayres, M., MacRae, M., & Stogran, M. (2004). *Levelised Unit Electricity Cost Comparison of Alternate Technologies for Baseload Generation in Ontario*. Calgary: Canadian Energy Research Institute.

Benson, S. M., & Surles, T. (2006). Carbon Dioxide Capture and Storage: An Overview With Emphasis on Capture and Storage in Deep Geological Formations. *IEEE* , 94, 1795-1805.

Canadian Energy Research Institute. (2005). *Electricity Generation Technologies: Performance and Cost Characteristics*. Toronto: CERI.

Chui, F., Elkamel, A., Croiset, E., & Douglas, P. (2006). Long term electricity demand forecasting for power system planning using economic, demographic, and climatic variables. *IEEE transactions on power systems* .

Environment Canada. (2005, April). *Canada's Greenhouse Gas Inventory, 1990-2003*. Retrieved March 12, 2007, from http://www.ec.gc.ca/pdb/ghg/inventory_report/2003_report/sum_e.cfm

Hashim, H. (2006). *An Optimal Fleet-Weide CO2 Mitigation Strategy for a Network of Power Plants*. Waterloo: University of Waterloo.

Hashim, H., Douglas, P. L., Elkamel, A., & Croiset, E. (2005). An Optimization Model for Energy Planning with CO2 Emission Considerations. *Industrial & Engineering Chemistry Research* , 44, 879-890.

ICF Consulting. (2005). *Electricity Demand in Ontario - Assessing the Conservation and Demand Management (CDM) Potential*. Toronto: OPA.

IESO. (2006). *Ontario Demand Forecast: 10-Year Outlook*. Toronto.

Iyer, R. R., Grossmann, I. E., Vasantharajan, S., & Cullick, A. S. (1998). Optimal Planning and Scheduling of Offshore Oil Field Infrastructure Investment and Operations. *Industrial & Engineering Chemistry Research* , 37, 1380-1397.

Maravelias, C. T., & Grossmann, I. E. (2001). Simultaneous Planning for New Product Development and Batch Manufacturing Facilities. *Industrial & Engineering Chemistry Research* , 40, 6147-6164.

Mo, B., Hegge, J., & Wangenstee, I. (1991). Stochastic Generation Expansion Planning by Means of Stochastic Dynamic Programming. *IEEE Transaction of Power System* , 6.

Murphy, F. H., Sen, S., & Soyster, A. L. (1982). Electric utility capacity expansion planning with uncertain load forecasts. *AIIE Transaction* , 14, 52-29.

Naini, A., Walden, T., Pinno, K., Stogran, M., & Mutysheva, D. (2005). *Electricity Generation Technologies: Performance and Cost Characteristics*. Canadian Energy Institute.

Navigant Consulting. (2005). *Overview of the Portfolio Screening Model*. Toronto: OPA.

Ontario Ministry of Energy. (2007). *Electricity*. Retrieved March 15, 2007, from <http://www.energy.gov.on.ca/>

Ontario Ministry of Energy. (2005). *Replacing Ontario's Coal-Fired Electricity Generation*. Toronto: OME.

Ontario Ministry of Environment. (2006, February). *Ontario Government Ensures a Competitive Ontario Through Price Stability*. Retrieved January 12, 2007, from Ontario Ministry of Environment: http://www.energy.gov.on.ca/index.cfm?fuseaction=english.news&back=yes&news_id=120&background_id=92

Ontario Power Authority. (2005). *Supply Mix Advice Report*. Toronto: OPA.

Ontario Power Generation . (2006). *OPG* . Retrieved January 14, 2007, from www.opg.com

Ontario Power Generation. (2007, March 15). Retrieved 2007, from Ontario Power Generation: <http://www.opg.com/news/releases/>

Ontario Power Generation. (2007). *Ontario Power Generation - Emissions In Perspective*. Toronto: OPG.

Roa, A. B., & Rubin, E. S. (2002). A Technical, Economic, and environmental assessment of amine-based CO₂ capture technology for power plant greenhouse gas control. *Environmental Science Technology* , 36, 4467-4475.

Scherer, C. (1978). Estimating Electric Power System Marginal Costs. *The Economic Journal*, Vol. 88, No. 349, pp. 152-154.

Shafeen, A., Croiset, E., Douglas, P. L., & Chatzis, I. (2004a). CO₂ sequestration in Ontario, Canada. Part I: Storage. *Energy Conversion Management* , 45, 2645-2659.

Shafeen, A., Croiset, E., Douglas, P. L., & Chatzis, I. (2004b). CO₂ sequestration in Ontario, Canada. Part II: Cost estimation. *Energy Conversion Management* , 45, 2645-2659.

Winfield, M. S., Horne, M., McClenaghan, T., & Peters, R. (2004). *Power for the Future: Towards a Sustainable Electricity System for Ontario*. Canadian Environmental Law Association.

Appendix A

Forecasted Demand by Chui et al. (2006)

Table 26 - Ontario's forecasted Annual Energy demand (GWh) for lower, median, and upper bound.

Year	Median Forecast	Low Forecast with Mild Weather	High Forecast with Extreme Weather
2005	155,781,368.95	152,430,691.17	159,771,847.64
2006	157,450,326.05	154,099,648.27	161,440,804.74
2007	159,147,655.42	155,796,977.64	163,138,134.10
2008	160,873,839.38	157,523,161.61	164,864,318.07
2009	162,629,368.48	159,278,690.71	166,619,847.17
2010	164,099,675.73	160,433,932.12	168,405,220.26
2011	165,590,567.28	161,601,881.19	170,220,944.69
2012	167,102,331.32	162,782,677.69	172,067,536.44
2013	168,635,260.05	163,976,462.96	173,945,520.25
2014	170,189,649.78	165,183,379.87	175,855,429.78
2015	171,653,218.74	166,292,646.22	177,569,292.72
2016	173,135,814.10	167,413,005.24	179,308,863.60
2017	174,637,683.20	168,544,567.85	181,074,528.04
2018	176,159,076.59	169,687,446.09	182,866,677.45
2019	177,700,248.10	170,841,753.11	184,685,709.11
2020	178,781,083.54	171,541,263.16	186,162,762.81
2021	179,871,646.49	172,244,970.28	187,657,541.15
2022	180,972,024.51	172,952,899.63	189,170,256.84
2023	182,082,305.94	173,665,076.57	190,701,125.11
2024	183,202,579.89	174,381,526.56	192,250,363.81
2025	184,332,936.31	175,102,275.25	193,818,193.36

Table 27 - Ontario's forecasted annual peak-load demand (MW) for low, median, and upper bound.

Year	Median Forecast	Low Forecast	High Forecast
2005	26,183.23	25,469.63	27,027.89
2006	26,649.82	25,923.50	27,509.54
2007	27,132.88	26,393.39	28,008.17
2008	27,633.12	26,880.00	28,524.55
2009	28,151.33	27,384.09	29,059.48
2010	28,592.82	27,720.96	29,613.79
2011	29,047.56	28,065.74	30,188.37
2012	29,516.05	28,418.67	30,784.16
2013	29,998.81	28,780.00	31,402.13
2014	30,496.40	29,149.98	32,043.33
2015	30,972.45	29,494.21	32,629.86
2016	31,462.27	29,846.01	33,236.16
2017	31,966.36	30,205.59	33,863.08
2018	32,485.24	30,573.17	34,511.49
2019	33,019.45	30,948.96	35,182.33
2020	33,399.32	31,178.93	35,736.63
2021	33,787.05	31,412.01	36,306.48
2022	34,182.83	31,648.24	36,892.42
2023	34,586.86	31,887.68	37,495.01
2024	34,999.38	32,130.39	38,114.86
2025	35,420.59	32,376.42	38,752.58

Table 28 - Ontario's forecasted annual base-load demand (MW) for low, median, and upper bound.

Year	Median Forecast	Low Forecast	High Forecast
2005	12,144.65	12,144.65	12,144.65
2006	12,294.92	12,294.92	12,294.92
2007	12,445.18	12,445.18	12,445.18
2008	12,595.45	12,595.45	12,595.45
2009	12,745.71	12,745.71	12,745.71
2010	12,869.64	12,843.23	12,895.98
2011	12,993.58	12,940.75	13,046.24
2012	13,117.51	13,038.27	13,196.51
2013	13,241.44	13,135.79	13,346.77
2014	13,365.37	13,233.31	13,497.04
2015	13,480.51	13,322.01	13,629.76
2016	13,595.64	13,410.70	13,762.48
2017	13,710.78	13,499.40	13,895.19
2018	13,825.91	13,588.10	14,027.91
2019	13,941.05	13,676.80	14,160.63
2020	14,020.92	13,730.12	14,266.96
2021	14,100.78	13,783.45	14,373.29
2022	14,180.65	13,836.77	14,479.63
2023	14,260.52	13,890.10	14,585.96
2024	14,340.39	13,943.42	14,692.29
2025	14,420.26	13,996.75	14,798.62

Appendix B

Natural Gas & Coal Price Forecast from NEB

Table 29 – Forecasted NG prices from National Energy Board (NEB). The presented data is based on two scenarios: a supply-plus and a techno-vert case (Naini et al., 2005).

Year	NG Price (1986C\$/GJ)	
	Supply-Plus	Techno-Vert
2005	4.77	5.02
2006	4.76	5.08
2007	4.76	5.14
2008	4.75	5.21
2009	4.74	5.27
2010	4.72	5.33
2011	4.7	5.31
2012	4.69	5.29
2013	4.67	5.23
2014	4.65	5.18
2015	4.63	5.15
2016	4.62	5.12
2017	4.6	5.07
2018	4.57	5.03
2019	4.53	4.99
2020	4.48	4.95
2021	4.43	4.91
2022	4.39	4.86
2023	4.35	4.82
2024	4.3	4.77
2025	4.25	4.73

Table 30 - Coal price forecast from National Energy Board (NEB). Costs are expressed in terms of 1986 Canadian dollars (Naini et al., 2005).

Year	Coal Price (1986C\$/GJ)
2005	1.21
2006	1.2
2007	1.18
2008	1.17
2009	1.16
2010	1.15
2011	1.14
2012	1.13
2013	1.11
2014	1.1
2015	1.09
2016	1.09
2017	1.09
2018	1.09
2019	1.09
2020	1.09
2021	1.09
2022	1.09
2023	1.09
2024	1.09
2025	1.09

Appendix C

GAMS Model

\$title A Multiperiod Optimization Model for Energy Planning with CO2 Emission Considerations

\$ontext

Version: 1.5.15
Date: March, 08,2007

Author: Hamid Mirza

\$offtext

\$call =xls2gms @"C:\Model Data\xls2gms_data.txt"

*

*.. list all sets

*

Set

i power stations /

\$include C:\Model Data\Model Input\set_i.inc

/

F Fossil/

\$include C:\Model Data\Model Input\set_F.inc

/

NG Existing Natural Gas /

\$include C:\Model Data\Model Input\set_NG.inc

/

ENuc Existing Nuclear stations/

\$include C:\Model Data\Model Input\set_ENuc.inc

/

H Existing Hydro/

\$include C:\Model Data\Model Input\set_H.inc

/

W Existing Wind/

\$include C:\Model Data\Model Input\set_W.inc

/

*=====

*=== Subsets for existing power plants

*=====

L(F) Lambton /

\$include C:\Model Data\Model Input\set_L.inc

/

NN(F) Nanticoke /

\$include C:\Model Data\Model Input\set_NN.inc

/

A(F) Atitokan /

\$include C:\Model Data\Model Input\set_A.inc

/

LN(F) Lennox /

\$include C:\Model Data\Model Input\set_LN.inc

/

TB(F) Thunder Bay /

\$include C:\Model Data\Model Input\set_TB.inc

/

```

*=====
*=== Set of new power plants
*=====
NFP New plant fossil /
$include C:\Model Data\Model Input\set_NFP.inc
/
NFPC New plant fossil with capture/
$include C:\Model Data\Model Input\set_NFPC.inc
/
NNuc New nuclear /
$include C:\Model Data\Model Input\set_NNuc.inc
/
Impo New Imports /
$include C:\Model Data\Model Input\set_Impo.inc
/

*=====
*=== Subsets of new power plants
*=====
PP1(NFP) PC 1 without capture/
$include C:\Model Data\Model Input\set_PP1.inc
/
PP2(NFP) PC 2 without capture/
$include C:\Model Data\Model Input\set_PP2.inc
/
PP3(NFP) PC 3 without capture /
$include C:\Model Data\Model Input\set_PP3.inc
/
PI1(NFP) IGCC 1 without capture /
$include C:\Model Data\Model Input\set_PI1.inc
/
PI2(NFP) IGCC 2 without capture /
$include C:\Model Data\Model Input\set_PI2.inc
/
PI3(NFP) IGCC 3 without capture /
$include C:\Model Data\Model Input\set_PI3.inc
/
PN1(NFP) NGCC 1 without capture /
$include C:\Model Data\Model Input\set_PN1.inc
/
PN2(NFP) NGCC 2 without capture /
$include C:\Model Data\Model Input\set_PN2.inc
/
PN3(NFP) NGCC 3 without capture /
$include C:\Model Data\Model Input\set_PN3.inc
/
PC1(NFPC) PC 1 with capture/
$include C:\Model Data\Model Input\set_PC1.inc
/
PC2(NFPC) PC 2 with capture/
$include C:\Model Data\Model Input\set_PC2.inc
/
PC3(NFPC) PC 3 with capture /
$include C:\Model Data\Model Input\set_PC3.inc
/
IIC1(NFPC) IGCC 1 with capture /
$include C:\Model Data\Model Input\set_IIC1.inc
/
IIC2(NFPC) IGCC 2 with capture /
$include C:\Model Data\Model Input\set_IIC2.inc
/
IIC3(NFPC) IGCC 3 with capture /
$include C:\Model Data\Model Input\set_IIC3.inc
/
NC1(NFPC) NGCC 1 with capture /

```

```

$include C:\Model Data\Model Input\set_NC1.inc
/
NC2(NFPC) NGCC 2 with capture /
$include C:\Model Data\Model Input\set_NC2.inc
/
NC3(NFPC) NGCC 3 with capture /
$include C:\Model Data\Model Input\set_NC3.inc
/

*=====
*=== Other sets
*=====
j fuels /
$include C:\Model Data\Model Input\set_j.inc
/
k capture process /
$include C:\Model Data\Model Input\set_k.inc
/
s sequestration location /
$include C:\Model Data\Model Input\set_s.inc
/
t time horizon /
$include C:\Model Data\Model Input\set_t.inc
/
ldc Load Duration Curve ldc /
$include C:\Model Data\Model Input\set_ldc.inc
/
;

alias (t, tc);

*=====Scalar=====
*=====

Scalar R allowable electricity increment /0.01/;
Scalar Lower ACF lower bound /0.1/;
Scalar perCCS percent CO2 capture /0.9/;
Scalar MaxCapRetro maximum energy requirement for capture (MWh per yr)/1000000000/;
Scalar M big number used in CO2 emission constraints /1E11/;
Scalar Ms big number used in linearization for CCS retrofit /1E14/;
Scalar Mp big number used in linearization for new plant w cap /1E14/;
Scalar loss Transmission and distribution loss factor /0/;
Scalar Optime Maximum operation time in a year is 8760 hours /8760/;

*=====Model Parameters=====
*=====

*=== Net Capacity for Existing power stations (MW)
*
Table NetCapF(F,t) Net Capacity for Existing Coal Power Stations(MW)

$include C:\Model Data\Model Input\data_NetCapF.inc
;
Parameter NetCapNG(NG) Net Capacity for Existing NG Power Stations(MW)
/
$include C:\Model Data\Model Input\data_NetCapNG.inc
/;
Table NetCapENuc(ENuc,t) Net Capacity for Existing Nuclear Power Stations(MW)
$include C:\Model Data\Model Input\data_NetCapENuc.inc
;
Parameter NetCapH (H) Net Capacity for Existing Hydro Power Stations(MW)
/
$include C:\Model Data\Model Input\data_NetCapH.inc
/;
Parameter NetCapW(W) Net Capacity for Existing Wind Power Stations(MW)

```

```

/
$include C:\Model Data\Model Input\data_NetCapW.inc
/;

*
*===Net Capacity for New Power Plants (MW)
*
Table NetCapNFP(NFP,tc,t) Net Capacity for New Fossil Fuel Power Plant WITHOUT Capture (MW)
$include C:\Model Data\Model Input\data_NetCapNFP.inc
;
Table NetCapNFPC(NFPC,tc,t) Net Capacity for New Fossil Fuel Power Plant WITH Capture (MW)
$include C:\Model Data\Model Input\data_NetCapNFPC.inc
;
Table NetCapNNuc(NNuc,tc,t) Net Capacity for New Nuclear Power Plant (MW)
$include C:\Model Data\Model Input\data_NetCapNNuc.inc
;
Table NetCapImpo(Impo,tc,t) Net Capacity for New Imports (MW)
$include C:\Model Data\Model Input\data_NetCapImpo.inc
;
*
*===Gross Capacity for Existing power stations (MW)
*
Parameter GrossCapF(F) Gross capacity for Existing Coal Power Plants(MW)
/
$include C:\Model Data\Model Input\data_GrossCapF.inc
/;
Parameter GrossCapNG(NG) Gross capacity for Existing NG Power Plants(MW)
/
$include C:\Model Data\Model Input\data_GrossCapNG.inc
/;
Table GrossCapENuc(ENuc,t) Gross capacity for Existing Nuclear Power Plants(MW)
$include C:\Model Data\Model Input\data_GrossCapENuc.inc
;
Parameter GrossCapH(H) Gross capacity for Existing Hydro Power Plants(MW)
/
$include C:\Model Data\Model Input\data_GrossCapH.inc
/;
Parameter GrossCapW(W) Gross capacity for Existing Wind Power Plants(MW)
/
$include C:\Model Data\Model Input\data_GrossCapW.inc
/;

*
*===Gross Capacity for New Power Plants (MW)
*
Parameter GrossCapNFP(NFP) Gross Capacity for New Fossil Fuel Power Plant WITHOUT Capture (MW)
/
$include C:\Model Data\Model Input\data_GrossCapNFP.inc
/;
Parameter GrossCapNFPC(NFPC) Gross Capacity for New Fossil Fuel Power Plant WITH Capture (MW)
/
$include C:\Model Data\Model Input\data_GrossCapNFPC.inc
/;
Parameter GrossCapNNuc(NNuc) Gross Capacity for New Nuclear Power Plant (MW)
/
$include C:\Model Data\Model Input\data_GrossCapNNuc.inc
/;
Parameter GrossCapImpo(Impo) Gross Capacity for New Imports (MW)
/
$include C:\Model Data\Model Input\data_GrossCapImpo.inc
/;

*
*=== Heat rate for Existing Power Plants (GJ per MWh)
*
Table HeatrF(F,j) Heat Rate for Existing Coal Power Stations (GJ per MWh)

```

```

$include C:\Model Data\Model Input\data_HeatrF.inc
;
Parameter HeatrNG(NG) Heat Rate for Existing NG Power Stations (GJ per MWh)
/
$include C:\Model Data\Model Input\data_HeatrNG.inc
/;
Parameter HeatrENuc(ENuc) Heat Rate for Existing Nuclear Power Stations (GJ per MWh)
/
$include C:\Model Data\Model Input\data_HeatrENuc.inc
/;
Parameter HeatrH(H) Heat Rate for Existing Hydor Power Stations (GJ per MWh)
/
$include C:\Model Data\Model Input\data_HeatrH.inc
/;
Parameter HeatrW(W) Heat Rate for Existing Wind Power Stations (GJ per MWh)
/
$include C:\Model Data\Model Input\data_HeatrW.inc
/;

*
*=== Heat rate for NEW Power Plants (GJ per MWh)
*
Parameter HeatrNFP(NFP) Heat Rate for New Fossil Fuel Power Stations WITHOUT Capture(GJ per MWh)
/
$include C:\Model Data\Model Input\data_HeatrNFP.inc
/;
Parameter HeatrNFPC(NFPC) Heat Rate for New Fossil Fuel Power Stations WITH Capture(GJ per MWh)
/
$include C:\Model Data\Model Input\data_HeatrNFPC.inc
/;
Parameter HeatrNNuc(NNuc) Heat Rate for New Nuclear Power Stations (GJ per MWh)
/
$include C:\Model Data\Model Input\data_HeatrNNuc.inc
/;
Parameter HeatrImpo(Impo) Heat Rate for New Imports (GJ per MWh)
/
$include C:\Model Data\Model Input\data_HeatrImpo.inc
/;

*
*=== Fixed O&M cost ($ per MW) for Existing power stations
*
Table FixOprF(F,j) Fixed operational cost for Existing Coal Power Plants ($ per MW)
$include C:\Model Data\Model Input\data_FixOprF.inc
;
Parameter FixOprENuc(ENuc) Fixed Operation cost for existing Nuclear Power Stations($ per MW)
/
$include C:\Model Data\Model Input\data_FixOprENuc.inc
/;
Parameter FixOprNG(NG) Fixed Operation cost for existing Natural Gas Power Stations ($ per MW)
/
$include C:\Model Data\Model Input\data_FixOprNG.inc
/;
Parameter FixOprH(H) Fixed Operation cost for existing Natural Gas Power Stations ($ per MW)
/
$include C:\Model Data\Model Input\data_FixOprH.inc
/;
Parameter FixOprW(W) Fixed Operation cost for existing Wing Stations ($ per MW)
/
$include C:\Model Data\Model Input\data_FixOprW.inc
/;

*
*=== Variable O&M cost ($ per MWh) for Existing power stations
*
Table VarOprF(F,j) Variable operational cost for Existing Coal Power Plants ($ per MWh)
$include C:\Model Data\Model Input\data_VarOprF.inc

```

```

;
Parameter VarOprNG(NG) Variable Operation cost for Existing Natural Gas Power Stations ($ per MWh)
/
$include C:\Model Data\Model Input\data_VarOprNG.inc
/;
Parameter VarOprENuc(ENuc) Variable Operation cost for Existing Nuclear Power Stations ($ per MWh)
/
$include C:\Model Data\Model Input\data_VarOprENuc.inc
/;
Parameter VarOprH(H) Variable Operation cost for Existing Nuclear Power Stations ($ per MWh)
/
$include C:\Model Data\Model Input\data_VarOprH.inc
/;
Parameter VarOprW(W) Variable Operation cost for Existing Wind Power Stations ($ per MWh)
/
$include C:\Model Data\Model Input\data_VarOprW.inc
/;

*
*=== Retrofit Cost ($M20 per 1000 MW) for Coal power stations
*
Parameter RcostF(F) Retrofit cost factor due to fuel switching($M20 per 1000 MW)
/
$include C:\Model Data\Model Input\data_RcostF.inc
/;

*
*.. CO2 emissions (tonne per MWh) for Existing fossil stations
*
Table CO2F(F,j) CO2 emission from Existing Coal Power Plant (tonne per MWh)
$include C:\Model Data\Model Input\data_CO2F.inc
;
Parameter CO2NG(NG) CO2 emission from Existing NG Power Plant (tonne per MWh)
/
$include C:\Model Data\Model Input\data_CO2NG.inc
/;

*
*=== Capital cost and Cash Flow($ per MW) for New Plants

Table CcostNFP(NFP,tc,t) Capital Cost for New Fossil Fuel Power Plant WITHOUT Capture ($ per MW)
$include C:\Model Data\Model Input\data_CcostNFP.inc
;
Table CcostNFPC(NFPC,tc,t) Capital Cost for New Fossil Fuel Power Plant WITH Capture ($ per MW)
$include C:\Model Data\Model Input\data_CcostNFPC.inc
;
Table CcostNNuc(NNuc,tc,t) Capital Cost for New Nuclear Power Plant ($ per MW)
$include C:\Model Data\Model Input\data_CcostNNuc.inc
;
Table CcostImpo(Impo,tc,t) Capital Cost for New Imports ($ per MW)
$include C:\Model Data\Model Input\data_CcostImpo.inc
;

*
*=== Annual Capacity Factor (ACF) for Existing Power Stations
*
Parameter ACFF(F) Annual Capacity Factor for Existing Coal Power Plants
/
$include C:\Model Data\Model Input\data_ACFF.inc
/;
Parameter ACFNG(NG) Annual Capacity Factor for Existing Natural Gas Power Stations
/
$include C:\Model Data\Model Input\data_ACFNG.inc
/;
Parameter ACFENuc(ENuc) Annual Capacity Factor for Existing Nuclear Power Stations
/

```

```

$include C:\Model Data\Model Input\data_ACFENuc.inc
/;
Parameter ACFH(H) Annual Capacity Factor for Existing Nuclear Power Stations
/
$include C:\Model Data\Model Input\data_ACFH.inc
/;
Parameter ACFW(W) Annual Capacity Factor for Existing Wind Power Stations
/
$include C:\Model Data\Model Input\data_ACFW.inc
/;

*
*=== Annual Capacity Factor (ACF) for New Power stations
*
Parameter ACFNFP(NFP) Annual Capacity Factor for new Fossil Fuel Power Without Capture
/
$include C:\Model Data\Model Input\data_ACFNFP.inc
/;
Parameter ACFNFPC(NFPC) Annual Capacity Factor for new Fossil Fuel Power Without Capture
/
$include C:\Model Data\Model Input\data_ACFNFPC.inc
/;
Parameter ACFNNuc(NNuC) Annual Capacity Factor for new nuclear
/
$include C:\Model Data\Model Input\data_ACFNNuc.inc
/;
Parameter ACFImpo(Impo) Annual Capacity Factor for Imports
/
$include C:\Model Data\Model Input\data_ACFImpo.inc
/;

*
*=== Fixed operational cost ($ per MW) for NEW Power Plants
*
Parameter FixOprNFP(NFP) Fixed O&M cost for NEW fossil fuel power plants without CO2 Capture ($ per MW)
/
$include C:\Model Data\Model Input\data_FixOprNFP.inc
/;
Parameter FixOprNFPC(NFPC) Fixed O&M cost for NEW fossil fuel power plants with CO2 Capture ($ per MW)
/
$include C:\Model Data\Model Input\data_FixOprNFPC.inc
/;
Parameter FixOprNNuc(NNuC) Fixed O&M cost (including fuel cost) for NEW nuclear ($ per MW)
/
$include C:\Model Data\Model Input\data_FixOprNNuc.inc
/;
Parameter FixOprImpo(Impo) Fixed O&M cost for NEW Out-of-Province Imports ($ per MW)
/
$include C:\Model Data\Model Input\data_FixOprImpo.inc
/;

*
*=== Variable operational cost ($ per MWh) NEW Power Plant without capture
*
parameter VarOprNFP(NFP) Variable O&M cost for new fossil fuel power plants with CO2 Capture ($ per MWh)
/
$include C:\Model Data\Model Input\data_VarOprNFP.inc
/;

parameter VarOprNFPC(NFPC) Variable O&M cost for new fossil fuel power plants with CO2 Capture ($ per MWh)
/
$include C:\Model Data\Model Input\data_VarOprNFPC.inc
/;

parameter VarOprNNuc(NNuC) Variable O&M cost (including fuel cost) for new nuclear ($ per MWh)
/
$include C:\Model Data\Model Input\data_VarOprNNuc.inc

```



```

/;

parameter VarOpImpo(Impo) Variable O&M cost for new Out-of-Province Imports ($ per MWh)
/
$include C:\Model Data\Model Input\data_VarOpImpo.inc
/;

*===CO2 emissions (tonne per MWh) from New Fossil Fuel Power Plants
*
parameter CO2NFP(NFP) CO2 emissions from New Fossil Power Plant without capture (tonne per MWh)
/
$include C:\Model Data\Model Input\data_CO2NFP.inc
/;

parameter CO2NFPC(NFPC) CO2 emissions from New Fossil Power Plant without capture(tonne per MWh)
/
$include C:\Model Data\Model Input\data_CO2NFPC.inc
/;

*
*=== Carbon capture and storage cost ($ per tonne CO2 capture)
*
parameter ccsF(F) ccs cost for existing Fossil Fuel Power Plant ($ per tonne CO2 capture)
/
$include C:\Model Data\Model Input\data_ccsF.inc
/;
parameter ccsNFPC(NFPC) ccs cost for new Fossil Fuel Power Plant with capture ($ per tonne CO2 capture)
/
$include C:\Model Data\Model Input\data_ccsNFPC.inc
/;

*.. Sequestration Cost for Existing Fossil Stations($ per tonne CO2 storage)
*
Table seqF(F,s) sequestration cost for Existing Coal-Fired Power plants ($ per tonne CO2 storage)
$include C:\Model Data\Model Input\data_seqF.inc
;

*=== Sequestration Cost for new power stations WITH capture process ($ per tonne CO2 storage)
*
Table seqNFPC(NFPC,s) sequestration cost for New Fossil Power Plant with capture ($ per tonne CO2 storage)
$include C:\Model Data\Model Input\data_seqNFPC.inc
;

*=== Elec required for CO2 capture for Existing Coal-fired power plants

Table EreqF(F,j) Elec required for CO2 capture in Existing Coal-Fired Power Plant (MWh per tonne CO2 capture)
$include C:\Model Data\Model Input\data_EreqF.inc
;

*
*=== Forecasted price of Coal and Natural Gas ($ per GJ)
*
Table FuelPrice(j,t) Forecasted Coal and Natural Gas prices ($ per GJ)
$include C:\Model Data\Model Input\data_FuelPrice.inc
;
* Forecasted price of Coal and NG ($ per GJ) - These values are the same as the ones found in
* table FuelPrice(j,t). The only diff is that the data is in a Parameter format.
*
parameter Pcoal(t) Forecasted Coal Price ($ per GJ)
/
$include C:\Model Data\Model Input\data_Pcoal.inc
/;
parameter NGcost(t) Forecasted Natural Gas Price ($ per GJ)
/
$include C:\Model Data\Model Input\data_NGcost.inc
/;

```

```

*
* CO2 Emission Limits for Entire Fleet Each Year (tonnes per year)
*
parameter CO2Limit(t) CO2 Emission Limits for Entire Fleet each year
/
$include C:\Model Data\Model Input\data_CO2Limit.inc
/;
*
* Carbon Emission Credit Cost ($ per tonnes CO2)
*
parameter CreditCost(t) Cost of buying CO2 Emission Credits ($ per tonne CO2)
/
$include C:\Model Data\Model Input\data_CreditCost.inc
/;

* Demand Each year (MW per year)
*
Table CapDemand(ldc,t) Capacity demand each year (MW per year)
$include C:\Model Data\Model Input\data_CapDemand.inc
;

Table GenDemand(ldc,t) Generating demand each year (MWh per year)
$include C:\Model Data\Model Input\data_GenDemand.inc
;

Table Rconstraint(F,tc,t) Generating demand each year (MWh per year)
$include C:\Model Data\Model Input\data_Rconstraint.inc
;
Table Timeldc(ldc,t) Operation time for each segment of ldc
$include "C:\Model Data\Model Input\data_Timeldc.inc"
;

* Energy savings from Conservation strategy in Ontario (MW per year)
*
parameter Conservation(t) Total electricity savings from conservation strategies (MW per year)
/
$include C:\Model Data\Model Input\data_Conservation.inc
/;

Table yh
$include "C:\Model Data\Model Input\data_yh.inc"
;
Table yw
$include "C:\Model Data\Model Input\data_yw.inc"
;
Table yng
$include "C:\Model Data\Model Input\data_yng.inc"
;
Table yENuc
$include "C:\Model Data\Model Input\data_yENuc.inc"
;

$ontext
parameter UpperNFP(NFP)
/
$include C:\Model Data\Model Input\data_UpperNFP.inc
/;
parameter UpperNFPC(NFPC)
/
$include C:\Model Data\Model Input\data_UpperNFPC.inc
/;
parameter UpperNNuc(NNuc)
/
$include C:\Model Data\Model Input\data_UpperNNuc.inc
/;

```

```

parameter UpperImpo(Impo)
/
$include C:\Model Data\Model Input\data_UpperImpo.inc
/;
$offtext

*.. list all variables
*

Variables
cost objective function

MWred(t) total energy required for capture process on all fossil stations during period t

PowerActiveRetro(F,t)

*---POSITIVE VARIABLES---

Credit(t) Amount of CO2 subtracted from emission cap (during period t) due to Carbon Credit Purchase

EF(F,ldc,t)    adjusted elec generation for Existing fossil power stations during period t (MWh per year)

EENuc(ENuc,ldc,t) adjusted elec generation for nuclear power plants during period t (MWh per year)
EH(H,ldc,t)    adjusted elec generation for hydro power plants during period t (MWh per year)
EW(W,ldc,t)    adjusted elec generation for wind power plants during period t (MWh per year)
ENG(NG,ldc,t)  adjusted elec generation for natural gas power plants during period t (MWh per year)

ENFP(NFP,ldc,t)  elec generation for PC during period t (MWh per year)
ENFPC(NFPC,ldc,t) elec generation for PC with capture during period t (MWh per year)
ENNuc(ENuc,ldc,t) elec generation for new nuclear during period t (MWh per year)
Elmpo(Impo,ldc,t) elec generation for new Imports during period t (MWh per year)

EFj(F,j,ldc,t)  adjusted elec generation for Existing fossil power stations using j fuel during period t (MWh per year)

EkFj(F,j,k,ldc,t) electricity required for capture process in F(MWh per year)

gamaF(F,j,k,ldc,t)  Linearized variable = EFj * zF = (MWh per year)

CO2F1(t) Lambton CO2 emissions during period t
CO2F2(t) Nanticoke CO2 emissions during period t
CO2F3(t) Atitokan CO2 emissions during period t
CO2F5(t) Lennox CO2 emissions during period t
CO2F6(t) Thunder Bay CO2 emissions during period t
CO2F7(t) Existing NG station CO2 emissions during period t
CO2P(t) CO2 Emissions From New Power Plants during period t

XF(F,j,t)  fuel selection for existing fossil fuel power plant

yNFP(NFP,tc) decision whether to build a NEW fossil fuel without capture
yNFPC(NFPC,tc) decision whether to build a NEW fossil fuel with capture
yNNuc(ENuc,tc) decision either to build a new nuclear power plant
yImpo(Impo,tc) decision whether to Import electricity

zF(F,j,k,t)  decision whether to put a Carbon Capture on existing fossil fuel power plant

retro(F,tc);

Binary variable XF,yNFP,yNFPC,yNNuc,yImpo,zF,retro;

Positive Variables EF,EENuc,EH,EW,ENG,ENFP,ENFPC,ENNuc,Elmpo,EFj,EkFj,gamaF,
CO2F1,CO2F2,CO2F3,CO2F5,CO2F6,CO2P,MWred,PowerActiveRetro,Credit;

Equations
totcost total annual cost ($ per year)

totMWh(ldc,t)

```

```

swiL(F,t),gas1(t),gas2(t),gas3(t),gas4(t)

epF(F,j,t),epENuc(ENuc,t),eph(h,t),epw(w,t),epng(ng,t)
epF2(F,j,t),epENuc2(ENuc,t)

totEkF(F,j,k,ldc,t)

c1(F,j,k,ldc,t)

f1(F,t),w1(F,j,t),z1(F,k,t)

conF1(F,j,k,ldc,t),conF2(F,j,k,ldc,t),conF3(F,j,k,ldc,t)

startNFP(NFP),startNFPC(NFPC),startNNuc(NNuc),startImpo(Impo)

retro1(F,t),retro2(F,t),retro3(F)
;

*=====OBJECTIVE FUNCTION=====
*=====
*
* Fixed O&M cost for existing power plants
totcost.. cost =e= (sum((F,j,t),XF(F,j,t)*FixOprF(F,j)*GrossCapF(F))+
    sum((NG,t),yNG(NG,t)*FixOprNG(NG)*GrossCapNG(NG))+
    sum((ENuc,t),yENuc(ENuc,t)*FixOprENuc(ENuc)*GrossCapENuc(ENuc,t))+
    sum((H,t),yH(H,t)*FixOprH(H)*GrossCapH(H))+
    sum((W,t),yw(W,t)*FixOprW(W)*GrossCapW(W))+

* Variable O&M cost for existing power plants
    sum((F,j,ldc,t),EFj(F,j,ldc,t)*Timeldc(ldc,t)*VarOprF(F,j))+
    sum((NG,ldc,t),ENG(NG,ldc,t)*Timeldc(ldc,t)*VarOprNG(NG))+
    sum((ENuc,ldc,t),EENuc(ENuc,ldc,t)*Timeldc(ldc,t)*VarOprENuc(ENuc))+
    sum((H,ldc,t),EH(H,ldc,t)*Timeldc(ldc,t)*VarOprH(H))+
    sum((W,ldc,t),EW(W,ldc,t)*Timeldc(ldc,t)*VarOprW(W))+

* Fuel Cost for existing coal and natural gas power plants
    sum((F,j,ldc,t), EFj(F,j,ldc,t)*Timeldc(ldc,t)*HeatrF(F,j)*FuelPrice(j,t))+
    sum((NG,ldc,t),ENG(NG,ldc,t)*Timeldc(ldc,t)*NGcost(t)*HeatrNG(NG))+

* Retrofit cost due to fuel switching on existing power plants
    sum((F,tc),RcostF(F)*GrossCapF(F)*retro(F,tc))+

* Capital cost for NEW fossil fuel power plant with and without capture
    sum((NFP,tc,t),CcostNFP(NFP,tc,t)*GrossCapNFP(NFP)*yNFP(NFP,tc))+
    sum((NFPC,tc,t),CcostNFPC(NFPC,tc,t)*GrossCapNFPC(NFPC)*yNFPC(NFPC,tc))+

* Capital cost for NEW nuclear and Imports
    sum((NNuc,tc,t),CcostNNuc(NNuc,tc,t)*GrossCapNNuc(NNuc)*yNNuc(NNuc,tc))+
    sum((Impo,tc,t),CcostImpo(Impo,tc,t)*GrossCapImpo(Impo)*yImpo(Impo,tc))+

* Fixed operating cost for new fossil fuel power plant with and without capture
    sum((NFP,tc,t),FixOprNFP(NFP)*NetCapNFP(NFP,tc,t)*yNFP(NFP,tc))+
    sum((NFPC,tc,t),FixOprNFPC(NFPC)*NetCapNFPC(NFPC,tc,t)*yNFPC(NFPC,tc))+

* Variable operating cost for new fossil fuel power plant with and without capture
    sum((NFP,t,ldc),VarOprNFP(NFP)*ENFP(NFP,ldc,t)*Timeldc(ldc,t))+
    sum((NFPC,t,ldc),VarOprNFPC(NFPC)*ENFPC(NFPC,ldc,t)*Timeldc(ldc,t))+

* Fuel Cost for new fossil fuel power plant with and without capture
    sum((PP1,ldc,t),Pcoal(t)*HeatrNFP(PP1)*ENFP(PP1,ldc,t)*Timeldc(ldc,t))+
    sum((PP2,ldc,t),Pcoal(t)*HeatrNFP(PP2)*ENFP(PP2,ldc,t)*Timeldc(ldc,t))+
    sum((PP3,ldc,t),Pcoal(t)*HeatrNFP(PP3)*ENFP(PP3,ldc,t)*Timeldc(ldc,t))+
    sum((PI1,ldc,t),Pcoal(t)*HeatrNFP(PI1)*ENFP(PI1,ldc,t)*Timeldc(ldc,t))+
    sum((PI2,ldc,t),Pcoal(t)*HeatrNFP(PI2)*ENFP(PI2,ldc,t)*Timeldc(ldc,t))+

```

$$\begin{aligned} & \text{sum}((\text{PI3},\text{ldc},\text{t}),\text{Pcoal}(\text{t}) * \text{HeatrNFP}(\text{PI3}) * \text{ENFP}(\text{PI3},\text{ldc},\text{t}) * \text{Timeldc}(\text{ldc},\text{t})) + \\ & \text{sum}((\text{PN1},\text{ldc},\text{t}),\text{NGcost}(\text{t}) * \text{HeatrNFP}(\text{PN1}) * \text{ENFP}(\text{PN1},\text{ldc},\text{t}) * \text{Timeldc}(\text{ldc},\text{t})) + \\ & \text{sum}((\text{PN2},\text{ldc},\text{t}),\text{NGcost}(\text{t}) * \text{HeatrNFP}(\text{PN2}) * \text{ENFP}(\text{PN2},\text{ldc},\text{t}) * \text{Timeldc}(\text{ldc},\text{t})) + \\ & \text{sum}((\text{PN3},\text{ldc},\text{t}),\text{NGcost}(\text{t}) * \text{HeatrNFP}(\text{PN3}) * \text{ENFP}(\text{PN3},\text{ldc},\text{t}) * \text{Timeldc}(\text{ldc},\text{t})) + \\ & \text{sum}((\text{PC1},\text{ldc},\text{t}),\text{Pcoal}(\text{t}) * \text{HeatrNFPC}(\text{PC1}) * \text{ENFPC}(\text{PC1},\text{ldc},\text{t}) * \text{Timeldc}(\text{ldc},\text{t})) + \\ & \text{sum}((\text{PC2},\text{ldc},\text{t}),\text{Pcoal}(\text{t}) * \text{HeatrNFPC}(\text{PC2}) * \text{ENFPC}(\text{PC2},\text{ldc},\text{t}) * \text{Timeldc}(\text{ldc},\text{t})) + \\ & \text{sum}((\text{PC3},\text{ldc},\text{t}),\text{Pcoal}(\text{t}) * \text{HeatrNFPC}(\text{PC3}) * \text{ENFPC}(\text{PC3},\text{ldc},\text{t}) * \text{Timeldc}(\text{ldc},\text{t})) + \\ & \text{sum}((\text{IIC1},\text{ldc},\text{t}),\text{Pcoal}(\text{t}) * \text{HeatrNFPC}(\text{IIC1}) * \text{ENFPC}(\text{IIC1},\text{ldc},\text{t}) * \text{Timeldc}(\text{ldc},\text{t})) + \\ & \text{sum}((\text{IIC2},\text{ldc},\text{t}),\text{Pcoal}(\text{t}) * \text{HeatrNFPC}(\text{IIC2}) * \text{ENFPC}(\text{IIC2},\text{ldc},\text{t}) * \text{Timeldc}(\text{ldc},\text{t})) + \\ & \text{sum}((\text{IIC3},\text{ldc},\text{t}),\text{Pcoal}(\text{t}) * \text{HeatrNFPC}(\text{IIC3}) * \text{ENFPC}(\text{IIC3},\text{ldc},\text{t}) * \text{Timeldc}(\text{ldc},\text{t})) + \\ & \text{sum}((\text{NC1},\text{ldc},\text{t}),\text{NGcost}(\text{t}) * \text{HeatrNFPC}(\text{NC1}) * \text{ENFPC}(\text{NC1},\text{ldc},\text{t}) * \text{Timeldc}(\text{ldc},\text{t})) + \\ & \text{sum}((\text{NC2},\text{ldc},\text{t}),\text{NGcost}(\text{t}) * \text{HeatrNFPC}(\text{NC2}) * \text{ENFPC}(\text{NC2},\text{ldc},\text{t}) * \text{Timeldc}(\text{ldc},\text{t})) + \\ & \text{sum}((\text{NC3},\text{ldc},\text{t}),\text{NGcost}(\text{t}) * \text{HeatrNFPC}(\text{NC3}) * \text{ENFPC}(\text{NC3},\text{ldc},\text{t}) * \text{Timeldc}(\text{ldc},\text{t})) + \end{aligned}$$

*Fixed O&M cost include fuel for NEW nuclear and Imports

$$\begin{aligned} & \text{sum}((\text{NNuc},\text{tc},\text{t}),\text{FixOprNNuc}(\text{NNuc}) * \text{NetCapNNuc}(\text{NNuc},\text{tc},\text{t}) * \text{yNNuc}(\text{NNuc},\text{tc})) + \\ & \text{sum}((\text{Impo},\text{tc},\text{t}),\text{FixOprImpo}(\text{Impo}) * \text{NetCapImpo}(\text{Impo},\text{tc},\text{t}) * \text{yImpo}(\text{Impo},\text{tc})) + \end{aligned}$$

*Variable O&M cost include fuel for NEW nuclear and Imports

$$\begin{aligned} & \text{sum}((\text{NNuc},\text{ldc},\text{t}),\text{VarOprNNuc}(\text{NNuc}) * \text{ENNuc}(\text{NNuc},\text{ldc},\text{t}) * \text{Timeldc}(\text{ldc},\text{t})) + \\ & \text{sum}((\text{Impo},\text{ldc},\text{t}),\text{VarOprImpo}(\text{Impo}) * \text{Elmpo}(\text{Impo},\text{ldc},\text{t}) * \text{Timeldc}(\text{ldc},\text{t})) + \end{aligned}$$

*Capital and operating cost for capture process on existing fossil stations

$$\begin{aligned} & \text{sum}((\text{F},\text{j},\text{k},\text{ldc},\text{t}),\text{ccsF}(\text{F}) * \text{perCCS} * \text{CO2F}(\text{F},\text{j}) * \text{gammaF}(\text{F},\text{j},\text{k},\text{ldc},\text{t}) * \text{Timeldc}(\text{ldc},\text{t})) + \\ & \text{sum}((\text{NFPC},\text{ldc},\text{t}),\text{ccsNFPC}(\text{NFPC}) * \text{CO2NFPC}(\text{NFPC}) * \text{ENFPC}(\text{NFPC},\text{ldc},\text{t}) * \text{Timeldc}(\text{ldc},\text{t})) + \end{aligned}$$

*Cost of purchasing CO2 emission credits

$$\text{sum}(\text{t},\text{Credit}(\text{t}) * \text{CreditCost}(\text{t}));$$

*=====EXPENDITURE REPORT=====

Equation CapitalNew(t),CapitalRetro(tc),CapitalFixOld(t),CapitalFixNew(t), CapitalFuel(t),

CapitalVarOld(t),CapitalVarNew(t),CapitalCCS(t),CapitalCredit(t) ;

variable CapitalExpenNew(t),CapitalExpenRetro(tc),CapitalExpenFixOld(t),CapitalExpenFixNew(t),

CapitalExpenFuel(t),CapitalExpenVarOld(t),CapitalExpenVarNew(t),CapitalExpenCCS(t),

CapitalExpenCredi(t);

CapitalNew(t).. CapitalExpenNew(t) =e=
$$\begin{aligned} & \text{sum}((\text{NFP},\text{tc}),\text{CcostNFP}(\text{NFP},\text{tc},\text{t}) * \text{GrossCapNFP}(\text{NFP}) * \text{yNFP}(\text{NFP},\text{tc})) + \\ & \text{sum}((\text{NFPC},\text{tc}),\text{CcostNFPC}(\text{NFPC},\text{tc},\text{t}) * \text{GrossCapNFPC}(\text{NFPC}) * \text{yNFPC}(\text{NFPC},\text{tc})) + \\ & \text{sum}((\text{NNuc},\text{tc}),\text{CcostNNuc}(\text{NNuc},\text{tc},\text{t}) * \text{GrossCapNNuc}(\text{NNuc}) * \text{yNNuc}(\text{NNuc},\text{tc})) + \\ & \text{sum}((\text{Impo},\text{tc}),\text{CcostImpo}(\text{Impo},\text{tc},\text{t}) * \text{GrossCapImpo}(\text{Impo}) * \text{yImpo}(\text{Impo},\text{tc})); \end{aligned}$$

CapitalRetro(tc).. CapitalExpenRetro(tc) =e=
$$\text{sum}((\text{F}),\text{RcostF}(\text{F}) * \text{GrossCapF}(\text{F}) * \text{retro}(\text{F},\text{tc}));$$

CapitalFixOld(t).. CapitalExpenFixOld(t) =e=

$$\begin{aligned} & \text{sum}((\text{F},\text{j}),\text{XF}(\text{F},\text{j},\text{t}) * \text{FixOprF}(\text{F},\text{j}) * \text{GrossCapF}(\text{F})) + \\ & \text{sum}((\text{NG}),\text{yNG}(\text{NG},\text{t}) * \text{FixOprNG}(\text{NG}) * \text{GrossCapNG}(\text{NG})) + \\ & \text{sum}((\text{ENuc}),\text{yENuc}(\text{ENuc},\text{t}) * \text{FixOprENuc}(\text{ENuc}) * \text{GrossCapENuc}(\text{ENuc},\text{t})) + \\ & \text{sum}((\text{H}),\text{yH}(\text{H},\text{t}) * \text{FixOprH}(\text{H}) * \text{GrossCapH}(\text{H})) + \\ & \text{sum}((\text{W}),\text{yW}(\text{W},\text{t}) * \text{FixOprW}(\text{W}) * \text{GrossCapW}(\text{W})); \end{aligned}$$

CapitalFixNew(t).. CapitalExpenFixNew(t) =e=

$$\begin{aligned} & \text{sum}((\text{NFP},\text{tc}),\text{FixOprNFP}(\text{NFP}) * \text{NetCapNFP}(\text{NFP},\text{tc},\text{t}) * \text{yNFP}(\text{NFP},\text{tc})) + \\ & \text{sum}((\text{NFPC},\text{tc}),\text{FixOprNFPC}(\text{NFPC}) * \text{NetCapNFPC}(\text{NFPC},\text{tc},\text{t}) * \text{yNFPC}(\text{NFPC},\text{tc})) + \\ & \text{sum}((\text{NNuc},\text{tc}),\text{FixOprNNuc}(\text{NNuc}) * \text{NetCapNNuc}(\text{NNuc},\text{tc},\text{t}) * \text{yNNuc}(\text{NNuc},\text{tc})) + \\ & \text{sum}((\text{Impo},\text{tc}),\text{FixOprImpo}(\text{Impo}) * \text{NetCapImpo}(\text{Impo},\text{tc},\text{t}) * \text{yImpo}(\text{Impo},\text{tc})); \end{aligned}$$

CapitalFuel(t).. CapitalExpenFuel(t) =e=

$$\begin{aligned} & \text{sum}((\text{F},\text{j},\text{ldc}),\text{EF}(\text{F},\text{j},\text{ldc},\text{t}) * \text{Timeldc}(\text{ldc},\text{t}) * \text{HeatrF}(\text{F},\text{j}) * \text{FuelPrice}(\text{j},\text{t})) + \\ & \text{sum}((\text{NG},\text{ldc}),\text{ENG}(\text{NG},\text{ldc},\text{t}) * \text{Timeldc}(\text{ldc},\text{t}) * \text{NGcost}(\text{t}) * \text{HeatrNG}(\text{NG})) + \\ & \text{sum}((\text{PP1},\text{ldc}),\text{Pcoal}(\text{t}) * \text{HeatrNFP}(\text{PP1}) * \text{ENFP}(\text{PP1},\text{ldc},\text{t}) * \text{Timeldc}(\text{ldc},\text{t})) + \\ & \text{sum}((\text{PP2},\text{ldc}),\text{Pcoal}(\text{t}) * \text{HeatrNFP}(\text{PP2}) * \text{ENFP}(\text{PP2},\text{ldc},\text{t}) * \text{Timeldc}(\text{ldc},\text{t})) + \\ & \text{sum}((\text{PP3},\text{ldc}),\text{Pcoal}(\text{t}) * \text{HeatrNFP}(\text{PP3}) * \text{ENFP}(\text{PP3},\text{ldc},\text{t}) * \text{Timeldc}(\text{ldc},\text{t})) + \\ & \text{sum}((\text{P11},\text{ldc}),\text{Pcoal}(\text{t}) * \text{HeatrNFP}(\text{P11}) * \text{ENFP}(\text{P11},\text{ldc},\text{t}) * \text{Timeldc}(\text{ldc},\text{t})) + \\ & \text{sum}((\text{P12},\text{ldc}),\text{Pcoal}(\text{t}) * \text{HeatrNFP}(\text{P12}) * \text{ENFP}(\text{P12},\text{ldc},\text{t}) * \text{Timeldc}(\text{ldc},\text{t})) + \\ & \text{sum}((\text{P13},\text{ldc}),\text{Pcoal}(\text{t}) * \text{HeatrNFP}(\text{P13}) * \text{ENFP}(\text{P13},\text{ldc},\text{t}) * \text{Timeldc}(\text{ldc},\text{t})) + \\ & \text{sum}((\text{PN1},\text{ldc}),\text{NGcost}(\text{t}) * \text{HeatrNFP}(\text{PN1}) * \text{ENFP}(\text{PN1},\text{ldc},\text{t}) * \text{Timeldc}(\text{ldc},\text{t})) + \end{aligned}$$

$\text{sum}((\text{PN2},\text{ldc}),\text{NGcost}(t)*\text{HeatrNFP}(\text{PN2})*\text{ENFP}(\text{PN2},\text{ldc},t)*\text{Timeldc}(\text{ldc},t))+$
 $\text{sum}((\text{PN3},\text{ldc}),\text{NGcost}(t)*\text{HeatrNFP}(\text{PN3})*\text{ENFP}(\text{PN3},\text{ldc},t)*\text{Timeldc}(\text{ldc},t))+$
 $\text{sum}((\text{PC1},\text{ldc}),\text{Pcoal}(t)*\text{HeatrNFPC}(\text{PC1})*\text{ENFPC}(\text{PC1},\text{ldc},t)*\text{Timeldc}(\text{ldc},t))+$
 $\text{sum}((\text{PC2},\text{ldc}),\text{Pcoal}(t)*\text{HeatrNFPC}(\text{PC2})*\text{ENFPC}(\text{PC2},\text{ldc},t)*\text{Timeldc}(\text{ldc},t))+$
 $\text{sum}((\text{PC3},\text{ldc}),\text{Pcoal}(t)*\text{HeatrNFPC}(\text{PC3})*\text{ENFPC}(\text{PC3},\text{ldc},t)*\text{Timeldc}(\text{ldc},t))+$
 $\text{sum}((\text{IIC1},\text{ldc}),\text{Pcoal}(t)*\text{HeatrNFPC}(\text{IIC1})*\text{ENFPC}(\text{IIC1},\text{ldc},t)*\text{Timeldc}(\text{ldc},t))+$
 $\text{sum}((\text{IIC2},\text{ldc}),\text{Pcoal}(t)*\text{HeatrNFPC}(\text{IIC2})*\text{ENFPC}(\text{IIC2},\text{ldc},t)*\text{Timeldc}(\text{ldc},t))+$
 $\text{sum}((\text{IIC3},\text{ldc}),\text{Pcoal}(t)*\text{HeatrNFPC}(\text{IIC3})*\text{ENFPC}(\text{IIC3},\text{ldc},t)*\text{Timeldc}(\text{ldc},t))+$
 $\text{sum}((\text{NC1},\text{ldc}),\text{NGcost}(t)*\text{HeatrNFPC}(\text{NC1})*\text{ENFPC}(\text{NC1},\text{ldc},t)*\text{Timeldc}(\text{ldc},t))+$
 $\text{sum}((\text{NC2},\text{ldc}),\text{NGcost}(t)*\text{HeatrNFPC}(\text{NC2})*\text{ENFPC}(\text{NC2},\text{ldc},t)*\text{Timeldc}(\text{ldc},t))+$
 $\text{sum}((\text{NC3},\text{ldc}),\text{NGcost}(t)*\text{HeatrNFPC}(\text{NC3})*\text{ENFPC}(\text{NC3},\text{ldc},t)*\text{Timeldc}(\text{ldc},t));$

CapitalVarOld(t)..

$\text{CapitalExpenVarOld}(t)=e=$
 $\text{sum}((\text{F},\text{j},\text{ldc}),\text{EFj}(\text{F},\text{j},\text{ldc},t)*\text{Timeldc}(\text{ldc},t)*\text{VarOprF}(\text{F},\text{j}))+$
 $\text{sum}((\text{NG},\text{ldc}),\text{ENG}(\text{NG},\text{ldc},t)*\text{Timeldc}(\text{ldc},t)*\text{VarOprNG}(\text{NG}))+$
 $\text{sum}((\text{ENuc},\text{ldc}),\text{EENuc}(\text{ENuc},\text{ldc},t)*\text{Timeldc}(\text{ldc},t)*\text{VarOprENuc}(\text{ENuc}))+$
 $\text{sum}((\text{H},\text{ldc}),\text{EH}(\text{H},\text{ldc},t)*\text{Timeldc}(\text{ldc},t)*\text{VarOprH}(\text{H}))+$
 $\text{sum}((\text{W},\text{ldc}),\text{EW}(\text{W},\text{ldc},t)*\text{Timeldc}(\text{ldc},t)*\text{VarOprW}(\text{W}));$

CapitalVarNew(t).. CapitalExpenVarNew(t)=e=

$\text{sum}((\text{NFP},\text{ldc}),\text{VarOprNFP}(\text{NFP})*\text{ENFP}(\text{NFP},\text{ldc},t)*\text{Timeldc}(\text{ldc},t))+$
 $\text{sum}((\text{NFPC},\text{ldc}),\text{VarOprNFPC}(\text{NFPC})*\text{ENFPC}(\text{NFPC},\text{ldc},t)*\text{Timeldc}(\text{ldc},t))+$
 $\text{sum}((\text{NNuc},\text{ldc}),\text{VarOprNNuc}(\text{NNuc})*\text{ENNuc}(\text{NNuc},\text{ldc},t)*\text{Timeldc}(\text{ldc},t))+$
 $\text{sum}((\text{Impo},\text{ldc}),\text{VarOprImpo}(\text{Impo})*\text{Elmpo}(\text{Impo},\text{ldc},t)*\text{Timeldc}(\text{ldc},t));$

CapitalCCS(t).. CapitalExpenCCS(t)=e=

$\text{sum}((\text{F},\text{j},\text{k},\text{ldc}),\text{ccsf}(\text{F},\text{j})*\text{perCCS}*\text{CO2F}(\text{F},\text{j})*\text{gamaF}(\text{F},\text{j},\text{k},\text{ldc},t)*\text{Timeldc}(\text{ldc},t))+$
 $\text{sum}((\text{NFPC},\text{ldc}),\text{ccsnfpc}(\text{NFPC})*\text{CO2NFPC}(\text{NFPC})*\text{ENFPC}(\text{NFPC},\text{ldc},t)*\text{Timeldc}(\text{ldc},t));$

CapitalCredit(t).. CapitalExpenCredi(t)=e= (Credit(t)*CreditCost(t));

*=====MODEL CONSTRAINT=====

*=====CO2 SYSTEM INFORMATION++++=====

Equation

$\text{totCO2}(t)$ total (from all power stations) CO2 emission during period t (tonne per year)
 $\text{totCO2F1}(t),\text{totCO2F2}(t),\text{totCO2F3}(t),\text{totCO2F5}(t),\text{totCO2F6}(t),\text{totCO2F7},\text{totCO2P}(t);$

* Lambton CO2 emissions during period t

$\text{totCO2F1}(t).. \text{CO2F1}(t) =e= \text{sum}((\text{L},\text{j},\text{ldc}),\text{CO2F}(\text{L},\text{j})*\text{EFj}(\text{L},\text{j},\text{ldc},t)*\text{Timeldc}(\text{ldc},t))-$
 $(\text{sum}((\text{L},\text{j},\text{k},\text{ldc}),\text{CO2F}(\text{L},\text{j})*\text{perCCS}*\text{gamaF}(\text{L},\text{j},\text{k},\text{ldc},t)*\text{Timeldc}(\text{ldc},t)));$

* Nanticoke CO2 emissions during period t

$\text{totCO2F2}(t).. \text{CO2F2}(t) =e= \text{sum}((\text{NN},\text{j},\text{ldc}),\text{CO2F}(\text{NN},\text{j})*\text{EFj}(\text{NN},\text{j},\text{ldc},t)*\text{Timeldc}(\text{ldc},t))-$
 $(\text{sum}((\text{NN},\text{j},\text{k},\text{ldc}),\text{CO2F}(\text{NN},\text{j})*\text{perCCS}*\text{gamaF}(\text{NN},\text{j},\text{k},\text{ldc},t)*\text{Timeldc}(\text{ldc},t)));$

* Atitokan CO2 emissions during period t

$\text{totCO2F3}(t).. \text{CO2F3}(t) =e= \text{sum}((\text{A},\text{j},\text{ldc}),\text{CO2F}(\text{A},\text{j})*\text{EFj}(\text{A},\text{j},\text{ldc},t)*\text{Timeldc}(\text{ldc},t))-$
 $(\text{sum}((\text{A},\text{j},\text{k},\text{ldc}),\text{CO2F}(\text{A},\text{j})*\text{perCCS}*\text{gamaF}(\text{A},\text{j},\text{k},\text{ldc},t)*\text{Timeldc}(\text{ldc},t)));$

* Lennox Power Plant CO2 emissions during period t

$\text{totCO2F5}(t).. \text{CO2F5}(t) =e= \text{sum}((\text{LN},\text{j},\text{ldc}),\text{CO2F}(\text{LN},\text{j})*\text{EFj}(\text{LN},\text{j},\text{ldc},t)*\text{Timeldc}(\text{ldc},t));$

* Thunder Bay CO2 emissions during period t

$\text{totCO2F6}(t).. \text{CO2F6}(t) =e= \text{sum}((\text{TB},\text{j},\text{ldc}),\text{CO2F}(\text{TB},\text{j})*\text{EFj}(\text{TB},\text{j},\text{ldc},t)*\text{Timeldc}(\text{ldc},t))-$
 $(\text{sum}((\text{TB},\text{j},\text{k},\text{ldc}),\text{CO2F}(\text{TB},\text{j})*\text{perCCS}*\text{gamaF}(\text{TB},\text{j},\text{k},\text{ldc},t)*\text{Timeldc}(\text{ldc},t)));$

* Existing NG Power Plant CO2 emissions during period t

$\text{totCO2F7}(t).. \text{CO2F7}(t) =e= \text{sum}((\text{NG},\text{ldc}), \text{CO2NG}(\text{NG})*\text{ENG}(\text{NG},\text{ldc},t)*\text{Timeldc}(\text{ldc},t));$

* CO2 Emissions From New Power Plants during period t

$\text{totCO2P}(t).. \text{CO2P}(t) =e= \text{sum}((\text{NFP},\text{ldc}),\text{CO2NFP}(\text{NFP})*\text{ENFP}(\text{NFP},\text{ldc},t)*\text{Timeldc}(\text{ldc},t))+$
 $\text{sum}((\text{NFPC},\text{ldc}),\text{CO2NFPC}(\text{NFPC})*\text{ENFPC}(\text{NFPC},\text{ldc},t)*\text{Timeldc}(\text{ldc},t));$

* Total CO2 emissions during period t (tonne per yr)

$\text{totCO2}(t).. \text{CO2F1}(t)+\text{CO2F2}(t)+\text{CO2F3}(t)+\text{CO2F5}(t)+\text{CO2F6}(t)+\text{CO2F7}(t)+\text{CO2P}(t)-\text{Credit}(t)=\text{CO2Limit}(t);$

*=====ENERGY CONSTRAINT=====

*=====

* energy required for capture process on fossil stations during period t (MWh per yr)

totEkF(F,j,k,lcd,t).. EkFj(F,j,k,lcd,t) =e= CO2F(F,j)*EreqF(F,j)*perCCS*gammaF(F,j,k,lcd,t)*Timelcd(lcd,t);

* total net electricity generated must satisfy forecasted demand in period t

totMWh(lcd,t).. (1-loss)*(sum((F,j),EFj(F,j,lcd,t)*Timelcd(lcd,t))+
sum(ENuc,EENuc(ENuc,lcd,t)*Timelcd(lcd,t))+
sum(H,EH(H,lcd,t)*Timelcd(lcd,t))+
sum(W,EW(W,lcd,t)*Timelcd(lcd,t))+
sum(NG,ENG(NG,lcd,t)*Timelcd(lcd,t))+

sum(NFP,ENFP(NFP,lcd,t)*Timelcd(lcd,t))+
sum(NFPC,ENFPC(NFPC,lcd,t)*Timelcd(lcd,t))+
sum(NNuc,ENNuc(NNuc,lcd,t)*Timelcd(lcd,t))+
sum(Impo,Elmpo(Impo,lcd,t)*Timelcd(lcd,t))-
sum((F,j,k),EkFj(F,j,k,lcd,t))) =g= GenDemand(lcd,t);

Equation Generation;

Positive variable Gen(lcd,t);

Generation(lcd,t).. Gen(lcd,t) =e= (1-loss)*(sum((F,j),EFj(F,j,lcd,t)*Timelcd(lcd,t))+
sum(ENuc,EENuc(ENuc,lcd,t)*Timelcd(lcd,t))+
sum(H,EH(H,lcd,t)*Timelcd(lcd,t))+
sum(W,EW(W,lcd,t)*Timelcd(lcd,t))+
sum(NG,ENG(NG,lcd,t)*Timelcd(lcd,t))+

sum(NFP,ENFP(NFP,lcd,t)*Timelcd(lcd,t))+
sum(NFPC,ENFPC(NFPC,lcd,t)*Timelcd(lcd,t))+
sum(NNuc,ENNuc(NNuc,lcd,t)*Timelcd(lcd,t))+
sum(Impo,Elmpo(Impo,lcd,t)*Timelcd(lcd,t))-
sum((F,j,k),EkFj(F,j,k,lcd,t)));

Equation Generation2,Generation3,Generation4,Generation5,Generation6,Generation7,

Generation8,Generation9,Generation10,Generation11;

Positive variable Gen2(lcd,t),Gen3(lcd,t),Gen4(lcd,t),Gen5(lcd,t),Gen11(lcd,t)

Gen6(lcd,t),Gen7(lcd,t),Gen8(lcd,t),Gen9(lcd,t),Gen10(lcd,t);

Generation2(lcd,t).. Gen2(lcd,t) =e= sum((F,j),EFj(F,j,lcd,t)*Timelcd(lcd,t));
Generation3(lcd,t).. Gen3(lcd,t) =e= sum(ENuc,EENuc(ENuc,lcd,t)*Timelcd(lcd,t));
Generation4(lcd,t).. Gen4(lcd,t) =e= sum(H,EH(H,lcd,t)*Timelcd(lcd,t));
Generation5(lcd,t).. Gen5(lcd,t) =e= sum(W,EW(W,lcd,t)*Timelcd(lcd,t));
Generation6(lcd,t).. Gen6(lcd,t) =e= sum(NG,ENG(NG,lcd,t)*Timelcd(lcd,t));
Generation7(lcd,t).. Gen7(lcd,t) =e= sum(NFP,ENFP(NFP,lcd,t)*Timelcd(lcd,t));
Generation8(lcd,t).. Gen8(lcd,t) =e= sum(NFPC,ENFPC(NFPC,lcd,t)*Timelcd(lcd,t));
Generation9(lcd,t).. Gen9(lcd,t) =e= sum(NNuc,ENNuc(NNuc,lcd,t)*Timelcd(lcd,t));
Generation10(lcd,t).. Gen10(lcd,t) =e= sum(Impo,Elmpo(Impo,lcd,t)*Timelcd(lcd,t));
Generation11(lcd,t).. Gen11(lcd,t) =e= sum((F,j,k),EkFj(F,j,k,lcd,t));

**Nuclear plants may not be used to meet peak load

Equation LdcENucBase(ENuc,t), LdcNNucBase(NNuc,t);

LdcENucBase(ENuc,t).. EENuc(ENuc,'peak',t) =e= 0;

LdcNNucBase(NNuc,t).. ENNuc(NNuc,'peak',t) =e= 0;

* Fuel selection and plant shut down

swil(F,t).. sum(j,XF(F,j,t)) =l= 1;

gas1(t).. XF('LN1','coal',t) =e= 0;

gas2(t).. XF('LN2','coal',t) =e= 0;

gas3(t).. XF('LN3','coal',t) =e= 0;

gas4(t).. XF('LN4','coal',t) =e= 0;

* Existing Station Shut-down and Generation Capacity Constraint

epF(F,j,t).. sum(ldc,EFj(F,j,ldc,t)) =l= NetCapF(F,t)*XF(F,j,t);
epENuc(ENuc,t).. sum(ldc,EENuc(ENuc,ldc,t)) =l= NetCapENuc(ENuc,t)*yEnUC(ENuc,t);
epNG(NG,t).. sum(ldc,ENG(NG,ldc,t)) =e= NetCapNg(NG)*yNG(NG,t);
epH(H,t).. sum(ldc,EH(H,ldc,t)) =e= NetCapH(H)*yH(H,t);
epW(W,t).. sum(ldc,EW(W,ldc,t)) =e= NetCapW(W)*yW(W,t);

*lower bound on exiting power plants AND capacity factor constraint

epF2(F,j,t).. sum(ldc,EFj(F,j,ldc,t)) =g= 0.1*NetCapF(F,t)*XF(F,j,t);
epENuc2(ENuc,t).. sum(ldc,EENuc(ENuc,ldc,t)) =g= 0.1*NetCapENuc(ENuc,t)*yEnUC(ENuc,t);

Equation CapFacF(F,j,t),CapFacENuc(ENuc,t);

CapFacF(F,j,t).. sum(ldc,EFj(F,j,ldc,t)*Timeldc(ldc,t)) =l= NetCapF(F,t)*Optime*ACFF(F)*XF(F,j,t);
CapFacENuc(ENuc,t).. sum(ldc,EENuc(ENuc,ldc,t)*Timeldc(ldc,t)) =l= NetCapENuc(ENuc,t)*Optime*ACFENuc(ENuc)*yEnUC(ENuc,t);

* Construction time lead time and maximum generation constraint for New plants

Equation newNFP(NFP,t),newNFPC(NFPC,t),newNNuc(NNuc,t),newImpo(Impo,t);

newNFP(NFP,t).. sum(ldc,ENFP(NFP,ldc,t)) =l= sum(tc,NetCapNFP(NFP,tc,t)*yNFP(NFP,tc));
newNFPC(NFPC,t).. sum(ldc,ENFPC(NFPC,ldc,t)) =l= sum(tc,NetCapNFPC(NFPC,tc,t)*yNFPC(NFPC,tc));
newNNuc(NNuc,t).. sum(ldc,ENNuc(NNuc,ldc,t)) =l= sum(tc,NetCapNNuc(NNuc,tc,t)*yNNuc(NNuc,tc));
newImpo(Impo,t).. sum(ldc,EImpo(Impo,ldc,t)) =l= sum(tc,NetCapImpo(Impo,tc,t)*yImpo(Impo,tc));

Equation newNFP2(NFP,t),newNFPC2(NFPC,t),newNNuc2(NNuc,t);

newNFP2(NFP,t).. sum(ldc,ENFP(NFP,ldc,t)) =g= sum(tc,0.1*NetCapNFP(NFP,tc,t)*yNFP(NFP,tc));
newNFPC2(NFPC,t).. sum(ldc,ENFPC(NFPC,ldc,t)) =g= sum(tc,0.1*NetCapNFPC(NFPC,tc,t)*yNFPC(NFPC,tc));
newNNuc2(NNuc,t).. sum(ldc,ENNuc(NNuc,ldc,t)) =g= sum(tc,0.1*NetCapNNuc(NNuc,tc,t)*yNNuc(NNuc,tc));

Equation CapFacNFP,CapFacNFPC,CapFacNNuc,CapFacImpo;

CapFacNFP(NFP,t).. sum(ldc,ENFP(NFP,ldc,t)*Timeldc(ldc,t)) =l= sum(tc,NetCapNFP(NFP,tc,t)*yNFP(NFP,tc)*Optime*ACFNFP(NFP));
CapFacNFPC(NFPC,t).. sum(ldc,ENFPC(NFPC,ldc,t)*Timeldc(ldc,t)) =l= sum(tc,NetCapNFPC(NFPC,tc,t)*yNFPC(NFPC,tc)*Optime*ACFNFP(NFPC));
CapFacNNuc(NNuc,t).. sum(ldc,ENNuc(NNuc,ldc,t)*Timeldc(ldc,t)) =l= sum(tc,NetCapNNuc(NNuc,tc,t)*yNNuc(NNuc,tc)*Optime*ACFNNuc(NNuc));
CapFacImpo(Impo,t).. sum(ldc,EImpo(Impo,ldc,t)*Timeldc(ldc,t)) =l= sum(tc,NetCapImpo(Impo,tc,t)*yImpo(Impo,tc)*Optime*ACFImpo(Impo));

* retrofit constraints

retro1(F,t).. PowerActiveRetro(F,t) =e= sum(tc,\$Rconstraint(F,tc,t), retro(F,tc));

retro2(F,t).. PowerActiveRetro(F,t) =e= XF(F,"NG",t);

retro3(F).. sum(tc, retro(F,tc)) =l= 1;

* Start of construction for new plant can occur only once during the time horizon

startNFP(NFP).. sum(tc,yNFP(NFP,tc)) =l= 1;
startNFPC(NFPC).. sum(tc,yNFPC(NFPC,tc)) =l= 1;
startNNuc(NNuc).. sum(tc,yNNuc(NNuc,tc)) =l= 1;
startImpo(Impo).. sum(tc,yImpo(Impo,tc)) =l= 1;

* CO2 capture energy constraints

c1(F,j,k,ldc,t).. EkFj(F,j,k,ldc,t) =l= (MaxCapRetro*zF(F,j,k,t));

* Selection of CO2 capture process

f1(F,t).. sum((j,k),zF(F,j,k,t)) =l= 1;

* If the fossil plants shut down no capture process will put online

w1(F,j,t).. sum(k,zF(F,j,k,t)) =l= XF(F,j,t);

* No capture process on natural gas power plants

z1(F,k,t).. zF(F,'ng',k,t) =e= 0;

** LINEARIZATION ****Capture Process on Coal-fired station ****

conF1(F,j,k,ldc,t).. gamaF(F,j,k,ldc,t) =l= EFj(F,j,ldc,t);
conF2(F,j,k,ldc,t).. gamaF(F,j,k,ldc,t) =g= EFj(F,j,ldc,t)-M*(1-zF(F,j,k,t));
conF3(F,j,k,ldc,t).. gamaF(F,j,k,ldc,t) =l= M*zF(F,j,k,t);

*Test

Equation hydro(t),hydro2(t);

hydro(t).. sum(H,EH(H,'base',t)) =l= 3424;

hydro2(t).. sum(H,EH(H,'base',t)) =e= 3424;

Model kyoto /all /;

file opt /cplex.opt/;

*putclose opt 'probe 3';

*putclose opt 'probe 3'/mipemphasis 2/'cuts 2';

putclose opt 'probe 3'/nodefileind 3/'workmem 500';

*putclose opt 'probe 3'/mipemphasis 2/'mipordind =1';

kyoto.optfile=1;

option LIMROW = 0;

option LIMCOL = 0;

option optcr = 0;

option mip = CPLEX;

option iterlim = 1000000000;

option reslim = 16009000;

Solve kyoto using mip minimizing cost;

execute 'copy preformatted.xls results.xls';

execute_unload 'kyoto' EFj,EEnuc,EH,EW,ENG,XF,yENuc,yH,yW,yNG,ENFP,ENFPC,ENNuc,Elmpo,
yNFP,yNFPC,yNNuc,yImpo,CO2F1,CO2F2,CO2F3,CO2F5,CO2F6,CO2P,CO2F7,CO2Limit,Credit,
zF,PowerActiveRetro,CapitalExpenNew,CapitalExpenRetro,CapitalExpenFixOld,
CapitalExpenFixNew,CapitalExpenFuel,CapitalExpenVarOld,CapitalExpenVarNew,
CapitalExpenCCS,CapitalExpenCredi,TimeLdc,GenDemand,Gen,Gen2,Gen3,Gen4,Gen5,Gen6
Gen7,Gen8,Gen9,Gen10,Gen11;

execute 'GDXXRW i=kyoto.gdx o=results.xls var=EFj.l rng=Existing_Power!A1:AB109 merge'

execute 'GDXXRW i=kyoto.gdx o=results.xls var=EEnuc.l rng=Existing_Power!A117:AA127 merge'

execute 'GDXXRW i=kyoto.gdx o=results.xls var=EH.l rng=Existing_Power!A132:AA248 merge'

execute 'GDXXRW i=kyoto.gdx o=results.xls var=EW.l rng=Existing_Power!A252:AA258 merge'

execute 'GDXXRW i=kyoto.gdx o=results.xls var=ENG.l rng=Existing_Power!A265:AA305 merge'

*

execute 'GDXXRW i=kyoto.gdx o=results.xls var=XF.l rng=Shutdown_Existing!a1:AA55 merge'

execute 'GDXXRW i=kyoto.gdx o=results.xls var=yENuc.l rng=Shutdown_Existing!a62:z67 merge'

execute 'GDXXRW i=kyoto.gdx o=results.xls var=yH.l rng=Shutdown_Existing!a72:z130 merge'

execute 'GDXXRW i=kyoto.gdx o=results.xls var=yW.l rng=Shutdown_Existing!a134:z137 merge'

execute 'GDXXRW i=kyoto.gdx o=results.xls var=yNG.l rng=Shutdown_Existing!a144:Z164 merge'

*

execute 'GDXXRW i=kyoto.gdx o=results.xls var=ENFP.l rng=New_Power!a1:AA157 merge'

execute 'GDXXRW i=kyoto.gdx o=results.xls var=ENFPC.l rng=New_Power!a1:AA157 merge'

execute 'GDXXRW i=kyoto.gdx o=results.xls var=ENNuc.l rng=New_Power!a1:AA157 merge'

execute 'GDXXRW i=kyoto.gdx o=results.xls var=Elmpo.l rng=New_Power!a1:AA157 merge'

*

execute 'GDXXRW i=kyoto.gdx o=results.xls var=yNFP.l rng=New_Construction!a1:Z79 merge'

execute 'GDXXRW i=kyoto.gdx o=results.xls var=yNFPC.l rng=New_Construction!a1:Z79 merge'

execute 'GDXXRW i=kyoto.gdx o=results.xls var=yNNuc.l rng=New_Construction!a1:Z79 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls var=yImpo.l rng=New_Construction!a1:Z79 merge'

execute 'GDXXRW i=kyoto.gdx o=results.xls var=CO2F1.l rng=CO2_Emission!b3 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls var=CO2F2.l rng=CO2_Emission!b5 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls var=CO2F3.l rng=CO2_Emission!b7 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls var=CO2F5.l rng=CO2_Emission!b11 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls var=CO2F6.l rng=CO2_Emission!b13 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls var=CO2F7.l rng=CO2_Emission!b9 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls var=CO2P.l rng=CO2_Emission!b15 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls par=CO2Limit rng=CO2_Emission!b21 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls var=Credit.l rng=CO2_Emission!b19 merge'

execute 'GDXXRW i=kyoto.gdx o=results.xls var=wF.l rng=Sequestration_E!a1:AA55 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls var=wNFPC.l rng=Sequestration_N!a1:AA73 merge'

execute 'GDXXRW i=kyoto.gdx o=results.xls var=zF.l rng=CCS_Existing!a1:AB28 merge'

execute 'GDXXRW i=kyoto.gdx o=results.xls var=CapitalExpenNew.l rng=Expenditure!a3:p4 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls var=CapitalExpenRetro.l rng=Expenditure!a5:p6 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls var=CapitalExpenFixOld.l rng=Expenditure!a7:p8 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls var=CapitalExpenFixNew.l rng=Expenditure!a9:p10 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls var=CapitalExpenFuel.l rng=Expenditure!a11:p12 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls var=CapitalExpenVarOld.l rng=Expenditure!a13:p14 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls var=CapitalExpenVarNew.l rng=Expenditure!a15:p16 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls var=CapitalExpenCCS.l rng=Expenditure!a17:p18 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls var=CapitalExpenCredi.l rng=Expenditure!a19:p20 merge'

execute 'GDXXRW i=kyoto.gdx o=results.xls par=Timeldc rng=Summary!ac84:aw86 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls par=GenDemand rng=COE!B3:Q5 merge'

execute 'GDXXRW i=kyoto.gdx o=results.xls var=Gen rng=Gen!A1:P3 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls var=Gen2 rng=Gen!A5:P7 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls var=Gen3 rng=Gen!A9:P11 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls var=Gen4 rng=Gen!A13:P15 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls var=Gen5 rng=Gen!A17:P19 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls var=Gen6 rng=Gen!A21:P23 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls var=Gen7 rng=Gen!A25:P27 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls var=Gen8 rng=Gen!A29:P31 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls var=Gen9 rng=Gen!A33:P35 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls var=Gen10 rng=Gen!A37:P39 merge'
execute 'GDXXRW i=kyoto.gdx o=results.xls var=Gen11 rng=Gen!A41:P43 merge'

execute 'ShellExecute results.xls';